

Rochester Water Reclamation Plant 2019 Facilities Plan



J4325



LOWER ENERGY // CLEAN DESIGN
DECREASED MAINTENANCE // INNOVATIVE PROCESSES



Rochester Water Reclamation Plant Facilities Plan

Prepared for
City of Rochester
Rochester, MN

I hereby certify that this plan, specification, or report was prepared by me or under my direct supervision and that I am a duly Licensed Professional Engineer under the laws of the State of Minnesota.

Signature: 

Name: Harold Voth, P.E.

Date: June 10, 2020 License No. 17045



Table of Contents

List of Figures	iv
List of Tables.....	v
List of Abbreviations.....	vi
Executive Summary	ES-1
NPDES Permit	ES-2
Phase 1 Improvements	ES-2
Phase 2 improvements	ES-3
Phase 3 Improvements	ES-5
Summary and Opinion of Probable Costs	ES-8
1. Introduction.....	9
1.1 Background	9
1.2 Project Definition.....	11
2. Flows and Loadings.....	12
2.1 Plant Influent Flows and Loadings	12
3. Design Criteria	14
3.1 Effluent Water Quality	14
4. Existing Facility Condition.....	15
4.1 Facility Condition	15
5. Process Optimization.....	17
5.1 Existing Process Unit Capacities	17
5.1.1 Primary Clarifiers 1 and 2.....	17
5.1.2 Intermediate Clarifiers.....	18
5.1.3 Final Clarifiers	18
5.2 Recommendations	19
6. Biological Nutrient Removal.....	20
6.1 Alternative Screening.....	20
6.1.1 Process Technology Screening Evaluation.....	20
6.1.2 Treatment Process Pathway Screening.....	21
6.2 Treatment Level 1: Existing Permit with Total Phosphorus (TP) Limit of 0.8 mg/L	23
6.3 Treatment Level 2: Total Nitrogen (TN) of 10 mg/L and TP less than 0.4 mg/L	24
6.4 Treatment Level 2X: NO _x -N of 10 mg/L and TP less than 0.4 mg/L	25
6.5 Treatment Level 3: Total Nitrogen (TN) of 4 mg/L and TP less than 0.1 mg/L.....	25
6.6 A/O Simultaneous Nitrification Denitrification with Hydrocyclones.....	26
6.7 Treatment Level 4: Salty Water Discharges	29
6.8 Sidestream Enhanced Biological Phosphorus Removal.....	30
7. Final Effluent.....	31

7.1	Disinfection.....	31
7.1.1	Chlorine Addition.....	31
7.1.2	Dechlorination.....	31
7.2	Outfall Modifications.....	31
7.3	Summary and Opinion of Probable Costs.....	33
8.	Solids Handling.....	34
8.1	Current Solids Production.....	34
8.2	Projected Solids Production.....	34
8.3	Thickening.....	35
8.3.1	Primary Sludge.....	35
8.3.2	Waste Activated Sludge.....	35
8.3.3	Digested Solids.....	35
8.4	Mesophilic Anaerobic Digestion.....	36
8.4.1	Existing Digestion Capacity.....	36
8.4.2	Digestion Alternatives.....	36
8.5	Thickened Digested Solids Storage and Pumping.....	36
8.5.1	Hauling Reduction.....	36
8.5.2	Thickened Digested Solid Storage.....	36
8.5.3	Digested Solids Pumping.....	37
8.6	Digester Control Building No. 1 Improvements.....	37
8.7	Waste Gas Burner.....	37
8.8	Summary of Opinion of Probable Costs.....	38
9.	Biogas Utilization.....	39
9.1	Background.....	39
9.2	Biogas Alternatives Analysis.....	39
9.2.1	Emissions and Air Permitting Considerations.....	40
9.3	Alternatives Comparison and Evaluation.....	40
9.3.1	NPV Analysis.....	40
10.	Reuse and Energy Recovery.....	42
10.1	Existing Systems.....	42
10.1.1	Heat Recovery: Low and Medium Temperature Loop.....	42
10.1.2	Water Reuse: Spray Water System.....	42
10.1.3	Heat Recovery: ABC Low Temperature Loop.....	43
10.1.4	Heat Recovery: Primary Clarifier 3 Heating.....	43
10.1.5	Water Reuse: Gravity Belt Thickener Washwater.....	43
10.1.6	Flushing Water.....	43
10.2	Recommendations.....	43
10.3	Summary of Opinion of Probable Costs.....	45
11.	Recommendations and Implementation Plan.....	46
11.1	Phase 1 Improvements.....	46

11.2 Phase 2 Improvements..... 47

11.3 Phase 3 Improvements..... 47

11.4 Summary and Opinion of Probable Costs..... 49

12. Clean Water Revolving Fund Checklists and Forms..... 50

13. Limitations..... 51

14. References..... 52

Appendices

Appendix 1 Technical Memorandum 1 Influent Flows and Loadings

Appendix 2 Technical Memorandum 2 Wastewater Characterization and BioWin™ Calibration

Appendix 3 Technical Memorandum 3 Plant Hydraulic Evaluation

Appendix 4 Technical Memorandum 4 Primary Clarifier Computational Fluid Dynamics Modeling

Appendix 5 Technical Memorandum 5 Final Clarifier Computational Fluid Dynamics Modeling

Appendix 6 Technical Memorandum 6 Liquid Stream Alternative Evaluation

Appendix 7 Technical Memorandum 7 Solids Alternative Evaluation

Appendix 8 Technical Memorandum 8 Digester Gas Management

Appendix 9 Technical Memorandum 9 Disinfection and Outfall Evaluation

Appendix 10 Technical Memorandum 10 Whole Plant Evaluation

Appendix 11 Technical Memorandum 11 Heat Recovery Loop Alternative

Appendix 12 Technical Memorandum 12 NPDES Permitting Process

Appendix 13 Technical Memorandum 13 Industrial Discharge Wasteloads and Practices

List of Figures

Figure ES-1. Phase 1 capital improvements and recommendations..... 3

Figure ES-2. Phase 2 capital improvements and recommendations..... 5

Figure ES-3. Phase 3 capital improvements and recommendations..... 6

Figure ES-4. Phase 4 capital improvements and recommendations..... 7

Figure 1-1. Rochester WRP flow schematic..... 10

Figure 1-2. WRP site layout..... 11

Figure 5-1. Primary Clarifier 2 recommended inlet channel stub baffle configuration 17

Figure 5-2. Diffuser plate configuration 18

Figure 6-1. Rochester process screening selected liquid stream treatment pathways and alternatives 22

Figure 6-2. Rochester WRP Liquid Stream BioWin™ flow schematic 22

Figure 6-3. Treatment Level 1 Anaerobic/Oxic (A/O) Key Facility Requirements and Layouts. (Year 2045)..... 23

Figure 6-4. Treatment Level 2 5 Stage BNR Key Facility Requirements and Layouts. (Year 2045).... 24

Figure 6-5. Treatment Level 2X 3-Stage BNR Key Facility Requirements and Layouts. (Year 2045)..	25
Figure 6-6. Treatment Level 3 5 Stage BNR Key Facility Requirements and Layouts. (Year 2045)....	26
Figure 6-7. A/O SND with Hydrocyclones Key Facility Requirements and Layouts. (Year 2045).....	27
Figure 7-1. Alternative 2: Rochester WRP serpentine CCT with center channel configuration.....	32
Figure 10-1. Proposed heat recover and water reuse system	44

List of Tables

Table ES-1. Rochester WRP Planning Effluent Water Quality Criteria.....	1
Table ES-2. Rochester WRP Phased Improvements Opinion of Probable Costs ^a	8
Table 1-1. Plant Expansion History.....	9
Table 2-1. Rochester WRP Design Influent Flow and Loading Projections.....	13
Table 3-1. Rochester WRP Planning Effluent Water Quality Criteria.....	14
Table 4-1. Rochester WRP Existing Facility Condition Assessment Issues.....	15
Table 5-1. Rochester HPOAS Intermediate Clarifier Capacity Analysis Results	18
Table 5-2. Rochester Final Clarifier Capacity Analysis Results	19
Table 6-1. Pathway 2 Opinion of Probable Construction Cost, Capital Cost, Annual Operating Cost, and Net Present Value.....	29
Table 7-1. Disinfection and Outfall Capital Improvements Opinion of Probable Costs	33
Table 8-1. Rochester WRP Current Solids Loading	34
Table 8-2. Rochester WRP Projected Solids Loading.....	35
Table 8-3. Solids Handling Improvements Opinion of Probable Costs ^a	38
Table 9-1. Biogas Utilization Alternatives 20-year NPV Results (\$, millions)	40
Table 10-1. Immediate Capital Improvements Opinion of Probable Costs ^a	45
Table 11-1. Rochester WRP Phased Improvements Opinion of Probable Costs ^a	49

List of Abbreviations

°C	degree(s) Celsius	CH ₄	methane
°F	degree(s) Fahrenheit	CHP	combined heat and power
µm	microns	CIP	Capital improvement plan
µm	micro-meter	CIP	Clean in Place
3D	three-dimensional	City	City of Rochester
A/O	anaerobic/oxic	Cl ₂	chlorine
A ₂ O	anaerobic/anoxic/oxic	CNG	compressed natural gas
AA	annual average	CO	carbon monoxide
AACEI	Association for the Advancement of Cost Engineering International	CO ₂	carbon dioxide
AAS	air activated sludge	COD	Chemical Oxygen Demand
ABC	Aeration Basin Complex	COP	Clean Out of Place
ADWF	average dry weather flow	CSA	Canadian Standards Association
AGS	aerobic granular sludge	cy	cubic yard
AHJ	authority having jurisdiction	d	day(s)
AMPI	American Milk Producers, Inc.	DAF	dissolved air flotation
ANSI	American National Standards Institute	DG	digester gas
ATP	adenosine triphosphate	DO	dissolved oxygen
Ave	average	DSS	dispersed suspended solids
AWW	average wet weather	DT	dry tons
AWWF	average wet weather flow	EBPR	enhanced biological phosphorus removal
BACT	best available control technology	EDI	energy-dissipating inlet
BC	Brown and Caldwell	EPA	Environmental Protection Agency
BCE	business case evaluation	EQ	equalization
BFP	belt filter press	ESS	effluent suspended solids
BNR	biological nutrient removal	F	fraction(s)
BOD	Biochemical Oxygen Demand	FC	final clarifier
Btu	British thermal unit(s)	Fe	iron
C	Celsius	FeCl ₃	ferric chloride
cap-d	capita per day	FEDWA	Flocculating Energy Dissipating Well Arrangement
CBOD	Carbonaceous Biochemical Oxygen Demand	FOG	fats, oils, and grease
cBOD ₅	5-day carbonaceous biochemical oxygen demand	fps	foot/feet per second
CCF	thousand cubic feet	FRP	fiberglass reinforced plastic
ccf	100 cubic feet	FSMA	Food Safety Management Act
CCT	chlorine contact tank	ft	foot/feet
CFD	computational fluid dynamics	ft ²	square foot/feet
CFH	cubic foot/feet per hour	ft ³	cubic foot/feet
cfm	cubic foot per minute	FTE	full-time equivalent
		g	gram(s)

G	velocity gradient	LOX	liquid oxygen
gal	gallon(s)	LT	low temperature
GBT	gravity belt thickener	m	meter(s)
GGE	gasoline gallon equivalent	M	million
GLUMRB	Great Lakes Upper Mississippi River Board	MABR	membrane aerated bioreactor
gpd	gallon(s) per day	MAC	oxygen system air compressor
gpm	gallon(s) per minute	MAD	mesophilic anaerobic digestion
GT	gravity thickener	max	maximum
GTO	gravity thickener overflow	MD	maximum day
H ₂ S	hydrogen sulfide	MDI	Morrill Dispersion Index
HDPE	high-density polyethylene	MERC	Minnesota Energy Resources
HEX	heat exchanger	MF	membrane filtration
HGL	hydraulic gradeline	mg	milligram(s)
HHV	higher heating value	MG	million gallons
HLR	hydraulic loading rate	mg/L	milligrams per liter
hp	horsepower	MgCl ₂	magnesium chloride
HPO	high-purity oxygen	mgd	million gallons per day
HPOAS	high-purity oxygen activated sludge	min	minute
hr	hour(s)	min	minimum
HRT	hydraulic residence time	mL	milliliter(s)
HSW	high-strength waste	MLE	modified Ludzack Ettinger
HVAC	heating, ventilation, and air conditioning	MLR	mixed liquor recycle
HX	heat exchanger	MLSS	mixed liquor suspended solids
IC	Intermediate Clarifier	MM	maximum month
IFAS	integrated fixed film activate sludge	mm	millimeters
in	inch(es)	MMBtu	million British thermal unit(s)
ISS	influent suspended solids	MPCA	Minnesota Pollution Control Agency
k	solids settling parameter	MPN	most probable number
K	thousand	MT	medium temperature
KA	floc aggregation rate coefficient	MW	maximum week
KB	floc break-up rate coefficient	MW	megawatt(s)
Kg	kilograms	N	nitrogen
KOH	caustic potash	N/A	Not Applicable
kW	kilowatt	N ₂	nitrogen
kWh	kilowatt hours	NA	Not Applicable
L	liter(s)	NaHSO ₃	sodium bisulfite
lb(s)	pound(s)	NaOH	sodium hydroxide (caustic)
lb/d	Pounds Per Day	NFPA	National Fire Protection Association
lbs/hr	pounds per hour	NG	natural gas
LF	linear foot/feet		
LHV	lower heating value	no	initial number of particles

NO _x -N	nitrite plus nitrate as nitrogen	SKU	stock keeping unit
NPDES	National Pollutant Discharge Elimination System	SLR	solids loading rate
NPV	net present value	SND	simultaneous nitrification denitrification
nt	number of particles at time	SOR	surface overflow rate
O&M	operation and maintenance	SPA	state point analysis
O ₂	oxygen	SRT	solids retention time
OLR	organic loading rate	SSV30	30-minute settled sludge volume
OTR	oxygen transfer rate	SVI	sludge volume index
P	phosphorus	SVISN	sludge volume index—2-liter settleometer unstirred
PAO	phosphorus accumulating organisms	t	time
PC	Primary Clarifier	T	tons
PD	positive displacement	TAD	thermophilic anaerobic digestion
PE	primary effluent	TCT	theoretical contact time
pH	potential hydrogen	Td	contact time
PHWWF	peak hour wet weather flow	Title 22	Title 22 California Code of Regulations
PIWWF	peak instantaneous wet weather flow	TKN	total Kjeldahl nitrogen
ppbv	part(s) per billion by volume	TM	technical memorandum
ppmv	part(s) per million by volume	TN	total nitrogen
PS	primary sludge	TP	total phosphorus
psi	pound(s) per square inch	tpd	tons per day
psig	pounds per square inch -gage	TPS	thickened primary sludge
PSRP	process to significantly reduce pathogens	TS	total solids
PVC	polyvinyl chloride	TSS	total suspended solids
PW	peak week	TWAS	thickened waste activated sludge
QAP	Quality assurance plan	UF	Ultrafiltration
RAS	return activated sludge	USEPA	United States Environmental Protection Agency
RFS2	Renewable Fuel Standard 2	V	velocity
RH	relative humidity	VA	volatile acids
RIN	Renewable Identification Number	VFA	volatile fatty acid
RNG	renewable natural gas	VFD	variable frequency drive
RO	reverse osmosis	Vo	initial settling velocity
rpm	revolution(s) per minute	Vs	settling velocity
s	second(s)	VS	volatile solids
S2EBPR	sidestream enhanced biological phosphorus removal	VSA	vacuum swing adsorption
SBD	sludge blanket depth	VSR	volatile solids reduction
SCADA	supervisory control and data acquisition	w.c.	water column
SCF	standard cubic foot/feet	WAS	waste activated sludge
SCFH	standard cubic foot/feet per hour	WGB	waste gas burner
scfm	standard cubic feet per minute	WRP	Water Reclamation Plant
SIC Code	Standard Industrial Classification Code	WSE	water surface elevation

WWTP wastewater treatment plant
X particle concentration
yr year(s)

Executive Summary

The Rochester Water Reclamation Plant (WRP) serves a population of approximately 120,000, discharging to the South Fork of the Zumbro River. With an average dry weather flow rating of 15.86 MGD, it was one of the first wastewater treatment plants in the state of Minnesota to receive an effluent phosphorus limit. Originally constructed in 1952, it has undergone 6 major upgrades between 1952 and 2006. The two largest plant expansions occurring within this time period were the implementation of two-stage high-purity oxygen activated sludge (HPOAS) in 1980 and implementation of parallel aeration basin complex (ABC) providing biological phosphorus removal in 2006. Whereas these up-grades have enabled the plant to consistently maintain permit compliance, the resultant process complexity, the age of existing infrastructure and pending regulatory requirements have resulted in the need for a long-range plan to maintain its ongoing level of service and environmental stewardship.

The Rochester WRP Facilities planning process was initiated to create a long-range plan to meet current and anticipated regulatory requirements with an upgraded facility that would achieve these objectives:

- Lower Energy – Reduce energy consumption while maximizing energy recovery towards a long-term goal of net-zero operation.
- Clean Design – Reduce plant complexity through elimination of parallel processes and consolidation of assets.
- Decreased Maintenance – Strive for operational simplicity and elimination of high maintenance aging infrastructure
- Innovative Processes - Implementation of best available and yet proven technologies.
- Long-Term Wholistic Approach - Provide a staging plan to achieve near term treatment goals with processes and configurations to accommodate future improvements to meet increasingly stringent regulatory requirements.

The initial planning process began by defining potential regulatory treatment levels 1, 2, 2X and 3 effluent water quality criteria identified in Table ES-1.

Table ES-1. Rochester WRP Planning Effluent Water Quality Criteria				
Treatment Level	Final Effluent ^a			General Technology Comments
	Monthly Ammonia, mg N/L	Annual N mg N/L	Monthly TP mg-P/L, (lb/d)	
Level 1	Current Permit Limits ^b	NA	0.8 mg-P/L (82 lb/d) 12-month rolling	
Level 2	< 2 mg/L	10 as TN	0.4 mg-P/L (82 lb/d) 12-month rolling	Full or partial stream filtration to meet TP limit
Level 2X	< 2 mg/L	10 as NOx-N	0.4 mg-P/L (82 lb/d) 12-month rolling	Full or partial stream filtration to meet TP limit
Level 3	< 2 mg/L	4 as TN	0.1 mg-P/L (82 lb/d) 12-month rolling	Filtration for TN and TP limit

a. Existing permit monthly/weekly effluent cBOD₅ and TSS limits of 15/25 and 30/45 apply to all options with associated mass loadings of 1352/2254 kg cBOD₅/d and 2705/4075 kg TSS/d.

b. Monthly ammonia limits for Dec-March, Apr-May, Jun-Sep, and Oct-Nov are 5,10, 3, and 13 mg N/L respectively with associated mass loadings of 451, 902, 270, and 1172 kg/d.

NPDES Permit

The City's current NPDES permit (MN0024619) was issued in 2010 with an original expiration date of April 30, 2015, which has been administratively continued. The continuance is allowing time for the City and MPCA to determine the best approach to several complex permitting issues including phosphorus and salt-related parameters. Current expectation is the MPCA will issue a phosphorous limit that cannot be met with the current process technology used by WRP. The draft permit would be subject to review and comment both by the City, the public and U.S. EPA Region V prior to being finalized.

Proposed Improvements

Planned upgrades to the Rochester Water Reclamation Plant have been identified in multiple phases to address aging infrastructure, changes in flows and loads and new effluent limits. Phase 1 improvements focus on plant disinfection and outfall improvements, replacement of the waste gas burner and improvements to plant administrative and maintenance spaces. Phase 2 improvements address the need to replace the aging high purity oxygen system and are centered around a conversion to a conventional air activated sludge process and associated liquids upgrades. Phase 3 will increase solids processing capacity while providing improved operational flexibility. Phase 4 represents a staged expansion to be implemented as necessary to address future regulatory requirements.

Phase 1 Improvements

Recommended Phase 1 improvements address immediate needs at the WRP. Figure ES-1 outlines the Phase 1 improvements, scheduled to occur between 2020 and 2023.

Following is a summary of the recommended Phase 1 improvements.

- Disinfection – Improvements to chlorination and dechlorination delivery systems as described in Section 7.1
- Effluent – Reconfiguration of the chlorine contact tanks by incorporating a Parshall flume for effluent flow metering and installation of a cascade aeration system as described in Section 7.2.
- Waste gas burner – Relocate and upgrade the waste gas burner to north side of WRP campus as described in Section 8.7.
- While outside of the scope of the work provided in this document, Phase 1 also includes a significant remodel to the WRP administration building as well as a new garage building for equipment storage.



Improvement	Benefit
1 Disinfection Improvements	Reduce energy and chemical usage while addressing aging high maintenance equipment.
2 Effluent Improvements	Improve permit required flow monitoring and add effluent cascade aeration to meet permit limits.
3 Turbine Generator	Evaluate turbine generator to produce electricity using flow of treated wastewater.
4 Remodel	Rehabilitate abandoned headworks and remodel 1952 building to meet space needs.
5 New garage	Storage for biosolids and sewer collection system equipment.
6 Waste Gas Burner	Digester gas burner relocation and safety improvements.


Figure ES-1. Phase 1 capital improvements and recommendations

Phase 2 Improvements

Phase 2 improvements focus on upgrades to the liquid treatment processes, including conversion of the HPOAS system to air activated sludge and implementing a single activated sludge system. Figure ES-2 outlines the Phase 2 improvements, scheduled to occur between 2023 and 2027.

Following is a summary of the recommended Phase 2 improvements:

- HPOAS Conversion – Decommission the existing HPO system and convert the existing HPOAS bioreactors into an air activated sludge A/O configuration with a new process aeration blower facility for nutrient removal as described in Section 6.2.
- ABC Expansion – Expand the existing ABC capacity to meet future demands as described in Section 6.2.
- Implement a single activated sludge system through the following improvements.
 - Primary Effluent Flow Structure– A new flow distribution structure to combine effluent flow from Primary Clarifiers 1 through 3 and then distribute the flow to the secondary treatment bioreactors as described in Appendix 10.
 - Return Sludge Flow Structure – Return activated sludge from Final Clarifiers 1-5 will be pumped into a common pipeline and routed to the new return sludge flow structure to be distributed to the secondary treatment bioreactors as described in Appendix 10.
 - Mixed Liquor Flow Control Structure – A new structure to route ABC mixed liquor flow in excess of Final Clarifier 5 capacity to Final Clarifiers 1-4.
- Effluent heat recovery – Implement improvements to the existing effluent heat recovery system described in Appendix 11.
- Sludge pumping – Replace existing RAS pumps servicing Final Clarifiers 1 through 4 with higher capacity units as described in Section 6.2.



Improvement	Benefit
Wastewater Distribution	Improves plant process control and eliminates the need to construct additional primary clarifiers.
Biological Phosphorus Removal	Replace high purity oxygen process with conventional air to meet future phosphorus requirements and reduce energy and chemical costs.

Replace Oxygen Plant	Replace failing, unreliable, 40 year old equipment with efficient aeration system.
Sludge Pumping System	Addresses pumping capacity issues and eliminate the need for additional clarifiers.
Three Additional Bioreactors	Extension of conventional air plant to meet phosphorus requirements through 2045.
Wastewater Heat Recovery	Increase energy recovery from wastewater heat while reducing maintenance of system.


Figure ES-2. Phase 2 capital improvements and recommendations

Phase 3 Improvements

Phase 3 capital improvements focus on the solids handling facilities scheduled to take place between 2027 and 2030. Delaying these improvements until after implementation of the A/O process will allow confirmation of solids loading and solids handling characteristics based on full plant implementation of the new secondary treatment processes.

Following is a summary of the recommended Phase 3 improvements and depicted in Figure ES-3.

- Gravity sludge thickening – Renovate existing Digester No. 3 as a primary sludge gravity thickener and Digester No. 4 as a primary sludge storage tank during gravity thickener outages.
- Digested solids wet well – Convert Digester No. 1 into a digested sludge storage tank or wet well prior to thickening the sludge on the gravity belt thickeners.
- Thickened digested solids storage as required – Convert Digester No. 2 to a storage tank and recuperative digester.
- Odor control – Replace antiquated odor control system with upgraded higher capacity facility.
- Sludge loadout – Provide additional sludge loadout facility to relieve truck loading congestion.
- Control building upgrades – Renovate Digester Control Building No. 1 for to meet NFPA 820 requirements.
- Replacement of one engine-generator. Second existing generator will remain for stand-by service.
- Digester gas cleaning improvements



Improvement	Benefit
Gravity Sludge Thickener	Eliminates need for additional digesters and increases overall plant capacity.
Digester Wet Well	Increase operational flexibility, decrease energy usage, and decrease volume of sludge generated.
Sludge Storage	Increased sludge storage without building additional storage tanks.
Odor Control Improvements	Replace aging equipment and increase capacity to odor scrub additional solids handling facilities.
Sludge Loadout Improvements	Provide increase loadout flexibility and capacity.
Control Building Renovation	Renovate 1952 building and tunnels to current ventilation and electrical codes.

Figure ES-3. Phase 3 capital improvements and recommendations

Phase 4 Improvements

Phase 4 improvements focus on upgrades to the liquid treatment processes that will be required to address future effluent limit scenarios based on the treatment levels identified in Table ES-1. Figure ES-4 identifies the plant build out that will be required to achieve these progressively more stringent effluent limits as described in further detail in TM 10 – Whole Plant Evaluation. Because the specific effluent limit trajectory in terms of parameters, specific limits and scheduled implementation is unknown at this time, improvements are presented relative to potential regulatory scenarios and are not tied to a specific timeline.




Figure ES-4. Phase 4 capital improvements and recommendations

Summary and Opinion of Probable Costs

Table ES-2 summarizes the project costs for each phase. These Class 5 estimates represent a conceptual level or project viability estimate consistent with the Association for the Advancement of Cost Engineering International (AACEI). Engineering for a Class 5 estimate typically represents zero to 2 percent completeness. The accuracy of a Class 5 estimate ranges from -50 to +100 percent.

Table ES-2. Rochester WRP Phased Improvements Opinion of Probable Costs^a		
Item	Cost	Implementation Schedule
Phase 1	\$10,000,000	2020 - 2023
Phase 2	\$52,000,000	2023 - 2027
Phase 3	\$11,000,000	2027 - 2030
Phase 4	\$75,000,000	Based on future effluent limits
Total	\$148,000,000	

Section 1

Introduction

This Facility Plan presents a summary of the City of Rochester (City) Water Reclamation Plant (WRP) facility evaluations conducted by Brown and Caldwell (BC) and the City to meet current and potential future wastewater treatment requirements through the Year 2045. The planning effort focused on the liquid stream processes from primary clarification through the plant outfall, solids handling systems, heat recovery, and biogas utilization. A capital improvement plan (CIP) is included based upon the facility recommendations.

The following list summarizes the major sections and organization of the Facility Plan.

- Section 1 – Introduction
- Section 2 – Flows and Loadings
- Section 3 – Design Criteria
- Section 4 – Existing Facility Condition
- Section 5 – Process Optimization
- Section 6 – Biological Nutrient Removal
- Section 7 – Final Effluent
- Section 8 – Solids Handling
- Section 9 – Biogas Utilization
- Section 10 – Reuse and Energy Recovery
- Section 11 – Recommendations and Implementation Plan
- Section 12 – Clean Water Revolving Fund Checklists and Forms

The detailed Technical Memoranda that served as the basis for this plan are included in Appendices 1 through 13.

1.1 Background

The Rochester WRP has a rated dry weather flow capacity of 15.86 million gallons per day (mgd) and an average wet weather flow capacity of 23.85 mgd, currently treating approximately 13 mgd on an annual average basis. It discharges to the South Fork of the Zumbro River under National Pollutant Discharge Elimination System (NPDES) Permit MN0024619 issued on May 26, 2010.

Constructed on the existing site in 1952, the plant has undergone major renovations as shown in Table 1-1.

Year	Project	Original Cost	Current Value
1952	Original Plant Construction	\$1,900,000	\$17,000,000
1958	Digester Addition	\$267,000	\$2,000,000
1968	Plant Expansion	\$2,700,000	\$14,000,000
1980	Plant Expansion with Conversion to High Purity Oxygen	\$56,000,000	\$201,000,000
1989	Chemical Storage and Feed Facility Addition	\$900,000	\$2,000,000
1990	Solids Handling Improvements	\$14,600,000	\$38,000,000
2006	Aeration Basin Complex Addition	\$68,000,000	\$106,000,000

Liquid stream treatment consists of influent pumping, screening, grit removal, and flow equalization systems. Following grit removal, the flow is split into two liquid treatment trains: high purity oxygen activated sludge (HPOAS) and the aeration basin complex (ABC) which uses enhanced biological phosphorus removal (EBPR) nitrifying air activated sludge. The HPOAS system treats approximately 75 percent of the flow with the remainder going to the ABC plant.

The HPOAS train consists of two rectangular primary clarifiers followed by a two-stage HPOAS system. The first stage HPOAS operates at low solids retention time (SRT) to remove carbonaceous compounds. The second stage HPOAS operates at an SRT greater than 10 days, nitrifying ammonia to nitrate. The two stages are fed high purity oxygen (HPO) gas from a cryogenic air plant. Phosphorus removal in the HPOAS train is primarily accomplished through ferric chloride addition in the primary clarifiers with some trimming with alum prior to the HPOAS final clarifiers as necessary.

The ABC train has one circular primary clarifier followed by an EBPR nitrifying activated sludge system. The ABC plant is typically operated in an A/O configuration but does have the ability to also be operated in an anaerobic/anoxic/aerobic (A2O) or Modified Ludzack-Ettinger (MLE) configuration. Alum is added to Final 5 to help reduce effluent phosphorous when needed.

Effluent from HPOAS Final Clarifiers 1-4 and ABC Final Clarifier 5 is blended and then routed to the chlorine contact tanks for disinfection and dechlorination before being discharged to the South Fork of the Zumbro River.

Primary solids are thickened in the primary clarifiers. Waste activated sludge (WAS) from each activated sludge system is blended and thickened using gravity belt thickeners (GBT). Thickened sludges are pumped to mesophilic anaerobic digesters (MAD). Digested biosolids are fed to a sludge holding tank and then thickened using GBTs. Thickened biosolids are then pumped to sludge storage tanks for land application. Recycle streams from the GBTs are routed to the head of the plant influent.

Figures 1-1 and 1-2 present a process flow schematic and plant layout of the WRP respectively.





Figure 1-1. Rochester WRP flow schematic



- a. Influent Pumping, Screening and Grit Removal
- b. Influent Flow Equalization
- c. Primary Clarification
- d. High Purity Oxygen Activated Sludge
- e. Aeration Basin Complex
- f. Intermediate Clarification
- g. Final Clarification
- h. Disinfection
- i. Thickening
- j. Digestion
- k. Solids Storage

Figure 1-2. WRP site layout

Image: Google Earth

1.2 Project Definition

The City and BC collaborated on this Facility Plan to develop a strategy to meet the projected needs at the WRP through the year 2045 providing a capital improvements plan (CIP) to meet current and anticipated future needs. The key aspects to this Facility Plan include:

- Projecting WRP influent flows and loads from current baseline conditions to Year 2045.
- Assess condition of existing WRP assets.
- Conduct detailed assessments of the existing plant treatment and hydraulic capacities. This included several full-scale data collection efforts to calibrate state-of-the-art models for predicting process performance and capacity
- Evaluate treatment process alternatives for various regulatory, capacity, and capital expenditure requirements.
- Develop recommended capital improvements plan to meet plant operating requirements through year 2035 and 2045.

Section 2

Flows and Loadings

This section summarizes the WRP plant influent and high strength waste flow and loading projections. Appendix 1 contains a detailed technical memorandum (TM) that presents historical plant influent flows and loadings, projected influent flows and loadings based upon historical plant data, and design influent flow and loadings projections. Appendix 13 provides information on the high strength waste flow and loads used.

2.1 Plant Influent Flows and Loadings

Historical plant influent flows and loadings from January 1, 2012 through December 31, 2017 were analyzed to define the existing baseline conditions. Industrial contributions to the WRP represent approximately 35 to 40 percent of the influent BOD load and 15-20 percent of the influent phosphorus loading. An evaluation of each of the six major industries – 1) Associated Milk Producers 2) Kemps LLC North 3) Kemps LLC South 4) Pace Dairy Foods 5) Kerry Ingredients 6) Seneca Foods was conducted as a part of the planning process. This information is summarized in the Industrial Discharge Wasteloads and Practices TM in Appendix 13.

Special sampling was used to characterize influent wastewater as well as between unit processes. A follow up special sampling event was conducted to compare the pollutant parameter concentrations using the plants existing influent sampler and ISCO type sampler. The results showed the existing influent sampler chemical oxygen demand (COD), carbonaceous biochemical oxygen demand (cBOD5) and total suspended solids (TSS) concentrations were statistically lower than ISCO type sampler. As such the influent COD, cBOD5, TSS baseline conditions were increased by the following multiplication factors using comparative sampling results and supporting BioWin™ model calibration discussed in Appendix 2. The “adjusted” loadings serve as the design influent loadings.

- Design influent cBOD5 load = historically based plant influent cBOD5 load * 1.15
- Design influent TSS load = historically based plant influent COD load * 1.35
- Design influent COD load = design influent cBOD5 load * 1.87

Baseline flows and loadings were then projected through Year 2045 based upon 1.5 percent yearly compounded growth. Several other growth projection approaches were considered but were not consistent with the City’s growth expectations.

Table 2-1 presents the existing baseline, Year 2030, and Year 2045 design flow and loading projections. In addition, the City identified that all new facilities shall be designed to hydraulically pass a peak flow of 60 million gallons per day (mgd) based on the design of the existing headworks. This flow rate will be incorporated into the design along with the other flows listed in Table 2-1. Also, the peak hour wet weather and peak instantaneous wet weather flows were calculated using the Minnesota Pollution Control Agency guide-lines (see Appendix 1, Attachment A).i

Table 2-1. Rochester WRP Design Influent Flow and Loading Projections				
Item	Units	Existing Baseline	Year 2030	Year 2045
Flows				
Annual Average	mgd	12.9	15.9	19.9
Average Dry Weather	mgd	10.6	12.9	16.2
Average Wet Weather	mgd	15.7	19.0	23.8
Peak Hour Wet Weather Flow	mgd	34.0	40.8	50.8
Peak Instantaneous Wet Weather Flow	mgd	38.9	45.6	55.6 ^c
Carbonaceous Biochemical Oxygen Demand^d				
Annual Average	lb/d	44,100	53,600	67,200
Maximum Month	lb/d	53,400	64,900	81,300
Maximum Week	lb/d	62,400	75,800	94,900
Maximum Day	lb/d	66,800	81,200	101,700
Chemical Oxygen Demand^{a,d}				
Annual Average	lb/d	82,500	100,300	125,600
Maximum Month	lb/d	99,900	121,500	152,100
Maximum Week	lb/d	116,600	141,700	177,500
Maximum Day	lb/d	124,900	151,800	190,200
Total Suspended Solids^d				
Annual Average	lb/d	32,200	39,100	49,000
Maximum Month	lb/d	38,500	46,700	58,400
Maximum Week	lb/d	42,700	51,800	64,900
Maximum Day	lb/d	48,300	58,700	73,600
Ammonia				
Annual Average	lb-N/d	2,600	3,200	4,000
Maximum Month	lb-N/d	3,200	3,900	4,800
Maximum Week	lb-N/d	3,400	4,100	5,100
Maximum Day	lb-N/d	4,300	5,200	6,500
Total Kjeldahl Nitrogen^b				
Annual Average	lb/d	4,900	6,000	7,500
Maximum Month	lb/d	6,000	7,300	9,100
Maximum Week	lb/d	6,300	7,700	9,600
Maximum Day	lb/d	8,100	9,800	12,300
Total Phosphorus				
Annual Average	lb/d	740	900	1,130
Maximum Month	lb/d	880	1,070	1,330
Maximum Week	lb/d	1,030	1,250	1,570
Maximum Day	lb/d	1,210	1,470	1,840

- COD based on COD:cBOD5 ratio observed during wastewater characterization (August 23-31, 2017) of 1.87.
- TKN based on historical ammonia:TKN ratio observed during wastewater characterization (August 23-31, 2017) of 0.53.
- Peak instantaneous flow of 60 mgd to be used in planning.
- Influent cBOD5, COD, and TSS include a 1.15, 1.15, and 1.35 adjustment factor, respectively, based on special sampling and BioWin™ model calibration.

Section 3

Design Criteria

Design criteria used for this project include effluent water quality, solids handling requirements, and process redundancy requirements. This analysis assumes all primary clarifiers, aeration tanks, final clarifiers and tertiary filters are in service during critical maximum month flow and loadings conditions and peak wet weather flow conditions.

3.1 Effluent Water Quality

This planning effort considered four levels of treatment for nutrient reduction as summarized in Table 3-1. In addition, an order-of-magnitude evaluation was conducted for the plant to meet Class 2 salty water discharge river water quality standards.

Table 3-1. Rochester WRP Planning Effluent Water Quality Criteria				
Treatment Level	Final Effluent ^a			General Technology Comments
	Monthly Ammonia, mg N/L	Annual N mg N/L	Monthly TP mg-P/L, (lb/d)	
Level 1	Current Permit Limits ^b	NA	0.8 mg-P/L (82 lb/d) 12-month rolling	
Level 2	< 2 mg/L	10 as TN	0.4 mg-P/L (82 lb/d) 12-month rolling	Full or partial filtration to meet TP limit
Level 2X	< 2 mg/L	10 as NO _x -N	0.4 mg-P/L (82 lb/d) 12-month rolling	Full or partial filtration to meet TP limit
Level 3	< 2 mg/L	4 as TN	0.1 mg-P/L (82 lb/d) 12-month rolling	Filtration for TN and TP limit

a. Existing permit monthly/weekly effluent cBOD₅ and TSS limits of 15/25 and 30/45 apply to all options with associated mass loadings of 1352/2254 kg cBOD₅/d and 2705/4075 kg TSS/d.

b. Monthly ammonia limits for Dec-March, Apr-May, Jun-Sep, and Oct-Nov are 5,10, 3, and 13 mg N/L respectively with associated mass loadings of 451, 902, 270, and 1172 kg/d.

For evaluation purposes, process modeling targeted effluent discharges of 80 percent or less than the values identified in Table 3-1 to account for process uncertainty and factors of safety. The total phosphorus (TP) discharge effluent criteria of 82 pounds per day (lb/d) or 37 kilograms per day (kg/d) is used based upon historical data from January 1, 2014 through May 8, 2017). An effluent TP loading criteria of 82 lbs/d was selected based on preliminary data provided by the governing regulatory agency regarding estimated phosphorous allocations to Lake Zumbro.

Solids handling key design features was so as to continue land applying a Class B product in accordance with all NPDES permit requirements. Further design consideration included 6 months of storage for thickened digested solids storage and a minimum digester solids retention time (SRT) of 15 days.

In addition to the key final effluent parameters listed above the NPDES permit contains several other parameters that were considered but not directly addressed in the alternatives evaluation within the scope of this Facility Plan including Disinfection requirements and pH.

Section 4

Existing Facility Condition

This section briefly covers the existing condition of the WRP assets.

4.1 Facility Condition

The City proactively tracks the condition of the WRP assets and thus BC did not conduct a condition assessment. Table 4-1 identifies the condition assessment issues identified and being tracked by the City.

Table 4-1. Rochester WRP Existing Facility Condition Assessment Issues			
Area	Asset	Issue	Comments
Equalization	Electrical equipment	Past expected life	Replaced in 2016
Equalization	Odor control	Poor performance	Conduct odor analysis and scrubber performance study
Primary clarification	Primary sludge pumps	Capacity limitations	Rehabilitation repurposing planned for future project
Primary clarification	Scum beaches on Primary Clarifiers 1 and 2	Poor condition	Replace in next few years
Primary clarification	Odor control for Primary Clarifiers 1 and 2	Poor performance	Rehabilitation/repurposing planned for future project
High purity oxygen	First stage tanks	Leaking joints	Reseal if HPO operation in future
High purity oxygen	Intermediate clarifier roofs	Leaking and failed insulation	Repair dependent on future use
High purity oxygen	Intermediate Clarifiers 1 and 2 collector/weir	Poor condition	Replace if needed for future service
High purity oxygen	Intermediate clarifier sludge pumps	Poor condition	Replace if needed for future service
High purity oxygen	Intermediate clarifier motor control centers	Poor condition	Replace if needed for future service
High purity oxygen	Second stage tanks	Leaking joints	Reseal if HPO operation in future
High purity oxygen	Return activated sludge piping	Poor condition (rolled steel sections)	Replace as needed
Final clarifiers 1-4	Return activated sludge pumps	Poor performance	Replace when HPO process switched to A/O
Final clarifiers 1-4	Motor control center	Poor condition	Replace and consolidate with projects rather than modify
Final clarifiers 1-4	Splitter box gates	Do not seal	Replace or refurbish as needed
Disinfection	Exterior equipment/piping	Past expected life	Replace with planned future project
Waste activated sludge holding	Tank	Poor concrete condition	Replace with planned future project

Table 4-1. Rochester WRP Existing Facility Condition Assessment Issues			
Area	Asset	Issue	Comments
Digested sludge holding	Tank	Poor condition	Replace with planned future project
Digested sludge holding	Pumps	Poor condition	Replace with planned future project
Digestion	Digester Nos. 1 and 2	Roofs in poor condition and portions of interior coating failing	Repair with planned future project
Digestion	Digester Nos. 3 and 4	Currently abandoned	Rehabilitation/repurposing planned for future project
Biogas	Low Pressure Holder	Corroded, near end of life	None
Biogas	Waste gas burners	Poor performance	Replace with planned future project
Solids handling	Odor control	Poor performance	Replace with planned future project
General	Concrete tanks	Interior coatings failing	None
General	Building roofing	Poor condition	Repair work scheduled based on annual inspections
General	Emergency power	Low capacity for across line starting	None
General	HVAC	Capacity limitations on pre-2007 equipment	Replace as needed based in future HVAC study
General	Field programmable logic controllers	Past expected life	None

Section 5

Process Optimization

5.1 Existing Process Unit Capacities

In an effort to optimize existing process unit capacities, detailed evaluations of key liquid stream process units were completed. This included individual studies evaluating modifications to improve Primary Clarifiers 1 and 2 performance, Intermediate Clarifiers 1-4 capacity, and Final Clarifiers 1-5 capacity and process performance enhancement. The following discussion summarizes more detailed information found in the referenced appendices related to these key process units.

5.1.1 Primary Clarifiers 1 and 2

A rectangular clarifier computational fluid dynamics (CFD) model, 2Dr, was used to analyze the performance of the primary clarifiers. The effort included field and stress testing Primary Clarifier 2 to collect data to calibrate the 2Dr model. The calibrated model was subsequently used to comparatively evaluate clarifier performance under Year 2045 conditions.

The 2Dr analysis showed baffles placed in front of the inlet ports would increase TSS removal if influent flow across the tank is evenly distributed. Based on the 2Dr model findings, influent baffling and flow distribution was refined using FLUENT™, a three-dimensional (3D) CFD model. The 3D model showed significant hydraulic improvements within the clarifiers from the addition of two baffles. The first baffle system consists of four 9-inch stub baffles in each influent channel feeding the primary clarifier to promote more even distribution between the six inlet ports. This is critical as stress testing showed uneven flow distribution and sludge blanket development and short-circuiting at higher SORs as flow was pushed to the “end” ports. Figure 5-1 shows the 3D model predicted velocity patterns at the inlet with the “stub” baffles installed.




Figure 5-1. Primary Clarifier 2 recommended inlet channel stub baffle configuration
(SOR = 1,660 gal/ft³-d)

The second baffle system builds upon the inlet baffle concept shown to be beneficial by the 2Dr model. Figure 5-2 shows the recommended inlet baffle diffuser plate located directly in front of each inlet port which could increase TSS capture.




Figure 5-2. Diffuser plate configuration

5.1.2 Intermediate Clarifiers

The City performed two days of intermediate clarifier (IC) stress testing to define the maximum loading condition at which either the effluent TSS exceeded 25 mg/L or sludge blanket depth (SBD) remained stable (i.e., not rising). Table 5-1 summarizes IC capacity at the historical 90th percentile sludge volume index (SVI) value of 260 milliliters per gram (mL/g) and a potential design SVI of 150 mL/g assuming a well-settling sludge in the first-stage HPOAS system that considers both the existing return activated sludge (RAS) pumping capacity of 2.0 mgd/clarifier and increased RAS capacity of 2.5 mgd/clarifier. At MLSS concentrations of 1,200 to 1,500 mg/L, clarifier performance is assumed to be hydraulically limited at 1,200 gal/ft²-d. Further testing should be conducted to verify the peak SOR capacity.

Table 5-1. Rochester HPOAS Intermediate Clarifier Capacity Analysis Results					
Condition	Units	SVI ^c = 260 mL/g		SVI ^c = 150 mL/g	
		Existing	Increased RAS	Existing	Increased RAS
Return sludge flow/clarifier	mgd	2.0	2.5	2.0	2.5
Solids loading rate	lb/ft ² -d	11.5	13.0	17.0	20.0
Flow/clarifier					
at MLSS = 1,200 mg/L	mgd	5.3	5.7	7.7 ^a	7.7 ^a
at MLSS = 1,500 mg/L	mgd	3.8	4.1	6.7	7.7
at MLSS = 2,000 mg/L	mgd	2.4	2.5	4.5	5.2

- a. Assumes maximum SOR of 1,200 gal/ft²-d.
- b. Based upon 65 percent of SPA theoretical maximum allowable SLR.
- c. 2-L non-stirred settleometer.

5.1.3 Final Clarifiers

The WRP has five final clarifiers each 120-ft in diameter. Final Clarifiers 1 through 4 serve the second stage of the HPOAS system and Final Clarifier 5 serves the ABC system. Final Clarifier 2 can also serve the ABC system when Final Clarifier 5 is out of service for maintenance. BC conducted field and stress testing to calibrate a circular final clarifier CFD model, 2Dc, and analyze the capacity of the system with and without performance modifications. See Appendix 5 for more details.

Table 5-2 shows Final Clarifier 5 has a solids loading rate (SLR) capacity of 39 pounds per square foot-day (lb/ft²-d) under the current configuration and can be increased to 43 lb/ft²-d by increasing the flocculation well depth from 4.0 to 8.5 feet. Increasing the flocculation well depth also reduces effluent suspended solids concentrations compared to the existing configuration. Final Clarifiers 1 through 4 have an SLR capacity of 24 lb/ft²-d under current operations with a 2.5 mgd/clarifier RAS flow (one RAS pump in operation) and can be increased to 31 and 38 lb/ft²-d by increasing the RAS pumping rate per clarifier to 3.6 and 5.3 mgd, respectively. With conversion of HPOAS to a conventional air system with an anaerobic selector (A/O), Final Clarifiers 1–4 capacity remains the same and can be increased to 43 lb/ft²-d by increasing the RAS flow to 6 mgd/clarifier.

Table 5-2. Rochester Final Clarifier Capacity Analysis Results

Condition	Unit	Final Clarifier 5		Final Clarifiers 1-4			
		BNR with anaerobic selector		Existing 2-stage HPOAS		BNR with anaerobic selector	
Clarifier condition	--	Existing	Deepened flocculation well	Existing	Increased RAS	Existing	Increased RAS
Process configuration	--	BNR with anaerobic selector		Existing 2-stage HPOAS		BNR with anaerobic selector	
Sludge volume index ^b	mL/g	130	130	90	90	130	130
RAS flow/clarifier	mgd	6.0	6.0	2.5	3.6/5.3	2.5	3.6/5.3/6.0
Solids loading rate	lb/ft ² -d	39	43	24	31/38	24	31/38/43
Peak hour flow/clarifier ^a							
at MLSS = 3,000 mg/L	mgd	11.5	12.8	8.3	10.4/12.0	8.3	10.5/12.6
at MLSS = 3,500 mg/L	mgd	9.1	10.3	6.8	8.4/9.5	6.8	8.5/10.0
at MLSS = 4,000 mg/L	mgd	7.2	8.2	5.6	6.9/7.7	5.6	7.0/8.1
at MLSS = 4,500 mg/L	mgd	5.8	6.7	4.7	5.7/6.2	4.7	5.8/6.6

a. Assumes no hydraulic limitations.

b. 2-L non-stirred settleometer.

5.2 Recommendations

The recommended improvements include the addition of baffles to Primary Clarifiers 1 and 2 influent channels, increasing the flocculation well depth of Final Clarifier 5, and increase RAS pumping rates of Final Clarifiers 1-4. The City has begun implementing Primary Clarifier 1 and 2 and Final Clarifier 5 improvements internally and cost estimates were not required. The increased RAS pumping rate capacity is included as part of Phase 2 Upgrades and cost estimates provided as part of meeting varying treatment standards illustrated in Section 6.

Section 6

Biological Nutrient Removal

This section summarizes the biological nutrient removal (BNR) alternatives screening process and recommended BNR alternative to achieve effluent water quality treatment levels presented in Section 3.1 above. The BNR alternatives include the primary clarifiers. The following TMs provide additional details on the primary and secondary system evaluations.

- Appendix 2 – Wastewater Characterization and BioWin™ Calibration
- Appendix 6 – Liquid Stream Alternative Evaluation
- Appendix 10 – Whole Plant Alternative

6.1 Alternative Screening

A BNR alternative screening workshop was conducted with WRP staff on April 20, 2018. The workshop focused on the review of viable liquid and sidestream technologies with respect to the City's goals listed below and proven record of operation.

- Lower energy – strive towards net-zero facility
- Clean design - streamline equipment, operation, and maintenance, limits stranded assets, reduce chemical consumption
- Decreased maintenance - includes equipment and facilities where possible
- Innovative processes –meet varying permit limits and achieve goals, proven record of operations
- Long-term holistic approach - ability to be staged to meet tighter limits, ensure treatment, operation, maintenance, and energy goals align, minimize impacts to other processes

6.1.1 Process Technology Screening Evaluation

The screening process identified and evaluated 19 viable liquid stream technologies which were grouped into four categories:

Conventional BNR Technologies

- Existing Configuration
- A/O
- A2O
- 5 Stage BNR
- MLE
- 4 Stage BNR

Technologies with a focus towards net zero energy

- Simultaneous Nitrification Denitrification
- Nitrite Shunt
- Membrane Aerated Bioreactor

- High Rate A/B
- Mainstream Anammox

Process Intensification Systems to Reduce Plant Footprint Requirements

- Membrane Bioreactor
- Integrate Fixed Film Activated Sludge
- BioMag™
- Aerobic Granular Sludge (AquaNereda™)

Tertiary Technologies to Further Reduce TP and TN

- Denitrification Filters/Moving Bed Biofilm Reactors
- Tertiary Filters
- Dual Stage Continuous Backwash Filters
- CoMag™

Based upon a long-term holistic approach and each technologies ability to be sequentially staged to achieve Treatment Level 2, 2X and 3 nitrogen and phosphorus discharges, three treatment pathways were developed based on the best fit of the above 19 treatment alternatives.

6.1.2 Treatment Process Pathway Screening

Three primary pathways were chosen to meet the increasingly more stringent effluent criteria and City goals outlined as part of this project. The three chosen pathways are shown in Figure 6-1 and summarized as follows:

- Pathway 1 maintains the existing high purity oxygen activated sludge (HPOAS) and air activated sludge system parallel treatment trains. To achieve treatment level 2, 2X, and 3, the existing second stage HPOAS is replaced with air activated sludge simultaneous nitrification denitrification (SND) and modifies the ABC facility to a 5-stage BNR process.
- Pathway 2 converts the existing facility to air activated sludge BNR. The existing HPOAS train is converted to an A/O process to meet treatment level 1, followed by 3-stage BNR for Treatment Level 2X, and finally 5-stage BNR to meet Treatment Levels 2 and 3.
- Pathway 3 converts the existing facility to an AquaNereda aerobic granular sludge (AGS) facility. Both the existing HPOAS and ABC trains are converted into AGS to meet treatment level 2, 2X, and 3. Treatment Level 3 includes sidestream deammonification to reduce annual TN discharges below 4 mg/L. Pathway 3 did not include Treatment Level 1 as tertiary filtration is required to reduce effluent TP discharges to the target levels.

To achieve Treatment Level 2, 2X, and 3 effluent TP discharges this analysis includes deep bed continuous backwash filters.

	Pathway 1: Parallel Systems	Pathway 2: Conversion to Air Activated Sludge BNR	Pathway 3: Conversion to Aerobic Granular Sludge
<u>Treatment Level 1</u> Existing Permit	Alternative 1: Existing Parallel System Parallel ABC and HPO trains	Alternative 2 A/O	
<u>Treatment Level 2</u> TN < 10 TP < 0.4	Alternative 1A: 1 st Stage HPOAS with 2 nd Stage Air Activated Sludge SND ABC: 5 stage BNR Deep Bed Filters	Alternative 4: 5-Stage BNR with Deep Bed Filters	Alternative 15: AquaNereda Deep Bed Filters
<u>Treatment Level 2X</u> NOx-N < 10 TP < 0.4	Alternative 1X: 3-Stage HPOAS BNR ABC: 3 stage BNR Deep Bed Filters	Alternative 4X: 3-Stage BNR with Deep Bed Filters	Alternative 15: AquaNereda Deep Bed Filters
<u>Treatment Level 3</u> TN < 4 TP < 0.1	Alternative 1B: 1 st Stage HPOAS with 2 nd Stage Air Activated Sludge SND ABC: 5 stage BNR- Carbon Addition Deep Bed Filters	Alternative 4B: 5-Stage BNR Carbon Addition Deep Bed Filters	Alternative 15B: AquaNereda Sidestream Deammonification Deep Bed Filters

Figure 6-1. Rochester process screening selected liquid stream treatment pathways and alternatives

Each treatment alternative was evaluated using the calibrated BioWin™ Version 5.3 whole-plant process simulator presented in Appendix 10 and updated for the design flow and loading conditions. The BNR alternative evaluations were based upon maintaining two liquid stream system with the plants existing MAD solids processing scheme as shown in Figure 6-2 for comparison purposes. For Pathway 3, the BioWin simulator was used to develop primary effluent flows and loadings to the AGS system which were then provided to Aqua Aerobic Systems Inc. for reactor sizing and supporting requirements of an AquaNereda AGS system.




Figure 6-2. Rochester WRP Liquid Stream BioWin™ flow schematic

Treatment Pathway 2, Conversion to Air Activated Sludge BNR, was ultimately selected as the best fit in both regards to the facility plan goals and net present costs as detailed in Appendix 2 and 10. The following sections only present the results pertaining to Pathway 2 as it is the recommended alternative.

6.2 Treatment Level 1: Existing Permit with Total Phosphorus (TP) Limit of 0.8 mg/L

Figure 6-3 summarizes the key features of Alternative 2 - A/O to meet Treatment Level 1 effluent criteria through year 2045. Treatment Level 1 is the existing permit taking into account growth and replacement of end of life equipment. The ABC system continues to operate in a nitrifying activated sludge (NAS) A/O mode while the HPOAS train is converted from a two-stage HPOAS system into the same nitrifying activated sludge A/O flow scheme. The ABC complex is expanded to provide a total of five 1.4 MG trains while the existing HPOAS tanks are repurposed to provide the equivalent of three 1.4 MG trains.

Table 6-1 presents the opinion of probable construction cost, capital cost, operations costs, and net present value (NPV) to meet Treatment Level 1. The total capital cost of \$52 million and annual operating cost of \$2,200,000 has a NPV 12 percent less than Pathway 1’s Treatment Level 1 alternative and provides staging and flexibility to meet more stringent limits in a staged process.

Appendix 6 provides a more detailed discussion on the facility requirements, design data, and economic evaluation. Appendix 10 summarizes additional facility requirements and an updated opinion of probable construction cost based upon the recommended A/O single activated sludge system concept.




Figure 6-3. Treatment Level 1 Anaerobic/Oxic (A/O) Key Facility Requirements and Layouts. (Year 2045)

6.3 Treatment Level 2: Total Nitrogen (TN) of 10 mg/L and TP less than 0.4 mg/L

Pathway 2 converts the A/O process to a 5-stage BNR to reduce annual TN discharges below 10 mg-N/L and monthly TP discharges less than 0.4 mg/L or 82 lb/d, whichever is more stringent.

Figure 6-4 summarizes the key attributes of the 5-stage BNR process that converts both the existing HPOAS and ABC aeration trains into a 5-stage BNR basins.

The ABC complex is expanded to provide three 4.2 MG trains while the existing HPOAS tanks and old aeration basins are re-purposed to provide the equivalent of two 4.2 MG trains. A firm effluent filtration capacity of 15 mgd is required to reduce monthly effluent TP discharges below the target limits. Taking into account the plant has already been converted to the A/O system to meet Treatment Level 1, the primary additional facilities for this alternative includes the addition and modifications of aeration basins and repurpose of several older aeration basins to meet permit limits. Additional pumping stations and piping, not shown, would be added to existing tunnel systems. Operator requirements to run the facility are higher than treatment level 1.

Table 6-1 presents the capital cost, operations costs, and NPV to meet treatment level 2. The total capital cost of \$114 million and annual operating cost of \$2,360,000 has an NPV 12 to 17 percent less than the Pathway 1 and 3 Treatment Level 2 alternatives.

Appendix 6 provides a more detailed discussion on the facility requirements, design data, and economic evaluation.




Figure 6-4. Treatment Level 2 5 Stage BNR Key Facility Requirements and Layouts. (Year 2045)

6.4 Treatment Level 2X: NO_x-N of 10 mg/L and TP less than 0.4 mg/L

Treatment Level 2X targets reducing effluent NO_x-N instead of TN primarily because TN limits are much more restrictive and pose a concern for the City. Treatment levels to reduce NO_x-N discharges below 10 mg/L and monthly TP discharges less than 0.4 mg/L or 82 lb/d, whichever is more stringent. Figure 6-5 summarizes the key features of the 3-stage BNR (A2O) system needed to meet the target effluent criteria. Both the HPOAS train and ABC system are converted into 3-stage BNR (A2O) systems. This configuration is a logical progression for nitrogen reduction from the A/O configuration outlined in Treatment Level 1. To meet Treatment Level 2X requirements, similar operations and work is required to Treatment Level 2. However, conversion of the intermediate clarifiers to bioreactors is not required and overall operations are much simpler compared to the 5-stage BNR treatment system. Firm effluent filtration capacity of 15 mgd is required to reduce effluent TP discharges below the target limits

Table 6-1 presents the capital cost, operations costs, and NPV for Treatment Level 2X. The total capital cost of \$104 million and annual operating cost of \$2,330,000.

Appendix 6 provides a more detailed discussion on the facility requirements, design data, and economic evaluation.




Figure 6-5. Treatment Level 2X 3-Stage BNR Key Facility Requirements and Layouts. (Year 2045)

6.5 Treatment Level 3: Total Nitrogen (TN) of 4 mg/L and TP less than 0.1 mg/L

Treatment Level 3 was selected to further reduce annual TN discharges below 4 mg/L and monthly TP discharges to less than 0.1 mg/L or 82 lb/d, whichever is more stringent.

Figure 6-6 summarizes the key features of the 3-stage BNR (A2O) system needed to meet the target effluent criteria. Treatment Level 3 design is the 5 stage BNR process outlined in Treatment Level 2 with the addition of supplemental carbon addition to reduce effluent TN and expanding the tertiary filtration capacity to 30 mgd.

Table 6-1 presents the capital cost, operations costs, and NPV for Treatment Level 3. The total capital cost of \$139 million and annual operating cost of \$3,240,000.

Appendix 6 provides a more detailed discussion on the facility requirements, design data, and economic evaluation.




Figure 6-6. Treatment Level 3 5 Stage BNR Key Facility Requirements and Layouts. (Year 2045)

6.6 A/O Simultaneous Nitrification Denitrification with Hydrocyclones

An emerging innovative A/O flow scheme which operates at low dissolved oxygen (DO) concentrations providing conditions for simultaneous nitrification denitrification (SND) to reduce TN discharges below 10 mg/L and TP discharges below 0.8 mg/L without filtration and 0.4 mg/L with filtration (Treatment Levels 1, 2 and 2X) should be considered for further evaluation and testing. This flow scheme builds upon the recommended A/O flow scheme by incorporating gravimetric selective wasting using hydrocyclones to significantly improve the poor sludge quality typically associated with low DO operations and advanced aeration control systems such as ammonia based aeration control. Figure 6-7 summarizes the key features of an A/O SND with Hydrocyclones system to meet Treatment Level 1, 2 and 2X effluent criteria through year 2045. Plant improvements are the same as described in Section 6.2 with the following additional systems.

- A hydrocyclone wasting station consisting of 12 hydrocyclones on 3 or 4 skids, hydrocyclone feed pumps, and waste sludge pumps for pumping hydrocyclone overflow to the gravity belt thickeners. It is assumed the hydrocyclones and feed pumps are housed in a new building with the overflow pumps in the existing plant tunnels/basement.
- One additional 1.4 MG ABC aeration basin.
- Ammonia based aeration control system.

If proven viable, this alternatives capital cost of \$76 million with filters is roughly 35 and 30 percent lower than the recommended pathway alternatives for Treatment Level 2/2X respectively with annual operating costs 10 percent less under both scenarios. The annual operating cost is also 10 percent lower than the recommended A/O configuration resulting in an NPV 7 percent higher than A/O, which for planning evaluations are considered equal.




Figure 6-7. A/O SND with Hydrocyclones Key Facility Requirements and Layouts. (Year 2045)

To date there is limited operating data on full-scale SND systems with hydrocyclone gravimetric selective wasting. Given the potential energy saving and significant capital savings for reducing TN discharges, this alternative should continue to be monitored and be considered for full-scale demonstration testing on the existing ABC system. This alternative is consistent with the recommended plan of implementing Pathway 2's A/O single activated sludge concept above. Alternative 2SND was not evaluated to further reduce nutrient discharges to Treatment Level 3.

Appendix 6 provides a more detailed discussion on the facility requirements, design data, and economic evaluation. Appendix 10 summarizes additional facility requirements and an updated opinion of probable construction cost based upon the recommended A/O single activated sludge system concept.

6.7 Net Present Value Comparison

Table 6-1 provides a comparison of the net present values of the alternatives identified to achieve the respective treatment levels, listing both the capital costs and the corresponding NPV O&M costs. The A/O SND with Hydrocyclones alternative listed in the last column is presented as an option that could achieve treatment levels 1, 2 or 2X.

Table 6-1. Pathway 2 Opinion of Probable Construction Cost, Capital Cost, Annual Operating Cost, and Net Present Value					
Treatment Level	1	2	2X	3	1, 2, or 2X
Process Configuration	A/O	5-Stage BNR	3-Stage BNR	5-Stage BNR with Carbon Addition	A/O SND with Hydrocyclones
Item					
Total Construction Cost	\$ 42,700,000	\$94,000,000	\$85,700,000	\$ 115,400,000	\$50,000,000
Engineering and Admin. (20 percent)	\$ 8,580,000	\$19,000,000	\$17,000,000	\$23,000,000	\$10,000,000
Equipment Renewal and Replacement	\$750,000	\$750,000	\$750,000	\$750,000	\$750,000
Total Capital Cost (rounded)	\$52,000,000	\$114,000,000	\$104,000,000	\$139,000,000	\$61,000,000^a
Annual Operating Costs					
ABC blower energy	\$310,000	\$250,000	\$300,000	\$290,000	\$ 260,000
HPOAS (Train 1) blower energy	\$ 220,000	\$ 190,000	\$ 150,000	\$190,000	\$ 150,000
Methanol	-	-	-	\$760,000	-
Ferric chloride	\$ 360,000	\$ 360,000	\$ 360,000	\$380,000	\$ 360,000
Mixer/pump energy	\$ 90,000	\$230,000	\$200,000	\$ 230,000	\$ 110,000
Raw sludge processing	\$290,000	\$570,000	\$580,000	\$590,000	\$280,000
Biosolids handling	\$ 570,000	\$120,000	\$120,000	\$130,000	\$ 570,000
Biosolids polymer	\$ 120,000	\$360,000	\$340,000	\$300,000	\$ 120,000
Labor O&M	\$ 220,000	\$280,000	\$280,000	\$400,000	\$ 230,000
Annual operation and maintenance	\$2,200,000	\$ 2,360,000	\$ 2,330,000	\$3,240,000	\$2,100,000
Comparative Annual O&M NPV	\$ 50,000,000	\$57,000,000	\$ 55,000,000	\$76,000,000	\$48,000,000
Net Present Value (rounded)	\$103,000,000	\$168,000,000	\$160,000,000	\$215,000,000	\$110,000,000^a

- Cost presented in 2020 dollars
- Annual operation and maintenance in first year of operation – 2023
- Total capital cost of \$76,000,000 with filters. Net present value of \$125,000,000 with filters

6.8 Treatment Level 4: Salty Water Discharges

A high-level order-of-magnitude evaluation was conducted for the plant to meet Class 2 salty water discharge river water quality standards using membrane filtration/reverse osmosis (MF/RO). Under the Class 2 standards, the WRP effluent chlorides limits would be 405 and 454 mg/L for monthly and maximum day, respectively. Preliminary analysis based upon limited data suggests three process trains with MF capacity of 1.75 mgd/train and RO capacity of 1.5 mgd/train is needed. RO concentrate management assumed a flow scheme with evaporators followed by a crystallizer. Total capital costs for the MF/RO system are roughly \$65 to \$70 million with an estimated annual O&M cost of \$750,000 in during the first year of operation. If total phosphorus and chlorides limits were to become more stringent than those indicated here, capital and operating costs would become even more prohibitive.

An earlier analysis considered the impact of monthly TP and maximum day chloride limits of 0.075 mg/L and 292 mg/L respectively. The estimated costs to treat to these levels were estimated to be \$200,000,000 in capital cost and \$22,000,000 in annual operating costs.

Because of the magnitude of these costs, the option of an alternative outfall located at the Mississippi River in Kellogg, MN was considered, based on an assumption that the effluent limits for the Mississippi would be less stringent effluent limits for the South Fork of the Zumbro River. However, the cost of a lift station and outfall pipe required for a Mississippi River discharge is equally prohibitive with an estimated capital cost of \$220,000,000.

6.9 Sidestream Enhanced Biological Phosphorus Removal

Sidestream enhanced biological phosphorus removal (S2EBPR) is an emerging technology which incorporates a sidestream anaerobic mixed liquor or RAS hydrolysis and fermentation reactor, in lieu of, or in addition to, a traditional mainstream anaerobic selector, for purposes of EBPR. Sidestream RAS Fermentation options could be implemented by diverting a fraction of the RAS flow from the common RAS header to intermediate clarifiers retrofitted into RAS fermentation reactors. If the City wishes to pursue this EBPR approach, pilot testing is recommended to confirm the system requirements and performance. Additional discussion on consideration for a S2EBPR system are included in Appendix 10.

Section 7

Final Effluent

Secondary treatment is followed by disinfection, dechlorination, with final effluent discharged to the South Fork of the Zumbro River. Technical Memorandum 9 - Disinfection and Outfall Evaluation provides an analysis of recommended improvements for this area of the plant. A summary of the analysis and recommended improvements are provided as follows:

7.1 Disinfection

The disinfection system is composed of the three chlorine contact tanks (CCTs) and disinfection chemical feed systems. The tanks were originally commissioned as final clarifiers and later repurposed for chlorine contact, which has resulted in some performance challenges. This section describes potential improvements to the chlorine (Cl₂) and sodium bisulfite (NaHSO₃) chemical delivery systems and modifications to reduce short-circuiting in the CCTs.

7.1.1 Chlorine Addition

The WRP adds Cl₂ before the CCTs via the mixing ejectors. Plant staff have indicated that Cl₂ gas would continue to be used as the primary disinfectant for the foreseeable future. The City desires to reduce power consumption where possible thus BC recommends changing out the chemical mixing system with a significantly less energy intensive chlorine inductor and solution diffuser system. The chlorine inductor(s) gets installed in the chlorination building and mixes the Cl₂ into a stream of final effluent acting as carrier water. The only power demand is the ejector motor final effluent pumping associated with the carrier water. The solution then travels to a submerged perforated polyvinyl chloride (PVC) pipe diffuser located at the CCT inlet.

7.1.2 Dechlorination

Free chlorine present after the CCTs must be removed which the WRP accomplishes through dechlorination with Sodium Bisulfite (NaHSO₃) addition. The NaHSO₃ is currently added approximately 10-ft upstream of the entrance to the outfall pipe. City staff report they currently use more NaHSO₃ than expected based on the stoichiometric relationship would suggest which BC attributes to poor mixing. BC recommends relocating the addition point to the recommended new flow measuring flume inlet discussed in Section 7.2. A new chemical diffuser made from perforated PVC pipe will distribute the NaHSO₃ evenly across the flow stream and the turbulence of the flume provides additional mixing.

7.2 Outfall Modifications

To improve chemical mixing, provide total effluent metering, improve dissolved oxygen concentrations, and reduce short circuiting, outfall modifications shown in Figure 7-1 are recommended. The following is a summary of the outfall modifications:

- Serpentine channels will be added to the existing chlorine basins. The serpentine flow configuration will improve chlorine contact time and reduce dead zones that exist within the current configuration.
- Plant flow is based on several flow meters located at the influent of the plant and large error occurs due to the number of flow meters required. A Parshall Flume will provide effluent

metering as a direct measurement for reliable effluent flow and load recording. A single point of flow measurement will also allow for more accurate flow based chemical dosing and decrease overall chemical costs.

- Cascade aeration will be added to improve DO levels. Forced air aeration will also likely be required to supplement cascade aeration to achieve permitted DO. The current NPDES permit requires final effluent contain 5 mg/L of DO, minimum. Switching from the existing HPO train to A/O will reduce the DO in the final effluent such that levels may drop below the regulated minimum. Cascade is an effective and low cost method to increase DO levels.
- New effluent submersible sampling pumps will replace the existing system that is inefficient due to poor hydraulic conditions. Basin reconfiguration also requires the replacement of these pumps. New effluent pump locations will increase chemical dosing efficiency and dissolved oxygen sampling accuracy.




Figure 7-1. Alternative 2: Rochester WRP serpentine CCT with center channel configuration

7.3 Summary and Opinion of Probable Costs

Table 7-1 provides a summary of the preliminary estimate of construction costs associated with the projects recommended in this section. Improvements will reduce energy costs by \$47,000 annually and reduce annual chemical costs by \$24,000. The probable costs to implement recommended capital improvements are \$1,000,000.

Table 7-1. Disinfection and Outfall Capital Improvements Opinion of Probable Costs	
Item	Cost
Chlorine solution equipment	\$160,000
Chlorine and sodium bisulfite piping and chemical diffusers	\$150,000
Inlet and serpentine flow revisions in existing CCTs	\$230,000
Temporary bypass pumping	\$200,000
Effluent flume	\$50,000
Cascade aeration	\$10,000
Small diffused air system	\$20,000
Engineering and administration (20 percent)	\$160,000
Total capital cost	\$1,000,000

Section 8

Solids Handling

This section provides an abridged discussion of the solids handling analyses conducted in the following TMs. Refer to the TMs for more detail.

- Appendix 7 – Solids Alternatives Evaluations
- Appendix 13 – Industrial Discharge Wasteloads and Practices

8.1 Current Solids Production

The City provided BC with historical plant operating data from January 1, 2014, through December 31, 2017, which were used to establish the current solids loadings and peaking factors. Table 8-1 summarizes selected annual average and maximum month loading values (pounds per day [lb/d]).

Table 8-1. Rochester WRP Current Solids Loading			
Item	Annual Average (lb/d)	Maximum Month (lb/d)	Peaking Factor
Primary sludge	22,400	28,400	1.3
Waste activated sludge	21,500	28,600	1.3
Thickened waste activated sludge	19,400	25,800	1.3
Digester feed	41,800	51,500	1.2
Thickened digested solids	17,200	22,300	1.3

8.2 Projected Solids Production

The projected solids in Table 8-2 are based on the BioWin™ model calibrated to WRP wastewater characteristics and operations, reflecting the recommended A/O configuration, at annual average (AA) conditions using the historical peaking factors in Table 8-1 to estimate maximum month (MM) loads.

The projected thickened digested solids quantities in Table 8-2 include high strength waste (HSW) added to the anaerobic digesters and gravity sludge thickeners for primary sludge thickening. The HSW program loadings (and digested solids quantities) are likely to vary from these projections depending on whether the HSW streams identified participate in the potential WRP program.

Table 8-2. Rochester WRP Projected Solids Loading

Item	2030		2045	
	Annual Average (lb/d)	Maximum Month (lb/d)	Annual Average (lb/d)	Maximum Month (lb/d)
Primary sludge	23,300	29,500	29,100	36,900
Waste activated sludge	26,100	34,700	32,600	43,400
Thickened primary sludge ^a	21,000	27,900	26,200	34,900
Thickened waste activated sludge	23,200	30,900	29,000	38,700
Digester feed ^b	44,800	55,200	56,100	69,100
High strength waste	3,340	4,180	3,340	4,180
Digested solids	27,800	--	34,800	--
Thickened digested solids ^c	24,800	32,100	31,000	40,200

a. Assumes gravity thickener installed.

b. High strength waste not included.

c. Includes high strength waste residuals.

8.3 Thickening

The WRP uses multiple forms of thickening to reduce the volume of water being handled. The following discusses the existing and planned thickening improvements. Refer to Table 8-3 for a summary of capital costs associated with the proposed thickening improvements.

8.3.1 Primary Sludge

The WRP currently thickens primary sludge in the existing primary clarifiers. A separate primary sludge gravity thickening process will more reliably increase the percent solids of the primary sludge fed to the MAD compared to thickening in the primary clarifiers. The City decided to allocate one of the abandoned digester tanks, Digester No. 3, for primary sludge gravity thickening. This process change also requires replacement of the five existing primary sludge pumps with higher capacity units. Another abandoned digester tank, Digester No. 4, will serve as a primary sludge storage tank during gravity thickener outages in the event the anaerobic digesters cannot accept the full primary sludge load due to capacity limitations.

8.3.2 Waste Activated Sludge

WAS is currently thickened on one of the three existing GBTs. The two older GBTs typically support WAS thickening while a new third GBT thickens digested solids. The projected flows and loads indicate the GBTs will be hydraulically and solids overloaded by the end of the planning period during peak conditions. This requires a second GBT to operate and would leave the City without a redundant unit when the digested solids require thickening. A fourth GBT is required to provide redundancy at peak conditions. The City decided to delay the installation of a fourth GBT until the projected flows and loads show a definite increase.

8.3.3 Digested Solids

The digested solids thickening process requires more than one GBT by the end of the planning period from a solids loading basis at maximum day conditions. As noted before the City decided to delay installation of any additional GBTs until the solids loadings show a definite increase.

8.4 Mesophilic Anaerobic Digestion

The existing mesophilic anaerobic digestion system provides solids stabilization and reduction. The City considered a few alternatives to this existing process to reduce life cycle costs as described below. Refer to Table 8-3 for a summary of capital costs associated with the proposed digestion improvements.

8.4.1 Existing Digestion Capacity

The WRP currently relies on Digester Nos. 5 and 6 for most operations while occasionally using Digester No. 1 during outages and when cleaning of the other two digesters. With a primary sludge GT in place, capacity of the existing system does not extend through the entire planning period during maximum month conditions with Digester Nos. 1, 5, or 6 out of service. The conversion of Digester No. 2 to a thickened digested solids storage tank with secondary digester capabilities mitigates the capacity shortfall.

8.4.2 Digestion Alternatives

This evaluation looked at business case evaluations for three digestion alternatives to maximize capacity including thermophilic anaerobic digestion, thermophilic anaerobic digestion with primary sludge GT and mesophilic anaerobic digestion (Status Quo) with primary sludge GT.

Despite the additional volatile solids reduction (VSR) achieved in the thermophilic process the existing mesophilic anaerobic digestion with primary sludge GT resulted in the lowest NPV and lowest natural gas consumption.

This evaluation recommended continuing with the mesophilic anaerobic digestion technology and augmenting its capacity with primary sludge gravity thickening.

8.5 Thickened Digested Solids Storage and Pumping

The most immediate solids processing capacity constraint at the WRP is the capability to land apply thickened digested solids during the brief opportunities in the spring and fall when conditions allow. Several evaluations looked at decreasing the volume of thickened digested solids and storage alternatives.

8.5.1 Hauling Reduction

The existing land application method was compared to thermal and chemical hydrolysis (Lystek), low alkaline hydrolysis, dewatering to a cake solid, and drying the product to a Class A exceptional product. Because the alternate processes have significant chemical and energy costs, the current land application method had the lowest net present value. It is recommended to stay with the existing application until volume hauled exceeds the capability of the WRP's land application program.

8.5.2 Thickened Digested Solid Storage

Based on projected solids production rates, additional thickened digested solids storage capacity will be required within the planning period. Consideration was given to building new storage tanks, leasing temporary dewatering equipment and converting Digester No. 2 to storage. Conversion of Digester No. 2 to storage was selected as the recommended alternative with the lowest net present value. The storage and hauling costs for this analysis was based on 6.5 percent TS leaving the GBTs. The WRP can achieve 7.0 percent solids most of the time but at 7.5 percent solids they cannot sufficiently remove biosolids from the tanks. Efforts continue at the facility to find cost effective methods to reducing hauled solids and increasing solids concentration in storage tanks.

8.5.3 Digested Solids Pumping

Digested solids are currently pumped twice before thickening. This double pumping scenario has high energy costs with the increased number of pumps and high maintenance costs due to struvite buildup. Building a new transfer station or refurbishing the existing Digester No.1 with new pumps was compared against keeping the existing double pumping system. Refurbishing the 0.73 MG Digester No. 1 for digested solids storage and new transfer pumps to convey solids to the GBTs for thickening was the selected alternative to reduce pumping and increase digested solids holding capacity upstream of thickening.

8.6 Digester Control Building No. 1 Improvements

To keep the upper level of Digester Control Building No. 1 unclassified per National Fire Protection Association (NFPA) 820 standard physical separation is required from the lower level which contains sludge pumps and digester gas equipment. Some, electrical, HVAC and architectural modifications are required to maintain physical separation of these classified and unclassified spaces.

8.7 Waste Gas Burner

The existing WGB is no longer in serviceable condition and there are future capacity concerns. The new WGB will automatically light the natural gas pilot flame when the biogas system pressure rises above the relief setpoint. Because of the high safety concern and the current limited operating status of this gas burner, this cost is not included with the solids treatment improvements and is instead moved to a fast track project under construction in 2020.

8.8 Summary of Opinion of Probable Costs

Table 8-3 provides a summary of the preliminary estimate of construction costs associated with the projects recommended in this section and the objectives to be achieved by these improvements.

Table 8-3. Solids Handling Improvements Opinion of Probable Costs ^a		
Item	Cost	Objective
GT system including: <ul style="list-style-type: none"> - Digester No. 3 conversion to thickener - Digester No. 4 conversion to PS storage - PS pump upgrades - TPS pump system - Elutriation water pumps system 	\$5,080,000	Increase digestion HRT to 15 days when Digester No. 5 or 6 are out of service
Digester Control Building No. 1 NFPA 820 modifications and HVAC/electrical renovations	\$830,000	Improve tunnel safety and refurbish corroded equipment
Digester No. 1 conversion for wet well/digestion	\$1,210,000	Simplify operations by reducing double-pumping and provide storage during GBT outages
Digester No. 2 conversion for storage	\$1,340,000	Increase thickened digested sludge storage
Thickening odor control and filtrate drain piping ^c improvements	\$1,620,000	Replace equipment at end of useful life and remove bottleneck in GBT capacity
Secondary digested solids loadout	\$330,000	Provide increased loadout flexibility and capacity
WGB replacement ^b	\$680,000	Improve digester gas management system safety
Total	\$11,100,000	

a. Cost presented in 2020 dollars.

b. 2020 project

Section 9

Biogas Utilization

The WRP utilizes anaerobic digestion for stabilizing the solids generated during the wastewater treatment process. The stabilization, or destruction, of solids generates biogas primarily composed of methane (CH₄) and carbon dioxide (CO₂). The WRP utilizes this biogas to fuel either engine driven electrical generators or hot water boilers. This section summarizes the evaluation of biogas uses captured in Appendix 8.

9.1 Background

From January 1, 2014 to December 31, 2017 the WRP biogas production averaged 272 SCFM, or just under 400,000 standard cubic feet per day (SCFD). Growth in production may occur during the planning period from HSW or load increases but the switch from HPOAS to A/O in the mainstream liquid process will likely reduce production. For this evaluation the historical average value served as the basis.

Lab analysis from two historical gas samples taken after the moisture removal indicated the WRP biogas has relatively low contaminant levels of H₂S and siloxanes.

9.2 Biogas Alternatives Analysis

Biogas utilization alternatives that were considered include the following:

- **Engine-Generators.** There are two existing 1-MW Waukesha engine generators, with one is generally operated at a time due to current gas production. The engine generator alternative's economics were based on replacement of these units at the end of their useful life, which is projected to occur by approximately 2027. New 1 MW engine generators would have an efficiency of approximately 39% compared to the approximately 29% efficiency of the existing units.
- **Microturbines.** The engine-generators could be replaced with microturbines, which are small combustion turbines that cogenerate heat and electricity. They are compact, modular, have lower emissions than diesel engines and require less ancillary equipment. Their output ranges from 65 kW to 330 kW per unit. They have a relatively small footprint and would be expected to fit in the existing engine building along with associated heat recovery equipment.
- **Direct Pipeline Injection.** There is an existing 4-inch 55 psi natural gas pipeline within 37th St. NW right of way and owned by Minnesota Energy Resources (MERC) that could provide a direct biogas injection point. This would require an approximately 50 ft x 80 ft footprint for skid mounted injection monitoring equipment that would be owned and operated by MERC. Pipeline injection would also require enhanced biogas conditioning for the removal of CO₂.
- **On-site Vehicle Fueling.** Biogas can also be repurposed as on-site fuel source. This would require additional equipment for compression, storage and dispensing of CNG. Compressors are required to boost the pressure to approximately 4,500 psi. The footprint for a fast-fill on-site vehicle fueling station would be approximately 50 ft x 110 ft. Similar to the direct pipeline injection alternative, a vehicle fueling station would require enhanced biogas conditioning.

9.2.1 Emissions and Air Permitting Considerations

Olmsted County is currently considered to be in “maintenance” status from an air quality standpoint, so it is treated as being in attainment. The attainment status means that a new engine generator is unlikely to be required by the MPCA to meet Best Available Control Technology (BACT) standards, reducing the likelihood that an oxidation catalyst or selective catalytic reduction (SCR) system would be required.

9.3 Alternatives Comparison and Evaluation

This section presents a capital cost estimate, O&M costs, and NPV analysis for the biogas utilization alternatives.

9.3.1 NPV Analysis

The NPV results are based upon several assumptions and variables outlined in this section and Appendix 8. Table 9-1 shows the NPV results and summarizes the O&M costs on an annual basis for each alternative. Note that positive values reflect costs, while negative values reflect savings.

Cost Component	Status Quo Engines ^a (2 at 1 MW)	Status Quo Engines ^a (1 at 1 MW)	Microturbines with Gas Conditioning (5 at 200 kW)	Pipeline Injection D3 ^c RIN No HSW	Pipeline Injection D5 ^c RIN With HSW	On-site Vehicle Fueling D3 RIN No HSW	On-site Vehicle Fueling D5 RIN With HSW
20-year NPV	\$1.3	(\$2.2)	\$5.5	(\$4.1)	\$15.8	(\$15.9)	\$2.7

- a. Costs are presented in 2020 dollars.
- b. Future mechanical component replacements at 15 years.
- c. Assumed D3 RIN \$1.60 and D5 RIN \$0.45

In comparing alternatives, the most favorable calculated NPV is where all biogas is used for on-site RNG fueling. Sending all biogas to produce a renewable vehicle fuel offers an economic benefit because the D3 RIN value and commodity value of fuel are both recoverable. However, there are hurdles in implementing this alternative, including the need to identify a fleet fueling partner. The pipeline injection alternative has smaller implementation barriers and net 20-year anticipated savings over \$4 million, assuming D3 RIN revenue at \$1.60 and no high strength waste addition that would disqualify the WRP from cellulosic RINs under current EPA policy. If RIN values trend lower, vehicle fueling and pipeline injection revenue will decrease proportionately. As of completing this report, D5 RIN values have remained fairly constant but D3 RIN values have dropped to around \$1.00, which effects NPV’s significantly for D3 alternatives. The local pipeline operator, MERC, has indicated an unwillingness to pursue pipeline injection at the WRP at this time, but this technology is growing rapidly and as industry standards for injection become more common MERC’s interest should increase. Of the cogeneration alternatives, engines appear to have a favorable NPV in comparison to microturbines due to the higher electrical and thermal efficiencies of the technology.

9.3.2 Recommendation

Replacing one existing engine generator with a single new engine generator and new gas cleaning system is the recommended alternative for biogas utilization with a 20 year NPV of \$2.2 million in savings. The remaining Waukesha engine generator would be maintained for stand-by service.

Although vehicle fuel alternatives had higher projected savings in the NPV analysis, the volatile market of D3 and D5 RIN credits, uncertainty of natural gas prices, and hurdles of working with local utilities to transport compressed methane gas make the on-site fueling and pipeline injection alternatives less favorable than the engine generator approach.

Section 10

Reuse and Energy Recovery

This section provides an abridged discussion of the resource and energy recovery systems conducted in Appendix 11 – Heat Recovery Loop Alternative Evaluations

10.1 Existing Systems

The WRP currently operates four heat recover loops serving different areas of the plant:

- Low Temperature (LT) Loop – High-purity oxygen (HPO) system, air compressors, digester gas cooling
- Medium Temperature (MT) Loop – Oxygen Compressor Intercooler
- ABC Low Temperature Loop– Aeration Basin Complex (ABC) and headworks
- Primary Clarifier (PC) 3 – Heat recovery and heat pump for make-up air heating

In the winter, these systems recover heat from wastewater and process equipment and use the heat in air handling unit preheating coils, reducing the energy required for boiler operation. In the summer, the equipment heat is rejected to the wastewater via heat exchange with water from the final clarifiers.

In tandem with the thermal reuse systems, the WRP operates three major effluent reuse systems:

- Spray Water – Headworks and chemical feed water uses (this flow is also the thermal source for ABC low temperature loop and PC3 heat exchangers listed above)
- GBT Washwater – Belt washing
- Flush Water – Basin flushing prior to personnel entering for headworks and ABC plant

The following sections describe these systems and their current maintenance concerns.

10.1.1 Heat Recovery: Low and Medium Temperature Loop

The LT loop uses wastewater withdrawn from FC1 and FC2 to reject excess process equipment heat that is not recovered for space heating. Heat recovery in the LT HVAC systems is currently limited by HVAC equipment and control system components that are not functioning as intended. The MT loop is used for heat recovery of the MAC intercooler system on the cryogenic air plant and then transfers heat to the LT loop. The anticipated shift from HPO to anaerobic/oxic (A/O) operations will remove the oxygen turbo expander, aftercooler, and compressor intercooler from this system and thus eliminate the need for the MT loop. . New blowers with oil cooling will be installed with the A/O conversion, and the oil-cooling system for these blowers can be connected to the LT loop. During winter months, the low temperature loop distributes roughly 1,300,000 btu/hr from equipment and distributes that to hvac preheat coils. During summer months, the low temperature loop dumps the collected heat from equipment into the wastewater through heat exchangers.

10.1.2 Water Reuse: Spray Water System

The spray water pumping system currently serves:

- Heat exchangers serving the ABC low temperature water loop

- Spray water usage, primarily in the headworks area
- PC3's make-up air heating

Water is withdrawn from FC3 and FC4. To improve water quality, chlorine solution can be added to the system and a motorized strainer is located downstream of the pumping system. Continuous use of the spray water system demands approximately 150 gpm while peak demand requires 660 gpm, most of which is for the primary clarifier 3 heating system later discussed. Non-potable water can supplement the spray water system if needed for peak flow conditions.

10.1.3 Heat Recovery: ABC Low Temperature Loop

ABC low temperature loop serves the newer ABC and headworks portions of the plant. The ABC low temperature water loop temperature is 5 °F to 10 °F lower than the effluent and thus recovers more heat from the effluent under winter conditions than the low temperature loop. The effluent water in this system is also used as a heat source for the heat pump serving PC3. During winter months, the ABC low temperature loop distributes 40,000 btu/hr from aeration blower equipment and 1,600,000 btu/hr from wastewater and distributes that to HVAC preheat coils. During summer months, the ABC low temperature loop dumps 40,000 btu/hr from equipment heat into the wastewater through heat exchangers.

10.1.4 Heat Recovery: Primary Clarifier 3 Heating

The PC3 heating system was added in 2011 to minimize fogging and improve personnel safety under the ABC primary clarifier dome. The PC3 system uses effluent water (wasted from the spray water system) in two modes:

- Closed loop preheating of the make-up air
- Effluent-source heat pump (Spray water)

The preheat system provides roughly a third of the winter heating at current loop temperatures with the remainder being provided by the heat pump. Heat recovered from the spray water system is approximately 600,000 Btu/hr during winter months and approximately 400,000 Btu/hr during the fall and spring months.

10.1.5 Water Reuse: Gravity Belt Thickener Washwater

Gravity belt thickener (GBT) washwater is withdrawn from Chlorine Basin 1 via a 20-inch pipe connection to the 1950's wet well. This piping reduces down to 3" before it passes through automatic strainers to the pumping system. Three pumps (replaced in 2004 up-grade) serve 3-inch and 4-inch parallel headers to the three GBT units. The manufacturer requires a minimum of 120 psi washwater at the GBT units at a flow rate of approximately 50 gpm per unit.

10.1.6 Flushing Water

Flushing water system draws wastewater from the same piping as the spray water system and is designed to flush out basins prior to personnel entering. The system works great however, the flushing water system starves the spray water pumping system of flow which has caused premature failure of pumps several times over just 13 years.

10.2 Recommendations

The recommended modified heat recovery loop configuration is shown in Figure 10-1. The addition of a final clarifier effluent vault water intake was chosen as a water source for both the heat recovery system and reuse water systems. The addition of the vault removes wastewater intakes from the

clarifiers which testing has shown will increase clarifier performance. In addition, the quality of treated wastewater will be higher and provide for better use as a spray water and flushing water throughout the plant as well as reduce maintenance caused by fouling on the wastewater heat exchangers. Figure 10-1 also shows the elimination of the medium temperature loop and combining of the low temperature loops to reduce pumping energy costs and maintenance costs.




Figure 10-1. Proposed heat recover and water reuse system

Note: Following conversion to A/O

10.3 Summary of Opinion of Probable Costs

Current heat recovery and water reuse system operating costs were estimated to be roughly \$125,000 per year. The modified effluent water intake, merged water loops, and spray water modifications are estimated to save approximately \$35,000 per year in pumping energy and \$20,000 per year in reduced pump and heat exchanger maintenance, reducing the estimated future annual operating cost to \$70,000.

Table 10-1 summarizes the recommended capital improvements.

Table 10-1. Immediate Capital Improvements Opinion of Probable Costs^a		
Item	Cost^{a, b}	Objective
Effluent water intake vault and suction piping near final clarifiers	\$138,000	Reduce maintenance and pumping energy
Merged LT water loops	\$50,000 ^c	Reduce pump maintenance
Reuse spray water pumping and piping revisions	\$115,000 ^e	Reduce pumping energy
PC3 HVAC heat source revisions	\$180,000	Reduce pumping energy
Strainer upgrades	\$100,000	Minimize maintenance of equipment served by spray water and GBT washwater systems
Demolish MT cooling loop	... ^d	Loop no longer required following conversion of secondary treatment to A/O
Total	\$590,000	

- a. Refer to Appendix 11 for accuracy, contingency, mark ups, and engineering and administration assumptions
- b. AACEI Class 5 estimate
- c. Rough estimate without developed scope of improvements
- d. Cost included in liquid treatment estimate
- e. Spray water pump replacement and connection to new effluent water intake vault

Section 11

Recommendations and Implementation Plan

The Rochester WRP Facilities planning process was initiated to create a long-range plan to meet current and anticipated regulatory requirements with an upgraded facility that would achieve these objectives:

- Lower Energy – Reduce energy consumption while maximizing energy recovery towards a long-term goal of net-zero operation.
- Clean Design – Reduce plant complexity through elimination of parallel processes and consolidation of assets.
- Decreased Maintenance – Strive for operational simplicity and elimination of high maintenance aging infrastructure
- Innovative Processes - Implementation of best available and yet proven technologies.
- Long-Term Wholistic Approach - Provide a staging plan to achieve near term treatment goals with processes and configurations to accommodate future improvements to meet increasingly stringent regulatory requirements.

The City considered the recommended improvements from the previous sections and in collaboration with BC came up with a three-phased implementation plan based upon facility needs.

11.1 Phase 1 Improvements

Phase 1 improvements shown in Figure ES-1 are programmed to occur between 2020 and 2023 and will address immediate needs at the WRP including the following:

- Disinfection
Disinfection improvements will include replacement of the chlorine injection equipment and replacement of the dechlorination feed system to reduce energy consumption, reduce chemical consumption and replace aging equipment. The chlorine contact basins will also be reconfigured to minimize short-circuiting and to increase chlorine contact time
- Outfall Improvements
Reconfiguration of the chlorine contact basins will include installation of a Parshall flume to provide plant effluent metering and installation of a cascade aeration system to improve effluent dissolved oxygen going to the river.
- Waste Gas Burner Replacement
The existing waste gas burner will be replaced with an upgraded unit installed on the north side of the WRP, improving safety and reliability.
- Space Modifications
While evaluated as a separate project outside the scope of this document, Phase 1 also includes a significant remodel to the WRP administration building and a new garage building for equipment storage.

11.2 Phase 2 Improvements

Phase 2 improvements shown in Figure ES-2 are programmed to occur between 2023 and 2027 and will focus on upgrades to the liquid treatment processes, including conversion of the HPOAS system to an air activated sludge system. These improvements will include the following:

- Primary Effluent Distribution

A new flow-distribution structure will combine effluent flow from Primary Clarifiers 1 through 3 and then distribute the flow to the secondary treatment bioreactors improving process control and maximizing primary clarifier capacity.

- Biological Phosphorus Removal

The existing HPOAS system will be decommissioned and converted to a nitrifying enhanced biological phosphorus removal system. The new single stage activated sludge system will include a new process aeration blower facility. These upgrades will allow the decommissioning of the aging cryogenic facility reducing maintenance costs and reducing energy consumption.

- Sludge Pumping Improvements

Sludge withdrawn from Final Clarifiers 1-5 will be pumped into a common RAS pipeline and routed to a new return sludge flow structure and will then be distributed to the secondary treatment bioreactors.

A new flow control structure will be constructed to route excess ABC mixed liquor flow to Final Clarifiers 1-4.

The existing RAS pumps servicing Final Clarifiers 1 through 4 will also be replaced with higher capacity units.

- Additional Aeration Capacity

The ABC plant will be expanded through the construction of three additional aeration basins to meet future demands.

- Effluent Heat Recovery

Effluent heat recovery will be improved through the addition of a final clarifier effluent vault water intake as a source for the heat recovery system and the reuse water system. The medium temperature loop will be eliminated and the low temperature loops will be combined, reducing energy costs, reducing maintenance costs and providing a higher quality water,

11.3 Phase 3 Improvements

Phase 3 improvements shown in Figure ES-3 are programmed to occur between 2027 and 2030 and will focus on the solids handling facilities. Deferring these improvements until after implementation of the A/O process will allow confirmation of solids loading and solids handling characteristics based on full plant implementation of the new secondary treatment processes.

Following is a summary of the recommended Phase 3 improvements:

- Gravity sludge thickening

Digester No. 3 will be renovated and converted to a primary sludge gravity thickener and Digester No. 4 will be upgraded as a primary sludge storage tank providing storage capacity

during gravity thickener outages. This will avoid the need to provide additional digester capacity

- Digested solids wet well

Digester No. 1 will be converted to a digested sludge storage tank and will be used as a wet well prior to thickening the sludge on the gravity belt thickeners, improving overall operational flexibility.

- Thickened digested solids storage

Digester No. 2 will be refurbished as recuperative digester and sludge storage tank.

- Odor control

The odor control system for the new solids handling facilities will be upgraded, replacing antiquated equipment and providing increased capacity.

- Sludge loadout

The sludge loadout facility will be upgraded with increased capacity to relieve truck loading congestion and improve the efficiency of the land application program.

- Control building upgrades

Digester Control Building No. 1 will be upgraded to bring it into compliance with NFPA 820 requirements.

Phase 4 Improvements

Phase 4 improvements shown in Figure ES-4 focus on upgrades to the liquid treatment processes required to address future effluent limits based on the treatment levels identified in Table ES-1. Each level represents increasingly stringent effluent limits with corresponding upgrades necessary to achieve those limits.

- Level 2X

Level 2X improvements are based on monthly ammonia limits less than 2 mg/L, an annual nitrate + nitrite nitrogen limit of 10 mg N/L and a monthly total phosphorus limit of 0.4 mg/L. Under this scenario an upgrade to a 3-stage BNR process would be required and the addition of effluent filters at a rated capacity of 15 mgd.

- Level 2

Level 2 improvements are based on monthly ammonia limits less than 2 mg/L, an annual total nitrogen limit of 10 mg N/L and a monthly total phosphorus limit of 0.4 mg/L. The selected treatment alternative for these effluent limits consists of migration to a 5-stage BNR process and effluent filters at a rated capacity of 15 mgd.

- Level 3

Level 3 improvements are based on monthly ammonia limits less than 2 mg/L, an annual total nitrogen limit of 4 mg N/L and a monthly total phosphorus limit of 0.1 mg/L. Level 3 regulatory requirements would require 5-stage BNR with carbon addition and effluent filter capacity of 30 mgd.

11.4 Summary and Opinion of Probable Costs

Table 11-1 summarizes the project costs for each phase. The phase 4 cost is based on the cumulative cost of treatment levels 2, 2X and 3.

Table 11-1. Rochester WRP Phased Improvements Opinion of Probable Costs^a		
Item	Cost	Implementation Schedule
Phase 1	\$10,000,000	2020 - 2023
Phase 2	\$52,000,000	2023 - 2027
Phase 3	\$11,000,000	2027 - 2030
Phase 4	\$75,000,000	Based on future effluent limits
Total	\$148,000,000	

Section 12

Clean Water Revolving Fund Checklists and Forms

At that point in time when specific projects are identified for implementation, several steps will be required for participation in the Clean Water Revolving Fund (CWRP) Program as administered by the MN Pollution Control Agency. These steps are outlined in the following MN PCA Checklists and Forms as summarized below:

1. CWRP Facilities Plan Submittal Checklist

This checklist provides a summary list of steps to be taken and documentation required for facilities plan submittals.

2. CWRP Cost and Effectiveness Checklist

This checklist provides a summary of the cost and effectiveness analysis as documented in the facilities plan.

3. CWRP B3 SB 2030 Exemption Form.

This form documents exemption from the Building, Benchmarks and Beyond (B3) provisions of the Sustainable Building (SB) 2030 guidelines as applicable.

4. CWRP Cost and Effectiveness Certification Form

This form documents compliance with the cost and effectiveness review requirements of the project.

5. Minnesota Clean Water Revolving Fund Cost and Effectiveness Guidance

This document provides guidance for completing the cost and effectiveness checklist.

6. Environmental Information Worksheet (EIS) Form

This form summarizes the environmental review process that must be completed in conjunction with submittal of the Facilities Plan to the MN Pollution Control Agency.

These checklists and forms are included as attachments at the end of this section

Instructions: The Facilities Plan may be submitted via email at ppl.submittals.pca@state.mn.us (and one hard copy submitted to the assigned Minnesota Pollution Control Agency [MPCA] Review Engineer).

Facility information

Project name: _____
 Proposed dates for construction: _____
 City's authorized representative: _____
 Title: _____ Telephone: _____
 Mailing address: _____
 City: _____ State: _____ Zip code: _____
 Technical agent or consulting engineer: _____
 Name of firm/organization: _____ Telephone: _____

Check yes or no for the following questions

Is the Facilities Plan signed by an engineer registered in the State of Minnesota? Yes No
 Has the municipality in which the facility will be located held at least one public hearing to discuss the proposed project?
 Yes No If yes, what was the date the hearing was held: _____

Check the boxes below if you have included the following items

If all of the following items are not included with the Facilities Plan, the Facilities Plan is incomplete and may be returned or filed until a complete submittal is received. Facilities Plan review will not begin until a complete submittal is received. Please see Minn. R. 7077.0272 for more information about the content of facilities plan.

The following forms can be found on the MPCA website at <https://www.pca.state.mn.us/water/wastewater-financial-assistance>.

- A completed *CWRF cost and effectiveness certification checklist* provided by the MPCA.
- A completed *CWRF B3 2030 exemption form* provided by the MPCA.
- A completed CWRF cost and effectiveness certification form provided by the MPCA.
- A summary of the public hearing documenting that the following items were discussed:
 - The various treatment alternatives considered
 - The location of the project site
 - The reasons for choosing the selected treatment method
 - The estimated sewer service charges
- A summary of the comments received at the public hearing and the action taken to address those comments.
- A complete list of addresses used for public notice purposes on a form provided by the MPCA.
- A copy of the resolution of the municipality's governing body adopting the facilities plan.
- A list of ordinances or intermunicipal agreements required for the implementation and administration of the project.
- A signed treatment agreement with each significant industrial user.
- For surface water dischargers only, a copy of the Preliminary Effluent Limits review letter provided by the MPCA.
 - Contact the MPCA to determine if a formal request for Preliminary Effluent Limits needs to be made for the project.
 - The alternatives analysis should address antidegradation requirements if the project is proposing an increase in flow or loading.
- A completed *Environmental Information Worksheet* provided by the MPCA.
- For individual sewage treatment systems that serve more than one structure, an assurance from the municipality stating that all property owners who will be served by the proposed system agree to be part of the system, to participate in the construction project, and to finance future operation, maintenance, and replacement of the system.
- Copies of all notifications, certifications, and comments received.

Instructions: This checklist must be used with the Minnesota Pollution Control Agency (MPCA) *Minnesota Clean Water Revolving Fund (CWRF) cost and effectiveness guidance* document dated March 2018. The guidance document assists the consulting engineer in completing the cost and effectiveness analysis required by the Federal Water Pollution Control Act (FWPCA) Section 602(b)(13). The cost and effectiveness analysis for a project must be further documented in the project Facilities Plan. This checklist is also an attachment to the MPCA *Facilities Plan submittal checklist*.

Project information

Project name: _____ Date submitted (mm/dd/yyyy): _____

City: _____

City's authorized representative: _____

Consulting engineer: _____

Cost analysis items

Cost analysis items to be completed for all CWRF wastewater projects.

Section		Yes	No
II.	Does the project owner have an Asset Management system in place? Where is the Asset Management system documented in the Facilities Plan:	<input type="checkbox"/>	<input type="checkbox"/>
IVA.	Did the Facilities Plan address Energy Conservation Opportunities? Where is the Energy Conservation discussion documented in the Facilities Plan:	<input type="checkbox"/>	<input type="checkbox"/>
IVB.	Did the Facilities Plan address Renewable Energy Opportunities? Where is the Renewable Energy discussion documented in the Facilities Plan:	<input type="checkbox"/>	<input type="checkbox"/>
IV.C.i.	Has the Facilities Plan analyzed Water Reuse options? Where is the Water Reuse options analysis documented in the Facilities Plan:	<input type="checkbox"/>	<input type="checkbox"/>
IV.C.ii.	Has the Facilities Plan analyzed installation of Water Efficient Devices? Where is the use of Water Efficient Devices analysis documented in the Facilities Plan:	<input type="checkbox"/>	<input type="checkbox"/>
IV.C.iii.	Has the Facilities Plan analyzed installation of new Water Meters or replacement of existing Water Meters? Where is the installation of new or replacement Water Meters analysis documented in the Facilities Plan:	<input type="checkbox"/>	<input type="checkbox"/>
IV.C.iv.	Has the Facilities Plan considered or completed Water Audits and/or Conservation Plan? Where is the discussion of Water Audits and/or Conservation Plan documented in the Facilities Plan:	<input type="checkbox"/>	<input type="checkbox"/>
IV.D.	Did the Facilities Plan for the project complete a Buildings, Benchmark, and Beyond (B3) Sustainable Building (SB) Wastewater Treatment Plant (WWTP) or B3 SB 2030 <i>WWTP exemption form</i> ? Where is the B3 SB 2030 <i>WWTP exemption form</i> documented in the Facilities Plan:	<input type="checkbox"/>	<input type="checkbox"/>

Nonmonetary analysis items **Applicable:** Yes No

Nonmonetary analysis items to be completed for all new wastewater treatment facilities with design average wet weather (AWW) flow of greater than 100,000 gallons per day, or significant upgrades meaning work on three or more major treatment units for any wastewater treatment facilities with a design AWW flow of greater than 1 million gallons per day.

Section		Yes	No
V.A.i.	Does the Facilities Plan analyze the project sustainability and climate resilience? Where is the discussion on project sustainability and climate resilience documented in the Facilities Plan:	<input type="checkbox"/>	<input type="checkbox"/>
V.A.ii.	Does the Facilities Plan analyze how a project addresses Water Quality objectives? Where is the discussion on how the project addresses Water Quality objectives documented in the Facilities Plan:	<input type="checkbox"/>	<input type="checkbox"/>
V.A.iii.	During the project planning process, did the owner consider project alternatives, such as consolidation or regionalization with another or other service area? Where is the discussion on how the project addresses possible consolidation or regionalization documented in the Facilities Plan:	<input type="checkbox"/>	<input type="checkbox"/>
V.B.i.	Is the project location and physical aspects discussed in the Facilities Plan? Where is the discussion on the project location and physical aspects located in the Facilities Plan:	<input type="checkbox"/>	<input type="checkbox"/>
V.B.ii.	Is the project reliability discussed in the Facilities Plan? Where is the discussion on the project reliability located in the Facilities Plan:	<input type="checkbox"/>	<input type="checkbox"/>
V.B.iii.	Is the project feasibility and operability discussed in the Facilities Plan? Where is the discussion on the project feasibility and operability located in the Facilities Plan:	<input type="checkbox"/>	<input type="checkbox"/>
V.C.i.	Are possible water conservation practices, water reuse and/or water recapture opportunities discussed in the Facilities Plan? Where is the discussion on the project water conservation practices, water reuse, and/or water recapture opportunities located in the Facilities Plan:	<input type="checkbox"/>	<input type="checkbox"/>
V.C.ii.	Are possible energy conservation practices discussed in the Facilities Plan? Where are the possible energy conservation practices discussed in the Facilities Plan:	<input type="checkbox"/>	<input type="checkbox"/>
V.C.iii.	Are possible opportunities to recover and recycle or reuse other resources discussed in the Facilities Plan? Where are possible opportunities to recover and recycle or reuse other resources options discussed in the Facilities Plan:	<input type="checkbox"/>	<input type="checkbox"/>
V.C.iv.	Are possible opportunities to use green infrastructure components within the project discussed in the Facilities Plan? Where are possible opportunities to use green infrastructure components within the project discussed in the Facilities Plan:	<input type="checkbox"/>	<input type="checkbox"/>
V.C.v.	Are possible other environmental impacts of the project discussed in the Facilities Plan? Where are the possible other environmental impacts of the project discussed in the Facilities Plan:	<input type="checkbox"/>	<input type="checkbox"/>

Section		Yes	No
V.D.i.	<p>Are possible considerations which may be part of a local trend or demographics affecting the need or demand for a project discussed in the Facilities Plan?</p> <p>Where are the possible considerations which may be part of a local trend or demographics affecting the need or demand for a project discussed in the Facilities Plan:</p>	<input type="checkbox"/>	<input type="checkbox"/>
V.D.ii.	<p>Are possible considerations which may be part of a local trend or demographics affecting the need or demand for a project discussed in the Facilities Plan?</p> <p>Where are the possible considerations which may be part of a local trend or demographics affecting the need or demand for a project discussed in the Facilities Plan:</p>	<input type="checkbox"/>	<input type="checkbox"/>
V.D.iii.	<p>Are there possible environmental justice issues which may be considered for the project discussed in the Facilities Plan?</p> <p>Where are the possible environmental justice issues which may be considered for the project discussed in the Facilities Plan:</p>	<input type="checkbox"/>	<input type="checkbox"/>
V.D.iv.	<p>Are there possible acceptability or affordability issues which may be considered for the project discussed in the Facilities Plan?</p> <p>Where are the possible acceptability or affordability issues which may be considered for the project discussed in the Facilities Plan:</p>	<input type="checkbox"/>	<input type="checkbox"/>

Integrating cost and effectiveness analysis Applicable: Yes No

Integrating cost and effectiveness analysis to be completed for all new wastewater treatment facilities with design AWW flow of greater than 100,000 gallons per day, or significant upgrades meaning work on three or more major treatment units for any wastewater treatment facilities with a design AWW flow of greater than 1 million gallons per day.

Section		Yes	No
VI.	<p>Has an integrated cost and effectiveness analysis of the cost factors and the other/nonmonetary factors for a project been completed in the Facilities Plan?</p> <p>Where is the integrated cost and effectiveness analysis of the cost factors and the other/nonmonetary factors for a project discussed/located in the Facilities Plan?</p>	<input type="checkbox"/>	<input type="checkbox"/>

CWRF B3 SB 2030 exemption form

Clean Water Revolving Fund (CWRF) Program Wastewater Projects

(Minn. Stat. § 216B.241, sub. 1-10 and 16B, sub. 1-4)

Instructions: If at least one of the “Yes” statements is checked, the project is considered to have completed these requirements and is not required to submit additional information to meet the Building, Benchmarks, and Beyond (B3) provisions of the Sustainable Building (SB) 2030 Guidelines (B3 SB 2030). Sign and send the completed form to the Minnesota Pollution Control Agency (MPCA) project engineer.

If the answer to **all of the statements is “No”**, the project will submit a preliminarily approved Facilities Plan [Minn. R. 7077.0272] to B3 SB 2030 Wastewater Treatment Plant Review. Sign and send the completed form to the MPCA project engineer.

Project information

Project name: _____

MPCA review engineer: _____ MPCA project number: _____

Exempt criteria

	Yes	No
1. The project is limited to environmental study.	<input type="checkbox"/>	<input type="checkbox"/>
2. The project is limited to planning and design.	<input type="checkbox"/>	<input type="checkbox"/>
3. The project is for emergency/disaster relief and/or protection.	<input type="checkbox"/>	<input type="checkbox"/>
4. The project is limited to minor modifications to an existing treatment facility.	<input type="checkbox"/>	<input type="checkbox"/>
5. The project is limited to modifications within a new or an existing building less than 10,000 square feet.	<input type="checkbox"/>	<input type="checkbox"/>
6. The project is limited to a new or existing collection system including lift stations.	<input type="checkbox"/>	<input type="checkbox"/>
7. The project is limited to pond system.	<input type="checkbox"/>	<input type="checkbox"/>
8. The project is limited to installation of a backup power generator.	<input type="checkbox"/>	<input type="checkbox"/>
9. The project is limited to a stormwater project	<input type="checkbox"/>	<input type="checkbox"/>

If “Yes” to any of 1- 9 above, please provide a brief written description of the project and complete the Certification Statement below.

Certification statement

I certify that the information provided on this form is complete and accurate and that this project:

- Meets the exempt criteria established by the Minnesota Pollution Control Agency.
- Does not meet the exempt criteria and a preliminary approved Facilities Plan will be sent to the B3 SB 2030 Wastewater Treatment Plant Review

Project Representative or Professional Engineer

Print name: _____

Organization: _____

Signature: _____

Date (mm/dd/yyyy): _____

CWRF cost and effectiveness certification form

Clean Water Revolving Fund (CWRF) Program

Federal Water Pollution Control Act Section 602(b)(13)
and Minn. R. 7077.0272, subp. 2.D. or 7077.0277, subp. 2.C.

Instructions: The project representative must check boxes 1), 2), and either Z) or ZZ) below, and the form must be signed by both the Project Representative and the Professional Engineer for the project.

- 1) The municipality has studied and evaluated the cost and effectiveness of the processes, materials, techniques, and technologies for carrying out the proposed project or activity for which the assistance is sought under the Clean Water Revolving Fund (Minn. Stat. § 446.07); and
- 2) The municipality has selected, to the maximum extent practicable, a project or activity that maximizes the potential for efficient water use, reuse, recapture, conservation, and energy conservation^{Z&ZZ}, taking into account:
 - a) The cost of constructing the project or activity.
 - b) The cost of operating and maintaining the project or activity over the life of the project or activity.
 - c) The cost of replacing the project or activity.
 - Z) If this project exempt from Building, Benchmarks, and Beyond (B3) provisions of the Sustainable Building (SB) 2030 Guidelines (B3 SB 2030) Wastewater Treatment Plants (WWTP) Review (attach a completed *B3 SB 2030 exemption form*).
 - ZZ) If this project not exempt from B3 SB 2030 WWTP Review.

Project information

Municipality name: _____

Project number: _____

Certification

We certify that the project has completed requirements (1 and 2, and either Z or ZZ) as checked above.

Project Representative

Print name: _____

Signature: _____

Date (mm/dd/yyyy): _____

Professional Engineer

Print name: _____

Signature: _____

Date (mm/dd/yyyy): _____

Footnote: If ZZ) is checked, the Professional Engineer has submitted a Facilities Plan to the B3 SB 2030 WWTP Review and will consider the Review water and energy conservation recommendations.

Minnesota Clean Water Revolving Fund

Cost and Effectiveness Guidance

- I. Introduction 1
- II. Asset Management related to Facilities Plan discussion 2
- III. Cost and Effectiveness Analysis 2
- IV. Cost Analysis..... 3
 - A. Energy conservation opportunities 3
 - B. Renewable energy opportunities 4
 - C. Water conservation opportunities 4
 - D. Buildings, Benchmarks and Beyond (B3) and Sustainable Building (SB) 2030 Wastewater Treatment Plant Review 5
- V. Other Factors/Nonmonetary Analysis..... 5
 - A. National, regional, state, and local priorities..... 5
 - B. Technical factors 6
 - C. Environmental factors..... 6
 - D. Socioeconomic factors 6
- VI. Integrating Cost and Effectiveness Analysis..... 7

I. Introduction

The Federal Water Pollution Control Act (FWPCA) was amended on June 10, 2014, to include a requirement under Section 602 (b)(13) that any recipient of Clean Water Revolving Fund (CWRF) assistance must complete a **Cost and Effectiveness Analysis** for any project with signed loan agreements after October 1, 2015.

(13) beginning in fiscal year 2016, the State will require as a condition of providing assistance to a municipality or inter-municipal, interstate, or State Agency that the recipient of such assistance certify, in a manner determined by the Governor of the State, that the recipient –

(A) has studied and evaluated the cost and effectiveness of the processes, materials, techniques, and technologies for carrying out the proposed project or activity for which assistance is sought under this title; and

(B) has selected to the maximum extent practicable, a project or activity that maximizes the potential for efficient water use, reuse, recapture, and conservation and energy conservation, taking into account -

- (i) the cost of constructing the project or activity;
- (ii) the cost of operating and maintaining the project or activity over the life of
- (iii) the life of the project or activity; and
- (iv) the cost of replacing the project or activity

The U.S. Environmental Protection Agency (EPA) has provided State CWRP program staff with interpretive guidance documents to assist with implementing this requirement. On January 6, 2015, the EPA published a memorandumⁱ with additional supplemental information on section 602(b)(13). This document identified the State has discretion to decide how an assistance recipient will certify that it has completed the required cost and effectiveness analysis and that it has selected to the maximum extent practicable, a project or activity that maximizes the potential for water and energy conservation, as appropriate.

To address this section 602(b)(13) requirement, the Minnesota Pollution Control Agency (MPCA) first created a certification form dated January 28, 2015, to state the section language directlyⁱⁱ. The current practice with this MPCA certification form has allowed the project recipient's consulting professional engineer to use their best professional judgement when making the statement or signing the certification form. This MPCA guidance document will further assist the consulting professional engineer with completing the cost and effectiveness analysis during the project Facilities Plan process, prior to signing off on the MPCA certification form.

II. Asset Management related to Facilities Plan discussion

Asset Management is a tool that can help inform the project Facilities Plan process. For a project owner, an Asset Management system can help inform project needs identification by showing the age of the individual system asset and the current condition or status of an asset. Asset Management systems or inventories can assist the project owner in determining which system components and equipment have remaining life that can be retained as a part of a project, which components and equipment need replacement, and may assist the owner with describing possible salvage values of components.

If a project owner has an existing Asset Management document or tool, a copy or summary of it should be located in the Facilities Plan. If the Asset Management tool is an electronic management system, a sample page of the Asset Management electronic system should be attached and referenced in the Facilities Plan and identified as a sample of the owner's Asset Management system.

The Minnesota Public Facilities Authority and the MPCA strongly encourage municipalities to have an Asset Management system. Some costs related to the development of an Asset Management system may be fundable as a part of a CWRP construction loan.

For project owners currently without an Asset Management system, there are resources available to help develop such a system.

The Minnesota Rural Water Association recently published Asset Management information on their website. Two documents are available: (1) Asset Management Introduction and (2) Asset Management for Wastewater (Stabilization Ponds) Systems {in an Excel template}. Links to those two documents are located at: <http://mrwa.com/assetmgmt.html>.

The EPA has an Asset Management guidance document for Small Water Systems that may be a useful reference for developing a small wastewater facilities Asset Management system. The current webpage location for this document is: <http://tinyurl.com/zwhsdbg>.

The EPA also has an Asset Management tool available to download called Check Up Program for Small Systems at: <https://www.epa.gov/dwcapacity/information-check-program-small-systems-cupss-asset-management-tool>.

III. Cost and Effectiveness Analysis

A cost effectiveness comparison of alternatives has been a requirement of the Minnesota CWRP program for many years, as part of the Facilities Plan for Wastewater Treatment Systems process for a project. The wastewater Facilities Plan must include information on the initial analysis of a project owner's identified needs, and the alternatives explored for meeting the objectives set out by that owner within any given goals and constraints while maximizing the federal, state, and local objectives for potential for water and energy efficiencies. The Facilities Plan must also identify the chosen project alternative selected by the owner and give the supporting reasons for selecting that alternative.

For CWRW wastewater collection and treatment projects, Minnesota Rule (Minn. R.) 7077.0272, subp. 2 describes the required contents of a Facilities Plan and includes subp. 2.D. “an analysis of all feasible treatment alternatives that are capable of meeting the applicable effluent, water quality and public health requirements for 20 years”. Minn. R. 7077.0272, subp. 2(1) goes on to require a cost effectiveness comparison of the alternatives considered, and is narratively described as a present worth analysis of all capital costs, annual operation and maintenance costs, equipment replacement costs, and salvage values.

Another way to depict this common engineering analysis calculation was shown in an EPA interpretive guidance memorandum dated April 17, 2015ⁱⁱⁱ. This EPA guidance document cited an Oregon state program reference^{iv} which shows an equation that will be adopted and modified slightly here using the Minnesota Rule cost effective language:

The present worth (PW) for each technically feasible alternative is calculated as the sum of the capital cost (C) plus the present worth uniform series of annual operation and maintenance costs (USPW {O & M}) plus equipment replacement costs (ER) minus the single payment present worth of the salvage values (SPPW {S}) or shown as:

$$PW = C + (USPW \{O \& M\}) + ER - (SPPW \{S\})$$

The change required by the FWPCA Section 602 (b)(13) adds the word “**and**” to the analysis, calling it a cost “**and**” effectiveness. What does this mean for Minnesota projects?

In short, it means added detail to the required cost “**and**” effectiveness analysis will need to be included in a project Facilities Plan.

IV. Cost Analysis

A Cost Analysis is to be completed for all wastewater projects and should include consideration of these items.

A. Energy conservation opportunities

Energy assessments for the electrical use components of a project should be completed at least preliminarily during the Facilities Plan process. This may be done for separate project types and/or portions of a project. Collection system projects should consider the electrical use at lift stations and pump types given the overall system design. This should be for both lift stations within the collection system as well as the main pumping station transporting the wastewater to the treatment facility.

Treatment facilities should assess energy usage throughout the plant complex. This could include mechanical facilities aeration energy use, mixing energy, solids handling energy use (transfer, mixing, aeration), and possible energy capture and reuse from solids processing.

For any existing electrical equipment that is proposed to be reused in a project or remain in service, energy audits should be considered to identify opportunities for possible energy savings. Similar to the energy assessments, components should be reviewed for their purpose and need, and determinations should be made if more efficient electrical components could be used to improve energy efficiency at the facility.

The state of Minnesota’s Buildings, Benchmarks & Beyond (B3) suite of tools has a wastewater treatment energy evaluation process within B3 Sustainable Buildings (SB) 2030 called B3 SB 2030 Wastewater Treatment Plant (WWTP) Review, including WWTP energy performance metrics in B3 Benchmarking.

The B3 Benchmarking tool provides an on line platform to track energy performance and help determine efficiency at existing WWTPs.

Learn more about B3 Benchmarking: <https://mn.b3benchmarking.com/>

Learn more about B3 Benchmarking & WWTPs: <http://mn.b3benchmarking.com/WastewaterTreatmentPlants>.

Access the B3 Benchmarking tool: <https://mn.b3benchmarking.com/Request-Access>.

The B3 SB 2030 WWTP Review is an energy review process and set of minimum energy conservation measures (ECM) that should be considered for WWTP designs. B3 SB 2030 WWTP Review may apply to certain wastewater projects. An MPCA SB 2030 exemption form is available to determine if the B3 SB 2030 WWTP Review applies. For more information, see Section III.D. or to learn more about the B3 SB 2030 WWTP Review go to: <http://www.b3mn.org/>.

Energy audits conducted by the local gas provider, electric utility, professional engineer, or the Minnesota Technical Assistance Program (MnTAP) may be able to help with efforts to optimize energy use. Other possible resources or references for energy conservation information are available from the Water Environment Federation^v and on the MNTAP webpage at: <http://www.mntap.umn.edu/POTW/energy.html>.

B. Renewable energy opportunities

The Cost Analysis should also consider renewable energy opportunities such as solar, wind, biogas, combined heat and power, etc. as a means of reducing the energy profile and providing a more reliable energy source in times of power outages. There may be rebate offers by public utilities to help finance the installation of renewable energy systems.

C. Water conservation opportunities

The Cost Analysis should also consider water conservation opportunities. Using less water within a project area can have an impact on the wastewater facilities in that project area. The Cost and Effectiveness Analysis should consider water conservation opportunities, including:

- i. Water reuse options. This option would be most appropriate in facilities planning for wastewater treatment facilities projects, as the treatment facility eventual design would be impacted by the type of treatment required for the possible water reuse opportunities. For example, are there industries, recreational locations (golf courses, parks, fields etc.), agricultural producers, or landscaping locations in the project area or near the project service area that may be interested in partnering on a water reuse project?

A Water Reuse Analysis section should be in the Facilities Plan clearly so it is very easy to document the option has been considered by the project.

If water reuse is not analyzed as an alternative, the project Facilities Plan should include a brief statement on the justification for this decision. These would typically be sewer pipe or forcemain replacement projects that do not include work not related to the wastewater treatment process, which typically must be addressed to facilitate water reuse. However, sewer extension projects may be candidates for possible water reuse projects, especially extensions to new industrial park growth areas where water reuse may be a possible industrial plant water source or where landscape watering or irrigation may be considered.

- ii. Water efficient devices. This is an option that may reduce overall water use within a project service area, and thereby reduce the wastewater flow volume that must be treated. This water conservation opportunity should be considered for both collection system and wastewater treatment projects as installing water efficient devices in residential homes, commercial businesses or industries can have the potential positive impact of reducing flows in the sewer pipes and reducing flows needed to be treated at the wastewater treatment facility.
- iii. Use of or replacement of water meters. Similar to using water efficient devices, addressing water meters in the project service area may reduce overall water use within a project service area simply by raising the user's awareness of the volume and cost, and thereby reduce the wastewater flow that must be treated. This water conservation opportunity should be considered for both collection system and wastewater treatment projects as installing or replacing water meters at residential homes, commercial businesses, or industries can have the potential positive impact of reducing flows in the sewer pipes and reducing flows needed to be treated at the wastewater treatment facility. Costs related to installation or replacement of water meters may be fundable as a part of a CWRP construction loan.

- iv. Water audits and conservation plans. Water audits, particularly with large water system users in the distribution system may locate flows of water that become wastewater that may be mitigated or reduced that can have positive impacts on the wastewater collection system and the treatment facilities. Similarly, implementing a water conservation plan (this may tie in with a Water Reuse option, for example) may have a positive impact on the wastewater collection system and the treatment facilities. For ideas to consider with this option, an information resource available in Minnesota is through the University of Minnesota at MNTAP: <http://www.mntap.umn.edu/> and the specific water conservation webpage link is at: <http://www.mntap.umn.edu/POTW/water.html>.

D. B3 Sustainable Building (SB) 2030 Wastewater Treatment Plant Review

The B3 SB 2030 WWTP Review is an energy review process and set of minimum energy conservation measures (ECM) that should be considered for wastewater treatment plant designs using tools established under Minn. Stat. § 216B.241.

Learn more about B3 SB 2030 WWTP Review: <https://www.b3mn.org/>

An MPCA SB 2030 exemption form is available to determine if the B3 SB 2030 WWTP Review applies. All nonexempt wastewater treatment plants will need to participate in the SB 2030 WWTP Review.

V. Other Factors/Nonmonetary Analysis

(To be completed for all new wastewater treatment facilities with design average wet weather (AWW) flow of greater than 100,000 gallons per day and significant upgrades meaning work on three or more major treatment units for any wastewater treatment facilities with a design AWW flow of greater than 1 million gallons per day).

In addition to cost analysis factors, there are also nonmonetary or non-cost factors that may be considered during project facilities planning. These factors can most certainly change depending on the type of wastewater facilities project the owner is proposing. Some nonmonetary factors may also have monetary or costs associated with them. This portion of the project analysis should be limited to considering the nonmonetary discussion or consideration of those factors or items. Some of these factors are listed below and the project consulting engineer and owner have flexibility in determining if these or other items should be considered for an individual project.

A. National, regional, state, and local priorities

- i. The CWRP is available to assist sustainable and climate resilient infrastructure projects, for example safeguarding water infrastructure from risks of climate change and extreme weather events. The Facilities Plan should address the extent to which sustainability and climate resilience have been considered. For information on these subjects, EPA has information on their webpage at:
<https://www.epa.gov/sustainability/learn-about-sustainability#what>
<https://www.epa.gov/sustainable-water-infrastructure/effective-utility-management-practices>
<https://www.epa.gov/crwu/build-climate-resilience-your-utility>
- ii. The Facilities Plan should address the water quality objectives of the project. For collection system projects, this may be insuring that the sewer system is capable of transporting all the wastewater in the service area to the treatment plant for final treatment that meets the effluent limits in the owners permit, or maybe addressing past bypass issues during wet weather events as examples. For treatment facilities, it may be how the project is addressing current or new effluent limits.
- iii. Consolidation/regionalization. Are there opportunities to consider collaborating in a consolidation or regionalization project for treatment facilities with other nearby communities or housing areas? In some cases, this alternative may involve nonmonetary considerations, such as benefiting the local technical

and managerial capacity to operate the system, obtaining more favorable discharge locations or facilitating a water reuse option. If the owner already is a “regional” facility, this should be identified in the Facilities Plan.

B. Technical factors

- i. The project location and project physical aspects may raise some nonmonetary considerations. Examples could include minimizing impacts on residents of the community or reducing the amount of land needed for the wastewater treatment facility site.
- ii. Project reliability may raise some nonmonetary considerations for a project alternative. This may be particularly true for small communities. In Minnesota, an example of this would be that a large number of small communities use stabilization pond systems for their treatment technology because that type of treatment process has been shown to be very reliable. The treatment alternatives considered for a particular location should consider this issue. This should not be confused with MPCA treatment plant component reliability requirements.
- iii. Project feasibility and operability may also raise some nonmonetary issues to consider when analyzing alternatives. For example, can the project owner reasonably expect to find qualified candidates for operations and maintenance staff in the local area or reasonably expect to contract for operation and maintenance services for the planned project? Is it a specialized technology that may take more operator time and take time away from other expected job responsibilities? Is the technology flexible and adaptable to future conditions, like changes in influent wastewater quality or quantity from a new or expanded industrial user?

C. Environmental factors

- i. The potential opportunity for a project to implement or enhance possible water conservation practices, water reuse, and/ or water recapture may have nonmonetary related consideration or aspects for a project alternative. Discuss this in the Facilities Plan as appropriate for a project.
- ii. Potential implementation of energy conservation practices, including the use of alternative energy sources may have nonmonetary related issues to consider for a project. Discuss this in the Facilities Plan as appropriate for the project.
- iii. Opportunities to recover and recycle or reuse other resources may have non-cost related considerations to identify for a project alternative. Good examples of this may include nutrient recapture from the wastewater stream for possible reuse. The most common practice is land applying biosolids in cooperation with landowners to use the nitrogen and phosphorus in crop uptake to assist with growing agricultural crops. More recent practices include struvite (phosphorus) harvesting or nitrogen harvesting for fertilizers have been put in to practice in some parts of the United States. Discuss this in the Facilities Plan as appropriate for the project.
- iv. The use of green infrastructure components within a project proposal may have nonmonetary considerations. Discuss this in the Facilities Plan as appropriate for the project.
- v. There may be other environmental impacts of a project that may have nonmonetary considerations. Examples may be land use impacts, impact to wildlife and/or habitat, impacts to wetlands or other critical water bodies, or impacts on air/water quality. Discuss this in the Facilities Plan as appropriate for the project.

D. Socioeconomic factors

- i. There may be nonmonetary related considerations for certain industries using or served by public infrastructure by the type of project. Discuss this in the Facilities Plan as appropriate for a project.
- ii. Nonmonetary considerations may be a part of local trend or demographics affecting the need or demand for a project. Discuss this in the Facilities Plan as appropriate for a project.

- iii. Environmental justice issues may have nonmonetary related issues or considerations for a project. Discuss this in the Facilities Plan as appropriate for a project.
- iv. Project acceptability or affordability may have nonmonetary types of considerations for a project. Discuss this in the Facilities Plan as appropriate for a project.

VI. Integrating Cost and Effectiveness Analysis

(To be completed for all new wastewater treatment facilities with design AWW flow of greater than 100,000 gallons per day and significant upgrades meaning work on three or more major treatment units for any wastewater treatment facilities with a design AWW flow of greater than 1 million gallons per day).

This is the recommended method or series of steps to integrate the Cost and Effectiveness Analysis into projects including the Cost Analysis and Other Factors/Nonmonetary Analysis portions of the review of alternatives.

- A. Display a summary table of the results of the present worth cost analysis of each of the alternatives studied during the Facilities Plan process that are capable of meeting the needs identified.
- B. Describe narratively or summarize in a table the Other Factors/Nonmonetary Analysis for each alternative studied.
- C. Assign a numeric weighting factor to both the Present Worth Cost Analysis and the Other Factors/Nonmonetary Analysis for each of the project alternatives.
- D. Summarize the weighting factors of both the Present Worth Cost Analysis and the Other Factors/Nonmonetary Analysis in one single table and identify how the weighting factors will be used to assist in making a decision on selecting a project alternative.
- E. Choose a selected project alternative. The Facilities Plan narrative should describe how both the Present Worth Cost Analysis and the Other Factors Analysis each shaped the reasoning behind selecting the implementation of this alternative. It is very important to note that Minn. R. 7077.0272 subp. 2.F. does not require selecting the lowest cost alternative for the project. The project owner is given latitude to select a project alternative that meets their identified needs and addresses the analysis of each of factors identified in this guidance document as appropriate for the individual project.

A reference to consider when integrating a Cost and Effectiveness Analysis is available from the Natural Resource Defense Council at: https://www.nrdc.org/sites/default/files/wat_16012504a.pdf.

References:

ⁱ EPA, Interpretive Guidance for Certain Amendments in the Water Resources Reform and Development Act to Titles I, II, V, and VI of the Federal Water Pollution Control Act, January 6, 2015, https://www.epa.gov/sites/production/files/2015-04/documents/water_resources_reform_and_development_act_guidance.pdf

ⁱⁱ MPCA Cost and Effectiveness Certification Form: <https://www.pca.state.mn.us/sites/default/files/wq-wwtp2-46.doc>

ⁱⁱⁱ EPA, Supplemental Information of Implementing Section 602(b)(13), April 17, 2015

^{iv} Preparing Wastewater Planning Documents and Environmental Reports for Public Utilities Financed by Oregon Infrastructure Finance Authority, Oregon Department of Environmental Quality, Rural Community Assistance Corporation, United States Department of Agriculture, May 21 and 22, 2013, <http://www.deq.state.or.us/wq/loans/docs/FacilitiesPlansGuidelines.pdf>

^v Water Environment Federation, Energy Conservation in Water and Wastewater Facilities, Manual of Practice No. 32, 2009

Environmental Information Worksheet (EIW) form

Clean Water State Revolving Fund Program

Minnesota Rule Chapter 7077.0272, subp. 2.a.F.
Minnesota Rule Chapter 7077.0277, subp. 3.E.

Doc Type: Wastewater Point Source

Eligible applicants seeking funds for clean water (stormwater and wastewater) projects through the Clean Water State Revolving Fund (commonly referred to as the CWSRF Program) are required by Minn. R. ch. 7077.0272, subp. 2.a.F. and Minn. R. ch. 7077.0277, subp. 3.E., to complete an Environmental Information Worksheet (EIW). This information will be used to assess environmental impacts, if any, caused by the project.

Questions: Contact Review Engineer or Bill Dunn at 651-757-2324 or bill.dunn@state.mn.us.

1. **Project title:** _____

2. **Proposer:** _____

Contact person: _____

Title: _____

Address: _____

Phone: _____

Fax: _____

3. **Project location:** County: _____ City/Twp: _____
_____ 1/4 _____ 1/4 Section: _____ Township: _____ Range: _____

Tables, Figures, and Appendices attached to the EIW:

- County map showing the general location of the project;
- United States Geological Survey 7.5 minute, 1:24,000 scale map indicating project boundaries (photocopy acceptable);
- Site plan showing all significant project and natural features.

4. **Description:**

a. Provide a project summary of 50 words or less.

b. Give a complete description of the proposed project and related new construction. Attach additional sheets as necessary. Emphasize construction, operation methods and features that will cause physical manipulation of the environment or will produce wastes. Include modifications to existing equipment or industrial processes and significant demolition, removal or remodeling of existing structures. Indicate the timing and duration of construction activities.

- c. Explain the project purpose; if the project will be carried out by a governmental unit, explain the need for the project and identify its beneficiaries.

- d. Are future stages of this development including development on any outlots planned or likely to happen? Yes No
If yes, briefly describe future stages, relationship to present project, timeline and plans for environmental review.

- e. Is this project a subsequent stage of an earlier project? Yes No
If yes, briefly describe the past development, timeline and any past environmental review.

5. Project magnitude data

Total Project Area (acres) _____ or Length (miles) _____
 Number of Residential Units: Unattached _____ Attached _____ maximum units per building _____
 Commercial/Industrial/Institutional Building Area (gross floor space): total square feet _____
 Indicate area of specific uses (in square feet): _____

Office _____	Manufacturing _____
Retail _____	Other Industrial _____
Warehouse _____	Institutional _____
Light Industrial _____	Agricultural _____
Other Commercial (specify) _____	

Building height _____ If over 2 stories, compare to heights of nearby buildings _____

- 6. **Permits and approvals required.** List all known local, state and federal permits, approvals and financial assistance for the project. Include modifications of any existing permits, governmental review of plans, and all direct and indirect forms of public financial assistance including bond guarantees, Tax Increment Financing and infrastructure.

Unit of government	Type of application	Status

- 7. **Land use.** Describe current and recent past land use and development on the site and on adjacent lands. Discuss project compatibility with adjacent and nearby land uses. Indicate whether any potential conflicts involve environmental matters. Identify any potential environmental hazards due to past site uses, such as soil contamination or abandoned storage tanks, or proximity to nearby hazardous liquid or gas pipelines.

- 8. **Cover types.** Estimate the acreage of the site with each of the following cover types before and after development:

	Before	After		Before	After
Types 1-8 wetlands	_____	_____	Lawn/landscaping	_____	_____
Wooded/forest	_____	_____	Impervious Surfaces	_____	_____
Brush/grassland	_____	_____	Other (describe)	_____	_____
Cropland	_____	_____			
			Total	_____	_____

9. Fish, wildlife, and ecologically sensitive resources.

- a. Identify fish and wildlife resources and habitats on or near the site and describe how they would be affected by the project. Describe any measures to be taken to minimize or avoid impacts.
- b. Are any state (endangered or threatened) species, rare plant communities or other sensitive ecological resources such as native prairie habitat, colonial waterbird nesting colonies or regionally rare plant communities on or near the site? Yes No
If yes, describe the resource and how it would be affected by the project. Indicate if a site survey of the resources has been conducted and describe the results. If the Minnesota Department of Natural Resources (DNR) Natural Heritage and Nongame Research program has been contacted give the correspondence reference number: _____
Describe measures to minimize or avoid adverse impacts.

- 10. Physical impacts on water resources.** Will the project involve the physical or hydrologic alteration (dredging, filling, stream diversion, outfall structure, diking, and impoundment) of any surface waters such as a lake, pond, wetland, stream or drainage ditch? Yes No
If yes, identify water resource affected. Describe alternatives considered and proposed mitigation measures to minimize impacts. Give the DNR Protected Waters Inventory (PWI) number(s) if the water resources affected are on the PWI.

- 11. Water use.** Will the project involve installation or abandonment of any water wells, connection to or changes in any public water supply or appropriation of any ground or surface water (including dewatering)? Yes No
If yes, as applicable, give location and purpose of any new wells; public supply affected, changes to be made, and water quantities to be used; the source, duration, quantity and purpose of any appropriations; and unique well numbers and DNR appropriation permit numbers, if known. Identify any existing and new wells on the site map. If there are no wells known on site, explain methodology used to determine.

- 12. Water-related land use management districts.** Does any part of the project involve a shoreland zoning district, a delineated 100-year flood plain, or a state or federally designated wild or scenic river land use district? Yes No
If yes, identify the district and discuss project compatibility with district land use restrictions.

- 13. Water surface use.** Will the project change the number or type of watercraft on any water body? Yes No
If yes, indicate the current and projected watercraft usage and discuss any potential overcrowding or conflicts with other uses.

- 14. Erosion and sedimentation.** Give the acreage to be graded or excavated and the cubic yards of soil to be moved: _____ Acres: _____ cubic yards. Describe any steep slopes or highly erodible soils and identify them on the site map. Describe any erosion and sedimentation control measures to be used during and after project construction.

15. Water quality – surface-water runoff.

- a. Compare the quantity and quality of site runoff before and after the project. Describe permanent controls to manage or treat runoff. Describe any storm water pollution prevention plans.

19. **Traffic.** Parking spaces added: _____ Existing spaces (if project involves expansion): _____
 Estimated total average daily traffic generated: _____ Estimated maximum peak hour traffic
 generated (if known) and its timing: _____ Provide an estimate of the impact on traffic
 congestion affected roads and describe any traffic improvements necessary. If the project is within the Twin Cities metropolitan
 area, discuss its impact on the regional transportation system.
20. **Vehicle-related air emissions.** Estimate the effect of the project's traffic generation on air quality, including carbon monoxide
 levels. Discuss the effect of traffic improvements or other mitigation measures on air quality impacts. Note: If the project involves
 500 or more parking spaces, consult *Environmental Assessment Worksheet (EAW) Guidelines* about whether a detailed air
 quality analysis is needed.
21. **Stationary source air emissions.** Describe the type, sources, quantities and compositions of any emissions from stationary
 sources of air emissions such as boilers, exhaust stacks or fugitive dust sources. Include any hazardous air pollutants (consult
EAW Guidelines for a listing), any greenhouse gases (such as carbon dioxide, methane, and nitrous oxides), and ozone-
 depleting chemicals (chlorofluorocarbons, hydrofluorocarbons, perfluorocarbons or sulfur hexafluoride). Also describe any
 proposed pollution prevention techniques and proposed air pollution control devices. Describe the impacts on air quality.
22. **Odors, noise, and dust.** Will the project generate odors, noise or dust during construction or during operation? Yes No
 If yes, describe sources, characteristics, duration, quantities or intensity and any proposed measures to mitigate adverse
 impacts. Also identify locations of nearby sensitive receptors and estimate impacts on them. Discuss potential impacts on human
 health or quality of life. (Note: fugitive dust generated by operations may be discussed at item 23 instead of here.)
- 23a. **Nearby resources.** Are any of the following resources on or in proximity to the site? Projects should search the Minnesota State
 Historic Preservation Office's (SHPO) National Register of Historic Places database.
 *Note: Project proposers must contact the SHPO at datarequestshpo@mnhs.org to request a database review to obtain
 information on any known historical or archaeological sites in the project area.
 Include a copy of correspondence with SHPO with the submittal of this EIW form.
- Archaeological, historical, or architectural resources? Yes No
 - Prime or unique farmlands or land within an agricultural preserve? Yes No
 - Designated parks, recreation areas, or trails? Yes No
 - Scenic views and vistas? Yes No
 - Other unique resources? Yes No
- If yes, describe the resource and identify any project-related impacts on the resources. Describe any measures to minimize or
 avoid adverse impacts.
- 23b. **Section 106 Review** (36 CFR 800) is required for all CWRP projects. The following forms can be found on the MPCA
 Wastewater and Stormwater Financial Assistance website at <https://www.pca.state.mn.us/ppf>. Select Clean Water Revolving
 Fund tab; then scroll to Facilities Plan and Facilities Plan Supplement for Wastewater Treatment Systems heading.
- Project is exempt from review (attach completed *Exemption Checklist*) Yes No
 - Project is required to complete further Section 106 Review: Yes No
 - SHPO
 - Tribal consultation
 - Other Consulting parties
24. **Visual impacts.** Will the project create adverse visual impacts during construction or operation? Such as glare from intense
 lights, lights visible in wilderness areas and large visible plumes from cooling towers or exhaust stacks? Yes No
 If yes, explain.

- 25. Compatibility with plans and land use regulations.** Is the project subject to an adopted local comprehensive plan, land use plan or regulation, or other applicable land use, water, or resource management plan of a local, regional, state or federal agency? Yes No

If yes, describe the plan, discuss its compatibility with the project and explain how any conflicts will be resolved. If no, explain.

- 26. Impact on infrastructure and public services.** Will new or expanded utilities, roads, other infrastructure or public services be required to serve the project? Yes No

If yes, describe the new or additional infrastructure or services needed. (Note: any infrastructure that is a connected action with respect to the project must be assessed in the EAW; see *EAW Guidelines* for details.)

- 27. Cumulative impacts.** Minn. R. 4410.1700, subp. 7, item B requires that the RGU consider the “cumulative potential effects of related or anticipated future projects” when determining the need for an environmental impact statement. Identify any past, present or reasonably foreseeable future projects that may interact with the project described in this EAW in such a way as to cause cumulative impacts. Describe the nature of the cumulative impacts and summarize any other available information relevant to determining whether there is potential for significant environmental effects due to cumulative impacts (or discuss each cumulative impact under appropriate item(s) elsewhere on this form).

- 28. Other potential environmental impacts.** If the project may cause any adverse environmental impacts not addressed by items 1 to 28, identify and discuss them here, along with any proposed mitigation.

- 29. Summary of issues.** List any impacts and issues identified above that may require further investigation before the project is begun. Discuss any alternatives or mitigative measures that have been or may be considered for these impacts and issues, including those that have been or may be ordered as permit conditions.

Section 13

Limitations

This document was prepared solely for City of Rochester in accordance with professional standards at the time the services were performed and in accordance with the contract between City of Rochester and Brown and Caldwell dated May 17, 2017. This document is governed by the specific scope of work authorized by City of Rochester; it is not intended to be relied upon by any other party except for regulatory authorities contemplated by the scope of work. We have relied on information or instructions provided by City of Rochester and other parties and, unless otherwise expressly indicated, have made no independent investigation as to the validity, completeness, or accuracy of such information.

This document sets forth the results of certain services performed by Brown and Caldwell with respect to the property or facilities described therein (the Property). [Client] recognizes and acknowledges that these services were designed and performed within various limitations, including budget and time constraints. These services were not designed or intended to determine the existence and nature of all possible environmental risks (which term shall include the presence or suspected or potential presence of any hazardous waste or hazardous substance, as defined under any applicable law or regulation, or any other actual or potential environmental problems or liabilities) affecting the Property. The nature of environmental risks is such that no amount of additional inspection and testing could determine as a matter of certainty that all environmental risks affecting the Property had been identified. Accordingly, THIS DOCUMENT DOES NOT PURPORT TO DESCRIBE ALL ENVIRONMENTAL RISKS AFFECTING THE PROPERTY, NOR WILL ANY ADDITIONAL TESTING OR INSPECTION RECOMMENDED OR OTHERWISE REFERRED TO IN THIS DOCUMENT NECESSARILY IDENTIFY ALL ENVIRONMENTAL RISKS AFFECTING THE PROPERTY.

Further, Brown and Caldwell makes no warranties, express or implied, with respect to this document, except for those, if any, contained in the agreement pursuant to which the document was prepared.

All data, drawings, documents, or information contained this report have been prepared exclusively for the person or entity to whom it was addressed and may not be relied upon by any other person or entity without the prior written consent of Brown and Caldwell unless otherwise provided by the Agreement pursuant to which these services were provided.

References

Chow, V. T., Open-Channel Hydraulics, McGraw-Hill, 1959, page 72.

City of Rochester, MN, Sustainability, <https://www.rochestermn.gov/departments/community-development/sustainability>.

Appendices

Appendix 1	Technical Memorandum 1 Influent Flows and Loadings
Appendix 2	Technical Memorandum 2 Wastewater Characterization and BioWin™ Calibration
Appendix 3	Technical Memorandum 3 Plant Hydraulic Evaluation
Appendix 4	Technical Memorandum 4 Primary Clarifier Computational Fluid Dynamics Modeling
Appendix 5	Technical Memorandum 5 Final Clarifier Computational Fluid Dynamics Modeling
Appendix 6	Technical Memorandum 6 Liquid Stream Alternative Evaluation
Appendix 7	Technical Memorandum 7 Solids Alternative Evaluation
Appendix 8	Technical Memorandum 8 Digester Gas Management
Appendix 9	Technical Memorandum 9 Disinfection and Outfall Evaluation
Appendix 10	Technical Memorandum 10 Whole Plant Evaluation
Appendix 11	Technical Memorandum 11 Heat Recovery Loop Alternative
Appendix 12	Technical Memorandum 12 NPDES Permitting Process
Appendix 13	Technical Memorandum 13 Industrial Discharge Wasteloads and Practices



LOWER ENERGY // CLEAN DESIGN
DECREASED MAINTENANCE // INNOVATIVE PROCESSES



Technical Memorandum 1	Influent Flows and Loadings
Technical Memorandum 2	Wastewater Characterization and BioWin Calibration
Technical Memorandum 3	Plant Hydraulic Evaluation
Technical Memorandum 4	Primary Clarifier Computational Fluid Dynamics Modeling
Technical Memorandum 5	Final Clarifier Computational Fluid Dynamics Modeling
Technical Memorandum 6	Liquid Stream Alternative Evaluation
Technical Memorandum 7	Solids Alternative Evaluation
Technical Memorandum 8	Digester Gas Management
Technical Memorandum 9	Disinfection and Outfall Evaluation
Technical Memorandum 10	Whole Plant Evaluation
Technical Memorandum 11	Heat Recovery Loop Alternative
Technical Memorandum 12	NPDES Permitting Process
Technical Memorandum 13	Industrial Discharge Wasteloads and Practices