

# Rochester Water Reclamation Plant 2019 Facilities Plan


## Technical Memorandum 11: Heat Recovery Loop Alternative



TM 11 of 13 | J4325



LOWER ENERGY // CLEAN DESIGN  
DECREASED MAINTENANCE // INNOVATIVE PROCESSES





# Technical Memorandum

30 East 7th Street, Suite 2500  
Saint Paul, MN 55101

T: 651.298.0710

Prepared for: City of Rochester

Project title: Water Reclamation Plant Facilities Plan

Project No.: 150811

City No.: J4325


## Technical Memorandum No. 11

Subject: Heat Recovery Loop Alternative Evaluations

Date: November 12, 2019

To: Matt Baker, P.E. Project Manager

From: Harold Voth, P.E. Project Manager

Prepared by:   
Nancy Andrews, P.E.

Reviewed by:   
Kenny Klittich, P.E.

I hereby certify that this plan, specification, or report was prepared by me or under my direct supervision and that I am a duly Licensed Professional Engineer under the laws of the State of Minnesota.

Signature: 

Name: Nancy Andrews

Date: November 12, 2019 License No. 21791

### Limitations:

*This document was prepared solely for City of Rochester in accordance with professional standards at the time the services were performed and in accordance with the contract between City of Rochester and Brown and Caldwell dated May 17, 2017. This document is governed by the specific scope of work authorized by City of Rochester; it is not intended to be relied upon by any other party except for regulatory authorities contemplated by the scope of work. We have relied on information or instructions provided by City of Rochester and other parties and, unless otherwise expressly indicated, have made no independent investigation as to the validity, completeness, or accuracy of such information.*

## Table of Contents

---

Executive Summary .....	ES-1
Section 1: Introduction.....	1
1.1 Heat Recovery: Low and Medium Temperature Loop.....	1
1.2 Water Reuse: Spray Water System .....	3
1.3 Heat Recovery: ABC Low Temperature Loop .....	4
1.4 Heat Recovery: Primary Clarifier 3 Heating .....	6
1.5 Water Reuse: Gravity Belt Thickener Washwater.....	7
Section 2: Heat Sources .....	8
2.1 Anticipated Process Equipment Heat Sources.....	8
2.2 Blower Air Heat Recovery.....	8
2.3 Effluent Heat Recovery .....	10
2.4 Boiler Exhaust Heat Recovery .....	10
2.5 Solar Thermal .....	10
Section 3: Heat Recovery Loop Alternatives.....	13
3.1 Cooling Sources.....	13
3.1.1 Maintain Pumped Water Source for Cooling.....	13
3.1.2 Submerged Heat Exchange.....	16
3.1.3 Dry Cooler.....	18
3.2 Net Present Value Evaluation.....	21
3.2.1 Estimating Assumptions.....	21
3.2.2 Operating Cost Comparison .....	22
3.2.3 Net Present Value.....	23
3.2.4 Alignment with WRP Goals.....	24
3.3 Merge Low Temperature Water Loops.....	25
3.4 Low Temperature Loop Economic Viability .....	25
Section 4: Reuse Water Alternatives.....	27
4.1 Water Reuse Pumping Alternatives.....	27
4.1.1 Separate Spray and GBT Water Systems.....	27
4.1.2 Merged Spray Water and GBT Wash Water – Chlorine Contact Basin.....	28
4.1.3 Merged Water Systems with GBT Booster Pump.....	29
4.2 Net Present Value Evaluation .....	29
4.2.1 Operating Cost Comparison .....	29
4.2.2 Net Present Value.....	30
4.2.3 Alignment with WRP Goals.....	30
4.3 Primary Clarifier 3 Heat Source .....	31
4.3.1 Route Headworks Spray Water Through Existing Heat Exchanger.....	31
4.3.2 Replace Heat Exchanger with Effluent Water Cooling Loop .....	32

4.3.3 Net Present Value .....	32
4.4 Strainer Upgrades .....	33
Section 5: Recommendations .....	34
Section 6: References .....	37
Attachment A: Blower Heat Recovery Coil Drawing and Quote .....	A-1
Attachment B: Sand Filter Drawing and Quote .....	B-1
Attachment C: Submerged Heat Exchanger .....	C-1
Attachment D: Air Cooled Radiator .....	D-1
Attachment E: Cost Estimating .....	E-1
Attachment F: Heat Exchanger Quotation .....	F-1

## List of Figures

---

Figure 1-1. LT and MT water loops schematic .....	2
Figure 1-2. LT water loops following HPO decommissioning .....	2
Figure 1-3. ABC low temperature loop schematic .....	5
Figure 2-1. 1.5 MW thermal hot water solar system on roof of St. Paul RiverCentre .....	11
Figure 2-2. Direct normal solar incidence .....	11
Figure 3-1. Proposed CCT intake for heat recovery loops .....	14
Figure 3-2. New heat recovery intake vault and piping .....	15
Figure 3-3. Example sand filter configuration .....	16
Figure 3-4. Example submerged heat exchanger configuration .....	17
Figure 3-5. Example submerged heat exchanger schematic .....	18
Figure 3-6. Preliminary dry cooler location .....	20
Figure 3-7. Potential dry cooler addition to ABC low temperature cooling loop configuration .....	21
Figure 4-1. Separate spray water and GBT washwater pumping systems .....	28
Figure 4-2. Cross-connection piping to merge spray water and GBT washwater systems .....	29
Figure 4-3. Piping to route effluent water from PC3 HVAC back to spray water .....	31
Figure 4-4. Spray water routed through PC3 HX .....	32
Figure 5-1. Proposed heat recovery and water reuse system .....	35

## List of Tables

---

Table 1-1. Low and Medium Temperature Heat Recovery Facility Characteristics.....	3
Table 1-2. Spray Water Usage .....	4
Table 1-3. ABC Low Temperature Loop Heat Recovery Facility Characteristics.....	5
Table 1-4. Primary Clarifier 3 Winter Operating Conditions.....	6
Table 1-5. GBT Washwater Facility Characteristics.....	7
Table 2-1. Summary of Process Equipment Heat Sources.....	8
Table 2-2. Blower Heat Recovery Estimated Winter Conditions.....	9
Table 2-3. Approximate Blower Heat Recovery Savings .....	9
Table 2-4. Approximate 250 SF Solar Thermal System Costs and Savings .....	12
Table 3-1. Approximate Future Heat Recovery System Pumping Conditions .....	13
Table 3-2. Filtration Alternatives Comparison .....	16
Table 3-3. Summary of Submerged Heat Exchanger Design Conditions.....	18
Table 3-4. Digester Gas Pre-Cooling Heat Exchanger Operating Conditions.....	19
Table 3-5. Project Cost Assumptions .....	22
Table 3-6. Annual Operating Cost and Net Present Value Assumptions .....	22
Table 3-7. Cooling and Heat Recovery Annual Operating Costs.....	23
Table 3-8. Cooling and Heat Recovery Capital Costs and Net Present Value .....	24
Table 3-9. Cooling and Heat Recovery Comparison.....	24
Table 3-10. Headworks Low Temperature Loop Operating Assumptions .....	25
Table 3-11. Headworks Low Temperature Loop Net Cost Evaluation .....	26
Table 4-1. Reuse Water Design Conditions .....	27
Table 4-2. Cooling and Heat Recovery Annual Operating Costs.....	30
Table 4-3. Water Reuse Capital Costs and Net Present Value.....	30
Table 4-4. Water Reuse Alternative Comparison .....	31
Table 4-5. PC3 Heat Source Capital Cost and NPV Comparison.....	33
Table 5-1. Immediate Capital Improvements Opinion of Probable Costs <sup>a</sup> .....	34
Table 5-2. Heat Recovery System Summary.....	35
Table 5-3. Preliminary Heat Exchanger Design Conditions .....	36

## List of Abbreviations

---

°C	degree(s) Celsius	NG	natural gas
°F	degree(s) Fahrenheit	NPV	net present value
µm	microns	O&M	Operation and Maintenance
AACEI	Association for the Advancement of Cost Engineering International	PC3	Primary Clarifier 3
ABC	Aeration Basin Complex	PD	positive displacement
A/O	anaerobic/oxic	psi	pound(s) per square inch
Btu	British thermal unit(s)	PW	peak week
BC	Brown and Caldwell	s	second(s)
CCT	chlorine contact tank	SCADA	supervisory control and data acquisition
cfm	cubic foot/feet per minute	SCFM	standard cubic feet per minute
City	City of Rochester	TM	technical memorandum
d	day(s)	VFD	variable frequency drive
DG	digester gas	VS	volatile solids
FC	final clarifier	WRP	water reclamation plant
fps	foot/feet per second		
ft	foot/feet		
ft <sup>2</sup>	square foot/feet		
GBT	gravity belt thickener		
gpm	gallon(s) per minute		
hp	horsepower		
HPO	high-purity oxygen		
hr	hour(s)		
HSW	high-strength waste		
HX	heat exchanger		
kWh	kilowatt-hour(s)		
L	liter(s)		
lb	pound(s)		
LF	Linear foot/feet		
LT	low temperature		
m	meter(s)		
MAC	oxygen system air compressor		
MD	maximum day		
mg	milligram(s)		
mgd	million gallons per day		
MM	maximum month		
MT	medium temperature		

## Executive Summary

The water reclamation plant (WRP) heat recovery system uses pumped effluent from the final clarifiers and heat exchangers to transfer heat to and from final effluent. During winter conditions the WRP heat recovery system reduces heat demands by capturing equipment and effluent heat. During summer conditions the system cools process equipment. This system has provided an energy benefit, but changes are required to address the following issues:

- Numerous pumps are required to circulate effluent and loop water flow.
- Particles from the final clarifier are drawn into the low temperature loop pump systems and foul the heat exchangers, requiring frequent cleaning.
- The spray water system serving the effluent loop operate at 80 psi (as needed for headworks equipment). The pump is oversized, and excess flow is relieved to Primary Clarifier (PC) 3 heating, grit washer, and the final clarifier (wasting pumping energy).
- Spray water system pumps and adjacent flush water pumps cavitate under current operating conditions, apparently due to restrictions in the intake piping.
- Conversion from high-pressure oxygen (HPO) to anaerobic/oxic (A/O) operation will remove the oxygen system compressors (MACs)—a significant heat source—from the low temperature loop.

To address these issues, the following proposed near-term improvements are proposed:

- **New effluent intake vault on final clarifier effluent.** In lieu of the effluent suction systems withdrawing flow from the final clarifiers, a new intake vault would be installed. This system would be less prone to fouling due to the cleaner water supply and would eliminate the adverse impact on clarifier performance.
- **Separate spray water from heat recovery system.** This separation allows optimization of each system for its intended purpose to minimize cavitation and simplify controls.
- **Combined Low Temperature, ABC Low Temperature, and Primary Clarifier (PC) 3 Loops.** The low temperature, ABC low temperature, and PC3 loops can be cross-connected to minimize the number of loop circulating pumps required and to use wastewater to heat and cool using a single heat exchanger system. It is recommended that the staging of this change be considered in conjunction with the change to A/O to ensure that all connected loads will be adequately served by the combined loops.
- **Improved straining system.** Automated strainers are available with suction cleaning that could improve performance and reduce downstream maintenance from fouling.

Water reuse pumping alternatives were considered to reduce energy and maintenance in the spray water and gravity belt thickener (GBT) washwater systems. Optimization of the existing spray water system to minimize flow has a lower net present value than other alternatives that merged the two reuse systems.

## Section 1: Introduction

The water reclamation plant (WRP) currently operates three heat recover loops serving different areas of the plant:

- Low Temperature (LT) Loop – High-purity oxygen (HPO) system, air compressors, digester gas cooling
- Medium Temperature (MT) Loop – Oxygen Compressor Intercooler
- ABC Low Temperature Loop– Aeration Basin Complex (ABC) and headworks
- Primary Clarifier (PC) 3 – Heat recovery and heat pump for make-up air heating

In the winter, these systems recover heat from wastewater and process equipment and use the heat in air handling unit preheating coils, reducing the energy required for boiler operation. In the summer, the equipment heat is rejected to the plant effluent via heat exchange with water from the final clarifiers.

In tandem with the thermal reuse systems, the WRP operates two major effluent reuse systems:

- Spray Water – Headworks and chemical feed water uses (this flow is also the thermal source for ABC low temperature loop and PC3 heat exchangers listed above)
- GBT Washwater – Belt washing

The following sections describe these systems and their current maintenance concerns.


### 1.1 Heat Recovery: Low and Medium Temperature Loop

The general arrangement of the LT and MT temperature loops is shown in Figure 1-1. The LT loop uses wastewater withdrawn from FC1 and FC2 to reject excess process equipment heat that is not recovered for space heating. The wastewater passes through a coarse automatic strainer to one of three pumps. Typically, one pump operates for wastewater heat exchange but two operate if heat demand requires it. The third withdrawal pump serves as a backup. Table 1-1 summarizes the major mechanical components of the low and medium temperature systems.

Because the winter temperature of the LT loop is roughly similar to or higher than the effluent water temperature, most of the heat is recovered from process components, and very little heat appears to be recovered from the effluent. Heat recovery in the LT HVAC systems is currently limited by HVAC equipment and control system components that are not functioning as intended. Estimated process component heat quantities are summarized in Section 2.1.


Final effluent entering the LT heat exchanger is drawn from perforated piping within the clarifier. This wastewater contains entrained solids and organic material that enter the heat exchangers and promote biofouling in the plate and frame units. As the heat exchangers foul, the flow through the system decreases. Heat exchanger fouling decreases the summer heat dissipating capacity of the system and increases pumping energy by creating excess pumping head. Every 6 weeks to 3 months, the fouled LT heat exchanger is taken out of service and cleaned with circulating citric acid to restore capacity.





**Figure 1-1. LT and MT water loops schematic**

The anticipated shift from HPO to anaerobic/oxic (A/O) operations will remove the oxygen turboexpander, aftercooler, and compressor intercooler from this system. Likewise, the MT loop will be eliminated when the HPO units are removed. Two or three new blowers with oil cooling will be installed with the A/O conversion, and the oil-cooling system for these blowers can be connected to the LT loop. Figure 1-2 depicts a possible simplified configuration of the LT cooling loop configuration under these future conditions.



**Figure 1-2. LT water loops following HPO decommissioning**

Table 1-1. Low and Medium Temperature Heat Recovery Facility Characteristics		
Item	Units	Value
LT (main) effluent pumps		
Number	--	3
Flow per unit <sup>a</sup>	gpm	500
Discharge pressure <sup>a</sup>	psi	20
Motor size	hp	15
LT loop (main) pumps		
Number	--	3
Flow per unit <sup>a</sup>	gpm	500
Differential pressure <sup>a</sup>	psi	36
Motor size	hp	30
MT loop pumps		
Number	--	2
Flow per unit <sup>a</sup>	gpm	165
Motor size	hp	15

<sup>a</sup>. Data from SCADA screenshots provided by the WRP

## 1.2 Water Reuse: Spray Water System

The spray water pumping system currently serves:

- Heat exchangers serving the ABC low temperature water loop (see Figure 1-3)
- Spray water usage, primarily in the headworks area
- PC3's make-up air heating

Water is withdrawn from FC3 and FC4. To improve water quality, chlorine solution can be added to the system and a motorized strainer is located downstream of the pumping system. Non-potable water can supplement the spray water system if needed for peak flow conditions.

Table 1-2 summarizes the spray water usage locations. The headworks wash water requires 80 pounds per square inch (psi) pressure to provide adequate head for the equipment on the upper floors of the headworks building. The effluent pump speed is modulated to maintain an 80 to 85 psi pressure set point on the strainer outlet. Because the spray water demand is variable, flow is relieved to FC3 as needed to maintain pumping conditions. During summer months, approximately 50 to 75 percent of the 80-psi pumped flow is released through this outlet, wasting pumping energy.

<b>Table 1-2. Spray Water Usage</b>			
<b>Item</b>	<b>Continuous (gpm)</b>	<b>Peak (gpm)</b>	<b>Notes</b>
Screens and grit			
Screen compactor	27	81	Peak condition: 3 screens
Screen washer	14	42	Peak condition: 3 screens
Screen	30	90	Peak condition: 3 screens
Grit washer	42	42	Includes 20 gpm to west grit washer to keep drain clean
PC3 spray water	5	5	WRP estimate
FC5 spray water	--	5	Seasonal
FC1 through FC4 spray water	20	20	Future, 5 gpm per clarifier
Ferric chloride carrier water (PC, digester)	9	9	
PC scum pits	--	10	Engineer's estimate Runs when scum pump runs
PC3 HVAC		350	
<b>Total</b>	<b>150</b>	<b>660</b>	

Spray water is being considered for polymer make-up water in lieu of city water. A few issues may preclude this:

- Chloride concentrations of 200-300 ppm or higher can reduce polymer effectiveness (Polydyne, 2015). A recent effluent sample had a chloride concentration of 279 ppm (eDMR, April 2019).
- Water pH less than 6.5 can reduce polymer effectiveness. Plant effluent pH is approximately 6.5.
- Unchlorinated water could cause biofouling of the polymer blend unit.

Prior to converting polymer dilution to spray water, jar testing would be required to gauge the impact of these factors.

### 1.3 Heat Recovery: ABC Low Temperature Loop

The general arrangement of the LT and MT loops is shown in Figure 1-3. ABC low temperature loop serves the newer ABC and headworks portions of the plant. Because the ABC low temperature water loop temperature is 5 °F to 10 °F lower than the effluent, this system recovers more heat from the effluent under winter conditions than the low temperature loop. In addition to the heat recovery function, the effluent water in this system is used as a heat source for the heat pump serving PC3.

The following Operation and Maintenance (O&M) considerations were noted:

- The effluent water pumps are variable speed. The pumps modulate to maintain a pressure set point. Under current operating conditions, these pumps are prone to cavitation.
- During winter months, the high-temperature heat exchanger is used to maintain a minimum loop temperature and prevent freezing.
- The ABC low temperature loop heat exchanger only requires cleaning every two years.




Figure 1-3. ABC low temperature loop schematic

Table 1-3. ABC Low Temperature Loop Heat Recovery Facility Characteristics		
Item	Units	Value
<b>Effluent (spray water) pumps</b>		
Number	--	2
Flow per unit <sup>a</sup>	gpm	850
Discharge pressure <sup>a</sup>	psi	80-85
Design head <sup>b</sup>	ft	225
Motor size	hp	75
<b>ABC low temperature loop pumps</b>		
Number	--	2
Flow per unit <sup>a</sup>	gpm	450
Motor size	hp	40
<b>PC3 loop pump</b>		
Number	--	1
Flow per unit <sup>a</sup>	gpm	150
Motor size	hp	10
<b>PC3 heat pump (load) pump</b>		
Number	--	1

**Table 1-3. ABC Low Temperature Loop Heat Recovery Facility Characteristics**

Item	Units	Value
Flow per unit <sup>a</sup>	gpm	50
Motor size	hp	5

a. Data from SCADA screenshots provided by WRP

b. Flowserve shop drawings

## 1.4 Heat Recovery: Primary Clarifier 3 Heating

The PC3 heating system was added in 2011 to minimize fogging and improve personnel safety under the ABC primary clarifier dome. As depicted in Figure 1-3, the PC3 system uses effluent water (wasted from the spray water system) in two modes:

- Closed loop preheating of the make-up air
- Effluent-source heat pump

Table 1-4 summarizes the PC3 heat recovery operating conditions based on supervisory control and data acquisition (SCADA) screen information and other data furnished by WRP staff. The preheat system appears to provide roughly a third of the winter heating at current loop temperatures using heat recovered from the effluent water,

In Sections 3 and 4, possible modifications to the spray water will be presented to conserve pumping energy and reduce pumping equipment. Refer to Section 4.3 for PC3 heating modifications triggered by these proposed changes.

**Table 1-4. Primary Clarifier 3 Winter Operating Conditions**

Item	Units	Value
<b>Heat exchanger</b>		
Effluent flow (current/design minimum)	gpm	325/100
Loop flow rate	gpm	220
Typical winter heat extracted	Btu/hr	240,000
Typical winter inlet/outlet loop temperatures	°F	54/52.5
<b>Preheat coil</b>		
Airflow rate	cfm	10,500
Water flow rate	gpm	150
Typical winter heat output (20°F outside air)	Btu/hr	190,000
Typical winter inlet/outlet loop temperatures	°F	51/48.5
<b>Heat pump</b>		
Source water flow rate	gpm	70
Hot water flow rate	gpm	45
Typical winter heat output	Btu/hr	400,000
Typical winter inlet/outlet loop source water temperatures	°F	51/48.5
Minimum source water temperature	°F	38

## 1.5 Water Reuse: Gravity Belt Thickener Washwater

Gravity belt thickener (GBT) washwater is withdrawn from Chlorine Basin 1 via a 20-inch pipe connection to the 1950's wet well. This piping reduces down to 14" then 6" then 4" before it increases to 6" as the flow passes through automatic strainers to the pumping system. Three pumps (replaced in 2004 upgrade) serve 3-inch and 4-inch parallel headers to the three GBT units. The manufacturer requires a minimum of 120 psi washwater at the GBT units. Table 1-5 summarizes the major GBT washwater pumping equipment characteristics.

A separate high-pressure water system serves the GBT high-pressure spray bars. This system uses non-potable water and a softener system.

<b>Table 1-5. GBT Washwater Facility Characteristics</b>		
<b>Item</b>	<b>Units</b>	<b>Value</b>
Number	--	3
Flow per unit <sup>a</sup>	gpm	110
Discharge pressure <sup>a</sup>	psi	150
Design head <sup>b</sup>	ft	380
Motor size	hp	20

<sup>a.</sup> Data from SCADA screenshots provided by WRP

<sup>b.</sup> Goulds pump curve

## Section 2: Heat Sources

This section documents the magnitude of existing and future heat sources that need to be dissipated either via HVAC preheat coils or through heat exchange to effluent water.

### 2.1 Anticipated Process Equipment Heat Sources

Table 2-1 summarizes the heat sources connected to the two heating loop systems under future A/O operation. Heat sources associated with the cryogenic plant will be eliminated by the anticipated future conversion to A/O and are not included in the long-term total heat sources. Similarly, the future blower serving the A/O system is not included in the near-term total. The oxygen compressor heat rejection is very large relative to the other heat sources, so the long-term heat recovery potential from process equipment will be significantly reduced.

The cogeneration system's lube oil heat recovery is currently dissipated via an air-cooled radiator. This heat source could be added to this system (479,000 British thermal units (Btu)/hr), but this heat would not be available when needed during cold weather if the WRP continues to switch their biogas utilization to the boiler system during winter months or migrates to a pipeline injection system.

**Table 2-1. Summary of Process Equipment Heat Sources**

Heat Inputs to Heat Recovery Loops	Estimated Heat Rejected per Unit (Btu/hr/unit)	Average Number Operating	Average Heat Rejected (Near Term)	Average Heat Rejected (Future)	Peak Number Operating	Peak Heat Rejected (Near Term)	Peak Heat Rejected (Future)
Large blower oil cooling	67,000	1	0	67,000 <sup>c</sup>	1	67,000	67,000
Small blower oil cooling	44,000	0	44,000 <sup>d</sup>	0	0	0	0
New blower oil cooling	67,000	1	0	67,000	2	0	133,000
Air compressor	25,000	1	50,000	0 <sup>a</sup>	1	50,000	0
Air dryer <sup>e</sup>	13,000	1	13,000	0 <sup>a</sup>	1	13,000	0
Digester gas cooling	72,000	1	90,000	90,000	1.25	112,000	112,000
Oxygen compressor cooling	930,000	1	930,000	0 <sup>b</sup>	1.25	1,200,000	0
Other oxygen components	246,000	1	246,000	0 <sup>b</sup>	1.25	308,000	0
<b>Total (Btu/hr)</b>			<b>1,350,000</b>	<b>220,000</b>		<b>1,700,000</b>	<b>310,000</b>

a. Assumes minimal compressed air required in the future following decommissioning of primary sludge pumps and sample pumps.

b. Following decommissioning of HPO

c. Existing KA 10

d. Existing KA2 (Less used in future)

e. Heat is rejected from refrigerated dryer and a compressed air precooler (heat exchange to LTW). Total heat rejected estimated to be roughly 50% of air compressor heat.

### 2.2 Blower Air Heat Recovery

This section evaluates heat recovery from the blower discharge air. The heat of compression raises the temperature of the air leaving the aeration blowers and deeper aeration tanks, such as the 25-

foot ABC basins, increase this heat. While not common, a heat recovery coil could be installed in the blower outlet duct to route some of this heat to the heat recovery loops. The future blowers that will serve the shallower HPO basins have lower discharge temperatures and are not included in this analysis.

The ABC blowers are currently lightly loaded, but airflows will increase with future plant load increases and conversion to plant-wide A/O operation. Table 2-2 summarizes typical winter operating conditions and estimated heat recovery. Table 2-3 summarizes the net savings associated with such a system, assuming the recovered heat would offset boiler natural gas use during winter months. The net savings calculation considers the additional blower electrical use required for the pressure drop across the heat recovery coil. WRP staff have optimized heating systems and lowered recent natural gas consumption, so some of this savings may not be realized if most plant heating is provided by biogas.

This blower heat recovery system would reduce some of the heat delivered to the aeration basins, but at a future plant flow of 19.6 million gallons per day (mgd), the reduction in wastewater temperature would be less than 0.001 °F.

The estimated cost of the heat recovery coil is only \$44,000 (Attachment A), but the coil installation to retrofit the ABC blowers with heat recovery is \$330,000 because the piping connections and associated valves are fairly large. As a result, the payback for the proposed system is lengthy but would payback within the life of the project.

Item	Units	Current	Future
Year		2019	2045
Average blower airflow	scfm	2,000	12,700
Blower inlet temperature	°F	20	20
Blower outlet temperature	°F	155	155
Heat exchanger air outlet temperature	°F	100	100
Recovered water temperature	°F	80	80
Heat recovery flow	gpm	300	300
Heat exchanger pressure drop	psi	0.2	0.2
Recovered heat	Btu/hr	120,000	750,000

Item	Current	Future
Annual natural gas savings <sup>a</sup>	\$3,300	\$21,000
Annual blower energy costs	\$500	\$3,000
Net savings <sup>b</sup>	\$2,800	\$18,000
Preliminary project cost estimate		\$330,000
Simple payback (years)		18

<sup>a</sup> Assumes 4 months of winter operation with all heat recovered offsetting boiler natural gas consumption (not biogas)

<sup>b</sup> No O&M for heat exchanger cleaning or maintenance included.



A similar system was installed at the Appleton, Wisconsin wastewater plant on blowers serving 30-foot deep aeration tanks. This system is not currently in use because the motors on the positive displacement (PD) blowers overheated, apparently due to the extra backpressure from the heat recovery heat exchanger (Shaw, 2017). This experience highlights the need to manage potential blower high-pressure issues by:

- Providing bypass piping to minimize blower head and energy consumption during summer months
- Coordinating the additional heat exchanger pressure drop with the blower design conditions
- Providing cleaning access to mitigate any fouling of the heat exchanger
- Monitoring blower discharge pressure so elevated pressure conditions can be addressed promptly

## 2.3 Effluent Heat Recovery

Under current conditions, the ABC low temperature loop recovers approximately 1,500,000 to 2,500,000 Btu/hr from the spray water heat exchanger. This heat is primarily used to reduce the heat demand in the headworks building. Making a rough assumption that this offsets natural gas use (versus biogas) approximately 2.5 months per year, the value of this recovered heat is on the order of \$20,000/year.

As noted previously, because current LT loop temperatures are similar to effluent water temperatures, effluent heat recovery in this system appears to be minimal. Following removal of the oxygen compressors, the loop temperature may drop, and this heat recovery would increase. In addition, several of the HVAC coils that would utilize the recovered LT heat in this older system are not currently functional, which further limits the ability of this LT loop to recover heat.

## 2.4 Boiler Exhaust Heat Recovery

A vendor has proposed installing a Cain Industries boiler exhaust economizer on the existing boilers to increase the heat output of the boilers by 130,000 Btu/hr per boiler at boiler full load. BC does not recommend pursuing this retrofit because removing heat from the boiler exhaust gases creates acidic condensing conditions that are corrosive to the economizer. Normally, natural gas-fired boiler exhaust is maintained well above 250°F to prevent acid gas corrosion. Digester gas boiler exhaust is even more corrosive due to the hydrogen sulfide (H<sub>2</sub>S) present in the biogas. Although the H<sub>2</sub>S concentrations in the WRP biogas are relatively low, exhaust temperatures should be kept above 300°F to minimize corrosion. The water temperature entering the proposed Cain economizer would be much lower than these values (75°F) and the projected exhaust temperatures ranged from 123 to 208°F, so the economizer installation would be expected to corrode rapidly.

## 2.5 Solar Thermal

Solar thermal collectors could be used to provide additional heat input to the LT loops. This system would be similar in concept to the solar thermal system shown in Figure 2-1 that is used to supplement the District Energy system in St. Paul. This solar thermal system provides space heating in winter months and domestic hot water heat at local hospitals in summer months.

The disadvantage of solar energy is that it is fairly diffuse, especially in Minnesota, as shown in Figure 2-2. Solar incidence is even lower during winter months, reducing its effectiveness for seasonal heating. For these reasons, solar thermal installations are often limited to year-round hot water heating applications such as the District Energy system.

Table 2-4 summarizes the costs and modest anticipated natural gas savings for a hypothetical 250 square foot installation at the WRP.



Figure 2-1. 1.5 MW thermal hot water solar system on roof of St. Paul RiverCentre




Figure 2-2. Direct normal solar incidence

<b>Table 2-4. Approximate 250 SF Solar Thermal System Costs and Savings</b>	
<b>Item</b>	<b>Current</b>
Annual natural gas savings <sup>a</sup>	\$1,500
Approximate thermal output during heating season, average over 24 hours (Btu/hr)	600
Preliminary project cost estimate	\$150,000
Simple payback (years)	100

a. Assumes 6 months of winter operation with all heat recovered offsetting boiler natural gas consumption (not biogas)

b. Solar water heater, plastic collector \$59/ft<sup>2</sup> <https://www.nrel.gov/analysis/tech-lcoe-re-cost-est.html>

## Section 3: Heat Recovery Loop Alternatives

This section presents alternatives to reduce maintenance and energy use in the heat recovery system. These alternatives include:

- Cleaner cooling water sources serving existing heat exchangers
- Closed loop heat rejection to submerged effluent or ambient air
- Merging the LT and ABC low temperature heat recovery loops

### 3.1 Cooling Sources

The following sections describe alternative methods for rejecting heat. The first set of alternatives maintains the current pumped effluent concept but include revisions to reduce heat exchanger fouling. The final two alternatives eliminate effluent pumping by converting to either a submerged heat exchanger or an air-cooled radiator.

#### 3.1.1 Maintain Pumped Water Source for Cooling

As noted in Section 1, one of the primary heat recovery system issues is the maintenance requirements of the effluent pumping and cleaning heat exchangers used for rejecting heat. The following two alternatives are configured to reduce the entrained solids that currently foul the heat exchangers by relocating the effluent intake out of the final clarifiers. This modification has the additional benefit of reducing disturbances to final clarifier settling which increases peak clarifier capacity.

The existing LT and ABC low temperature heat exchangers would continue to be used with these options, but pumps would be replaced with pumps selected for the revised flow and head conditions (refer to Table 3-1).

The spray water system is tentatively planned to be separated from the effluent pumps used with the loop heat exchangers. This separation will allow the two pumping systems and related controls to be optimized for their respective functions. Although this separation increases the number of installed pumps it does not increase expected pumping energy since it allows each system to pump only the flow and head required for their respective applications.

The loop systems are planned to be merged. Refer to Section 3.3.

Item	Units	Value
<b>Effluent Pumps (Cooling Water Source)</b>		
Flow rate, LT without HPO	gpm	250
Flow rate, ABC LT without relief or spray water	gpm	340
Flow rate, total without spray water	gpm	590
Head	ft	50
Energy consumption	bhp	13
<b>Loop Water Pumps</b>		

Table 3-1. Approximate Future Heat Recovery System Pumping Conditions		
Item	Units	Value
Flow rate	gpm	700
Head	ft	80
Energy consumption	bhp	24

### Alternate 1: Relocate Intake to Chlorine Contact Channel

This alternative configuration would relocate the effluent water source from the final clarifiers to the chlorine contact tank (CCT). The chlorine in this flow would mitigate biofouling of the heat exchangers, but the piping associated with this alternative is lengthy (approximately 1,000 linear feet [LF]), as shown in the preliminary layout in Figure 3-1.




Figure 3-1. Proposed CCT intake for heat recovery loops

Image source: Google Earth

### Alternate 2: Relocate Intake to New Sump on Final Clarifier Effluent

This alternative relocates the effluent water source to a new sump near the final clarifiers. This location is expected to have less solids than the current location in the clarifier's settling zone and

would require less field piping than Alternative 1 but would not be chlorinated. The proposed configuration is shown in Figure 3-2.



**Figure 3-2. New heat recovery intake vault and piping**

*Image source: Google Earth*

### Add Filtration to Existing Intake

In addition to revising the heat recovery water intake, more effective filtration could be added to control solids. Table 3-2 summarizes different types of strainers considered for this use. For the NPV analysis in Section 3.2, addition of a sand filter similar to the one in Figure 3-3 and Attachment B was assumed for Alternates 1 and 2. The choice of filter types and filter location will need to be refined during the project design.

Table 3-2. Filtration Alternatives Comparison					
Item	Units	Filter 1 - Dual Basket	Filter 2 - Automatic Strainer	Filter 3 - Sand Filter	Filter 4 - Automatic Screen Filter
Representative manufacturer		Fluid Engineering	Fluid Engineering	Ecologix	Evoqua, Orival
Filtering size	inches/microns	1/16"	1/16"		100 microns
Pressure drop (psi)	psi		~1		7 (maximum prior to backflush)
Backwash requirements (gpm)	gpm	N/A	30-40	240	~1% of flow
Compressed air	cfm	N/A	N/A	2	N/A
Electrical requirements	hp	N/A	¼	Controls only	N/A
Equipment cost		\$15,000	\$14,000	\$43,000	\$39,000



Figure 3-3. Example sand filter configuration

### 3.1.2 Submerged Heat Exchange


This alternative would install a submerged heat exchanger in the CCT, similar to the example shown in Figure 3-4. This system would use the flow through the CCT to cool or heat the cooling loop in lieu of the pumped effluent systems described above, as shown in Figure 3-5. The heat exchanger would need to be mounted in a way that would be retrievable for cleaning. As an alternate to the CCT

location the submerged heat exchanger could be located in a new vault near the final clarifiers, similar to the vault shown in Figure 3-2.

During heat exchanger cleaning or other outages the existing once-through non-potable water cooling system would provide back-up cooling for the aeration blower lube oil systems.

The submerged heat exchanger sized only to reject the heat sources during summer months is relatively small. A larger unit would be required for winter heat recovery to provide preheating equivalent to the existing effluent water system. Table 3-33 compares the heat exchangers needed for summer and winter conditions. Submerged HX quotations are found in Attachment C.

The capital cost for this alternate assumed 304 stainless steel heat exchanger construction. Effluent chloride concentrations would need to be confirmed to determine if a higher stainless grade is required. 316 stainless steel will provide better corrosion resistance if the chloride is more than 300 parts per million (ppm) but less than 1000 ppm. Based on April 2019 data provided by the WRP, current wastewater chloride concentrations are approximately 280 ppm, which is close enough to the threshold to warrant additional data to support the selection of metal grades. Heat exchanger welds should be a higher stainless-steel grade than the plates because they are inherently less corrosion-resistant. The heat exchanger could be located in the downstream portion of the CCT to minimize exposure to residual chlorine.



**Figure 3-4. Example submerged heat exchanger configuration**






Figure 3-5. Example submerged heat exchanger schematic

Table 3-3. Summary of Submerged Heat Exchanger Design Conditions.

	Units	Summer	Winter
<b>Water in Chlorine Contact Tank</b>			
Temperature	°C/°F	20/68 <sup>a</sup>	13/55
Velocity	fps	0.02	0.02
Depth	ft	7	7
<b>Water to be Cooled or Heated</b>			
Inlet temperature	°F	80	43
Outlet temperature	°F	75	53
Flow rate	gpm	105	500
Heat transferred	Btu/hr	262,500 <sup>b</sup>	2,500,000 <sup>c</sup>
HX dimensions	inches	24"H x 25"W x 120" L	52"H x 72"W x 284"L
Budget HX cost	\$	\$24,000	\$96,000

- Peak summer wastewater temperature can reach 78 °F. Under these conditions a larger heat exchanger or periodic non-potable cooling would be required.
- Future cooling following decommissioning of HPO
- Winter conditions shown based on current cold winter day conditions in ABC low temperature loop to serve current winter heat recovery loads. Peak future LT HVAC heat loads could add a heat transfer demand on the order of 6,500,000 Btu/hr based on the LT loads in the heating coil schedule on sheet O-5 of the 1980 Expansion drawings.

### 3.1.3 Dry Cooler

Dry coolers (similar to radiators) are considered “dry” because they utilize outdoor air as a cooling fluid. A dry cooler system would simplify operations by removing the requirement for effluent heat exchange and the related fouling. Under a future A/O operation, aeration blowers could be cooled

through a combination of heat recovery and radiator cooling. According to Howden (Turblex), their blower cooling systems operate with fluid temperatures as high as 120°F, which could be achieved even under summer conditions with a radiator cooling system cooling a glycol loop.

Additional research would be required to determine the temperature requirements of the oxygen components and determine if they would work with the higher summer temperatures of a cooling system served by a radiator. The current medium temperature loop was designed to operate at loop temperatures over 100°F, but currently provides cooling water at 58 to 78 °F since this improves equipment operation. This consideration will impact whether the radiator retrofit would need to be delayed to coincide with the A/O retrofit.

A significant disadvantage of the dry cooler alternative is the loss of effluent heat recovery from the spray water system. The estimated increase in boiler natural gas (NG) consumption to compensate for this loss is included in the NPV analysis in Section 3.2.

The impact of the dry cooler alternative on the digester gas (DG) cooling system would also need to be considered. The DG cooler provides a first stage of cooling prior to chilled water cooling. Table 3-4 summarizes the DG cooler operating conditions. The precooling system saves roughly \$4,600 per year in chiller energy. The dry cooler system would be able to maintain these cooling loop temperatures when the outside air temperature is less than 60°F to 70°F, but half of the pre-cooling savings could be lost if an alternative pre-cooling source is not provided for warm weather conditions. In addition, the low temperature water is used to cool the high-pressure gas entering the storage sphere, and this cooling is beneficial to control moisture on high pressure gas routed to the engine-generators and to maximize the stored DG mass for a given storage pressure. In order to replace the low temperature cooling during warm weather, the capital costs for this alternative includes routing effluent water from the GBT washwater system to the DG heat exchanger.

<b>Criterion</b>	<b>Value</b>
DG inlet temperature (°F)	98
DG outlet temperature (°F)	67 (or warmer when LT loop temperature is high)
LT inlet water temperature (°F)	55-77
LT water temperature increase across heat exchanger (°F)	7
LT water flow (gpm)	20-25

Figure 3-6 shows a preliminary location and approximate dry cooler sizing for heat rejection from both the existing and future heat rejection scenarios. Figure 3-7 shows the integration of dry coolers in the heat recovery loop schematic.



**Figure 3-6. Preliminary dry cooler location**

*Image Source: Google Earth*




Figure 3-7. Potential dry cooler addition to ABC low temperature cooling loop configuration

## 3.2 Net Present Value Evaluation

### 3.2.1 Estimating Assumptions

Comparative capital costs were developed for each alternative, along with operating costs and life cycle present worth. Developed costs represent Class 5 estimates for Conceptual Level Planning and alternative comparison in accordance with the Association for the Advancement of Cost Engineering International (ACEI). Expected accuracy for Class 5 estimates typically ranges from -50 to +100 percent, depending on the technological complexity of the project, appropriate reference information, and the inclusion of an appropriate contingency determination. The economic analysis uses the assumptions provided in Table 3-5 and Table 3-6 below.

Table 3-5. Project Cost Assumptions	
Item	Percentage of Cost
<b>Net cost markups</b>	
Labor (employer payroll burden)	15
Materials and process equipment	10
Equipment (construction-related)	10
Subcontractor	10
Sales tax	8.125
Material shipping and handling	2
<b>Gross cost markups</b>	
Contractor general conditions	15
Start-up, training, and O&M	2
Construction contingency	50
Builders risk, liability, and auto insurance	2
Performance and payment bonds	2
Escalation to midpoint of construction	3

Table 3-6. Annual Operating Cost and Net Present Value Assumptions	
Item	Cost
Electricity unit cost <sup>a</sup>	\$0.096 per kWh
Labor rate (operations and maintenance staff) <sup>b</sup>	\$55 per hr
Pump maintenance	0.2 hrs/day/pump
Heat exchanger maintenance (current)	96 hrs/year
Interest rate	3%
Discount rate	5%
Life-cycle cost period	20 years

<sup>a.</sup> Based on electricity bills received from the City for the WRP from January, February, and May in 2017.

<sup>b.</sup> Assumed based on similar projects

### 3.2.2 Operating Cost Comparison

Table 3-7 summarizes the estimated operating costs for the heat recovery alternatives. The submerged heat exchanger in the CCT has the lowest operating costs due to reduced pumping energy and pump maintenance.

**Table 3-7. Cooling and Heat Recovery Annual Operating Costs**

Item	Final Clarifier Cooling Source (Status Quo)	CI Contact Cooling Source	FC Effluent Sump Cooling Source	Submerged HX in CI Contact	Air-Cooled Radiator
Pumping energy	\$30,000	\$28,000	\$24,000	\$16,500	\$11,000
Natural gas					\$9,000 <sup>b</sup>
Pump maintenance	\$40,000	\$24,000	\$24,000	\$12,000	\$12,000
HX maintenance	\$5,000	\$1,500	\$1,500	\$2,500	--
Filter maintenance	\$2,000	\$2,000	\$2,000	--	--
Blower maintenance	--	--	--	--	\$2,500 <sup>a</sup>
Dry cooler energy					\$1,800
Dry cooler maintenance	--	--	--	--	\$5,000
<b>Operating total</b>	<b>\$77,000</b>	<b>\$57,500</b>	<b>\$53,500</b>	<b>\$31,000</b>	<b>\$41,000</b>

<sup>a.</sup> Assumes small maintenance increase from higher lubrication temperature

<sup>b.</sup> Increased natural gas to compensate for loss of heat recovery in ABC low temperature loop during winter months

### 3.2.3 Net Present Value

A presentation of the capital costs and net present values of each alternative are presented in Table 3.8 below.

The final clarifier effluent sump and air cooled radiator alternatives had the lowest (most economical) NPV. The submerged HX in the CCT had a slightly higher NPV than these alternatives due to its higher estimated capital cost.

This analysis includes the O&M factors in Table 3-6. The NPV calculation did not include the increased potential for additional effluent heat recovery on the LT loop if the HVAC systems are repaired.

Item	Final Clarifier Cooling Source (Status Quo)	CI Contact Cooling Source	FC Effluent Sump Cooling Source	Submerged HX in CI Contact	Air-Cooled Radiator
Piping and pumps		\$185,000	\$60,000	\$142,000	\$25,000
Dry cooler					\$24,000
Submerged heat exchanger				\$110,000	
HX installation				\$40,000	\$37,000
GBT washwater to DG cooling					\$5,000
Sand Filter		69,000	69,000		
Electrical				\$20,000	\$20,000
Markups		\$230,000	\$120,000	\$280,000	\$100,000
Engineering and administration (20%)		\$71,000	\$23,000	\$120,000	\$43,000
<b>Total capital cost</b>		<b>\$590,000</b>	<b>\$300,000</b>	<b>\$710,000</b>	<b>\$260,000</b>
NPV of O&M costs	\$1,400,000	\$1,000,000	\$900,000	\$570,000	\$745,000
NPV	\$1,400,000	\$1,600,000	\$1,250,000	\$1,300,000	\$1,000,000

a. Cost presented in 2020 dollars

b. Includes \$200,000 for engineering and administration related to developing and testing the performance

### 3.2.4 Alignment with WRP Goals

Table 3-9 summarizes the advantages and disadvantages of the cooling and heat recovery alternatives relative to WRP facility planning goals and other considerations. The submerged HX scores favorably in some aspects of this comparison, but this approach is not proven in a wastewater setting and the effort required to keep the heat exchanger clean is unknown.

The air-cooled radiator alternative does not offer heat recovery without ancillary effluent heat exchange, so this alternative was eliminated from further consideration.

Item	Final Clarifier Cooling Source (Status Quo)	CI Contact Cooling Source	FC Effluent Sump Cooling Source	Submerged HX in CI Contact	Air-Cooled Radiator
Reduces pumping energy	0	0	0	+	+
Minimizes natural gas consumption	0	0	0	0	—
Reduces maintenance	—	+	0	0	+

Item	Final Clarifier Cooling Source (Status Quo)	CI Contact Cooling Source	FC Effluent Sump Cooling Source	Submerged HX in CI Contact	Air-Cooled Radiator
Ease of constructability	+	—	0	—	+
Compatibility with existing heat sources	+	+	+	+	—
Proven approach	0	+	+	—	+

a. Symbols: + positive attribute, 0 neutral, - negative attribute

### 3.3 Merge Low Temperature Water Loops

Any of the heat recovery alternatives noted above could be implemented with merged LT and ABC low temperature water loops. Merging the loops would eliminate at least two pumps and their associated maintenance. The three LT loop pumps are designed for 500 gallons per minute (gpm) at 20 psi, with one pump typically in service and the ABC low temperature effluent loop pump capacity is 450 gpm. Based on the pipe sizes in the pumping area (8-inch), the LT loop pumps would appear to be the best candidates for serving the merged loop. A detailed hydraulic analysis would be needed to determine whether the existing pump's flow and head characteristics would be suitable for the merged loop conditions, both under current conditions and future conditions following conversion to A/O. This evaluation could also consider the potential energy benefit of retrofitting these pumps with variable frequency drives (VFDs).

### 3.4 Low Temperature Loop Economic Viability

Although the low temperature heat recovery system provides an innovative means of reducing boiler heating demand, there are energy and maintenance costs associated with operating the system. This section considers the cost effectiveness of the branch of the ABC low temperature system serving the headworks.

Eliminating the heat recovery serving the headworks would add approximately 10% to the winter boiler heating load. During spring and fall months, the additional load would represent approximately 50% of the available recovered heat while the CHP system is running, decreasing the number of weeks per year that the CHP system would be able to provide adequate heat for the high temperature loop.

Table 3-10 summarizes the operating assumptions used to estimate the net savings for this heat recovery system. Table 3-11 summarizes the estimated operating costs and savings. Based on this analysis there is a net benefit of roughly \$13,000 per year for this heat recovery system.

Item	Units	Value
ABC low temperature loop pump		
Flow	gpm	500
Head	ft	121
System operation	months/year	5



**Table 3-10. Headworks Low Temperature Loop Operating Assumptions**

Item	Units	Value
Energy	bhp	22
Maintenance	hours/pump/day	0.2
Spray water pump		500
Flow	gpm	300
HX head	ft	48
System operation	months/year	5
Energy	bhp	5
HVAC Airflow		
Total (grit, screenings, influent pump)	cfm	47,000
Coil pressure drop	inches w.c.	0.8 <sup>a</sup>
Energy	bhp	8.3
System operation	months/year	12
Heat recovery		
Natural gas savings duration	months/year	2.5 <sup>b</sup>
Recovered heat, headworks typical	Btu/hr	1,500,000
Additional CHP		
Operation duration	weeks/year	4
Output	kW	600

a. Based on 1980 expansion coil schedule (drawing O-5)

b. Assumes biogas is used for heating during the remaining heating season

**Table 3-11. Headworks Low Temperature Loop Net Cost Evaluation**

Item	Annual Cost (\$)
Loop pump energy <sup>a</sup>	5,600
Spray water additional energy	3,200
Fan Energy	5,200
Loop Pump Maintenance	8,000
HVAC and LT HX Maintenance	2,000
Natural Gas Savings <sup>b</sup>	(20,800)
Additional Fall/Spring Electrical Production <sup>c</sup>	(13,000)
Net Savings	(7,800)

a. \$0.096/kWh

b. \$0.76/therm

c. CHP electrical savings: \$0.06 \$/kWh with no demand. O&M: \$0.028 \$/kWh

## Section 4: Reuse Water Alternatives

As described previously in Section 1, there are three major effluent re-use systems: low temperature heat recovery, spray water, and GBT washwater. Section 3 presented alternate cooling sources to reduce heat exchanger maintenance. The analysis in this section assumes that the spray water is separated from the ABC low temperature effluent heat exchanger, either via the submerged heat exchanger or separate low-pressure pumps serving the existing heat exchanger.

In addition, this section considers:

- Alternatives to providing a heat source to PC3 if the effluent water source is decommissioned
- Upgrades to the reuse water strainer systems.

### 4.1 Water Reuse Pumping Alternatives

Table 4-1 summarizes the design conditions for the two remaining reuse water systems. The following sections present alternatives to optimize these systems.

Item	Continuous (gpm)	Peak (gpm)	Future Continuous/Peak (gpm)	Pump Differential Pressure (psi)
Spray water	130	280	130/280	80
GBT washwater	110	110	150/205 <sup>a</sup>	170
Total	240	390	280/485	--

a. Includes 10 gpm for scrubber water chlorinators, 10 gpm for future disinfection chlorinators, 20 gpm for carrier water, and washwater increased by 50% for potential future fourth GBT (increase from 2 to 3 GBTs in service)

#### 4.1.1 Separate Spray and GBT Water Systems

This alternative would continue to keep the spray and GBT pumping systems separate as shown in Figure 4-1. The two existing spray water pumps would be replaced with two new pumps to reduce the rated pump flow from 850 gpm to 280 gpm, selecting a pump that would address the cavitation observed in the current pumping system. The existing FC3 and FC4 intake configuration would be modified to use a new inlet sump as shown in Figure 3-2. The GBT pumps would remain in their current configuration and have adequate capacity for future conditions.



Figure 4-1. Separate spray water and GBT washwater pumping systems

Image Source: Google Earth

#### 4.1.2 Merged Spray Water and GBT Wash Water – Chlorine Contact Basin

This alternative would merge the two water reuse systems in order to reduce the number of pumping systems needing maintenance. This configuration would also provide chlorinated effluent for the spray water system. Figure 4-2 shows one possible configuration for the cross-connection piping required to merge the two systems and the pressure reducing valve required to throttle the pressure in the spray water system. The 3- and 4-inch piping serving the combined spray water and GBT systems would see somewhat high velocities under peak conditions, so alternate routing could be considered during final design. The three existing GBT pumps only have a combined capacity of 330 gpm. The estimated capital cost for this alternative includes three new pumps to supply future peak operating conditions.

This configuration increases pumping energy relative to the separate systems because all pumping would operate at 170 psi.




Figure 4-2. Cross-connection piping to merge spray water and GBT washwater systems

Image Source: Google Earth

### 4.1.3 Merged Water Systems with GBT Booster Pump

This alternative would replace the existing GBT washwater pumps with 80 psi pumps sized to provide the total flow requirements listed in Table 4-1. New 10 horsepower (hp) booster pumps would be added to each GBT to provide adequate flow and pressure belt washing. The cross-connection piping configuration would be similar to that shown in Figure 4-2 (without the pressure reducing valve).

## 4.2 Net Present Value Evaluation

This section presents the net present value evaluation for the water reuse alternatives. The assumptions used in this analysis are the same as those presented in Section 3.2.1.

### 4.2.1 Operating Cost Comparison

Table 4-2 summarizes the annual operating costs for the three reuse water alternatives. The alternatives presented below all reduce pump energy consumption by at least \$30,000 per year relative to current pumping conditions, primarily by reducing the average flow through the spray water system. Refer to Section 4.3 for additional scope related to separating the spray water from the PC3 heating system.

Of the future alternatives, the merged spray and GBT systems alternative has the lowest estimated operating cost due to the predicted reduction in pump maintenance, which offsets the increase in energy cost.

**Table 4-2. Cooling and Heat Recovery Annual Operating Costs**

Item	Separate Spray Water and GBT Washwater Systems	Merged Spray and GBT Systems	Merged Spray and GBT Systems with GBT Booster Pumps
Pumping energy	\$17,000	\$22,000	\$20,000
Pump maintenance	\$20,000	\$12,000	\$24,000
Strainer maintenance and chlorination	\$1,000	--	--
Operating total	\$38,000	\$34,000	\$44,000

### 4.2.2 Net Present Value

A presentation of the capital costs and NPVs of each alternative are presented in Table 4-3. The separate spray water and GBT washwater system alternative has the most favorable NPV due to the lower capital cost. This analysis assumes that the existing GBT washwater pumps are suitable for continued use over the planning period, with no capital costs included for replacing these pumps.

**Table 4-3. Water Reuse Capital Costs and Net Present Value**

Item	Separate Spray Water and GBT Washwater Systems	Merged Spray and GBT Systems	Merged Spray and GBT Systems with GBT Booster Pumps
Piping	5,000	56,000	52,000
Pump replacement	30,000	95,000	100,000
Revised pump intake	154,000 <sup>a</sup>		
Electrical and instrumentation	11,000	54,000	56,000
Markups	140,000	211,000	212,000
Engineering and Administration (20%)	70,000	83,000	84,000
Total Capital Cost	410,000	500,000	500,000
NPV of O&M Costs	700,000	770,000	800,000
NPV	\$1,100,000	\$1,300,000	\$1,300,000

a. Capital cost for pump intake vault also included in LT loop alternative BCE in Table 3-7.

### 4.2.3 Alignment with WRP Goals

Table 4-4 summarizes the advantages and disadvantages of the effluent reuse alternatives relative WRP facility planning goals and other considerations. Separate reuse water systems scores most favorably in this comparison.

Table 4-4. Water Reuse Alternative Comparison			
Item	Separate Spray Water and GBT Washwater Systems	Merged Spray and GBT Systems	Merged Spray and GBT Systems with GBT Booster Pumps
Reduces pumping energy	+	0	+
Reduces maintenance	0	+	0
Ease of constructability	+	0	0

Symbols: + positive attribute, 0 neutral, - negative attribute

### 4.3 Primary Clarifier 3 Heat Source

The PC3 heating system is described in Section 1.4. This system will be impacted by the proposed changes to the heat recovery section described in Section 3, especially if the submerged heat exchanger alternative is selected. This section compares two alternatives for revising the PC3 heating system.

#### 4.3.1 Route Headworks Spray Water Through Existing Heat Exchanger

This alternative assumes that effluent flow to the PC3 HVAC heat exchanger is provided by one of the water reuse pumping systems above, with the pumped flow being returned to the spray water system instead of wasted to the primary clarifier effluent. The new piping is shown in Figure 4-3 and a schematic is shown in Figure 4-4.



Figure 4-3. Piping to route effluent water from PC3 HVAC back to spray water

Image Source: Google Earth




Figure 4-4. Spray water routed through PC3 HX

### 4.3.2 Replace Heat Exchanger with Effluent Water Cooling Loop

This alternative assumes that the PC3 heating loop would be connected to the main heat recovery loop. The PC3 heating system withdraws approximately 250,000 Btu/hr from the effluent water system. Under this condition, the PC3 heat withdrawal would need to be made up through some combination of increased effluent heat exchange or extra hot water system (boiler) use. This analysis assumes that the additional heat exchange is provided by enlarging the submerged heat exchanger. In addition, approximately 600 LF of 4-inch piping would be required to connect PC3 to the effluent water loop in the ABC blower building.

This alternative has two advantages:

- Elimination of maintenance associated with two PC3 loop pumps and HX
- Elimination of HX pumping energy in loop

### 4.3.3 Net Present Value

Table 4-5 compares the capital cost and NPV for the two PC3 modification alternatives. Merging the PC3 and ABC low temperature cooling loops has the most economical NPV, primarily due to reduced pump maintenance through the elimination of the PC3 loop pumps.

Another potential heat recovery strategy would be to route tunnel exhaust to the PC3 air handling unit. This option would require a building code review and investigation of the available exhaust airflow and ducting required.

Item	Route Spray Water through PC3 Heat Exchanger	Merge PC3 and Effluent Cooling Loops
Piping	\$60,000	\$80,000
Larger submerged heat exchanger	\$10,000	
Markups	\$92,000	\$100,000
Engineering and administration (20%)	\$18,000	\$35,000
Total capital cost	\$180,000	\$215,000
NPV of O&M costs	\$160,000 <sup>a</sup>	\$7,600 <sup>b</sup>
NPV	\$340,000	\$220,000

a. \$8,000/year PC3 loop pump and HX maintenance, \$900/year pump energy  
b. \$400/year pump energy

## 4.4 Strainer Upgrades

The ABC low temperature effluent water and GBT washwater systems have automated strainers. The low temperature loop has a coarse strainer that is pressure-differential backflushed. WRP staff have indicated that they would like to remove additional solids from the reuse water using upgraded straining systems.

The appropriate mesh size for water reuse can be based on the maximum particle size or solids concentration that can be tolerated by downstream equipment. For example, one GBT manufacturer (Alfa Laval) states that the solids concentration in washwater can be as high as 200 mg/L.

Alternatively, the mesh size can be determined based on the typical particle size in reuse water. The WRP occasionally experiences pin floc, especially in the HPO system final clarifiers. Pin flocs are often smaller than 50µm. A mesh size of 270 or smaller would provide openings in this size range. Brown and Caldwell's treatability lab could perform a sieve analysis to confirm this mesh recommendation based on actual particle sizes.



## Section 5: Recommendations

This Technical Memorandum (TM) presented several evaluations of the heat recovery and water reuse systems. Table 5-1 summarizes the capital improvements based on the conclusions. Figure 5-1 depicts the recommended heat recovery loop configuration. The final clarifier effluent vault water intake was chosen as a water source for both the heat recovery system over the submerged heat exchanger alternative because this approach is more proven and there is less uncertainty about the effort needed to keep the heat exchanger clean. This vault will also be used for the spray and flushing water system's intakes.

Current heat recovery and water reuse system operating costs were estimated to be roughly \$125,000 per year. The modified effluent water intake, merged water loops, and spray water modifications are estimated to save approximately \$35,000 per year in pumping energy and \$20,000 per year in reduced pump and heat exchanger maintenance, reducing the estimated future annual operating cost to \$70,000.

Table 5-2 summarizes the heat sources and sinks in the heat recovery system, including the low temperature HVAC, headworks HVAC, ABC HVAC, and primary 3 HVAC. Table 5-3 suggests preliminary design conditions for a new heat exchanger to serve the combined low temperature systems. A preliminary quote for this heat exchanger, with 8 mm openings for solids passing, is in Attachment F. Wider plate spacing lowers the velocity of the flow between the plates and under low summer flow rates, so the design needs to be optimized to avoid laminar conditions which reduce heat transfer and could lead to particle settling. Future refinement of the heat exchanger design may require two heat exchangers with only one operating in summer conditions to balance the advantages of wider plate spacing against the potential for low flow velocity,

Item	Cost <sup>a, b</sup>	Objective
Effluent water intake vault and suction piping near final clarifiers	\$138,000	Reduce maintenance and pumping energy
Merged LT water loops	\$50,000 <sup>c</sup>	Reduce pump maintenance
Reuse spray water pumping and piping revisions	\$115,000 <sup>e</sup>	Reduce pumping energy
PC3 HVAC heat source revisions	\$180,000	Reduce pumping energy
Strainer upgrades	\$100,000	Minimize maintenance of equipment served by spray water and GBT washwater systems
Demolish MT cooling loop	-- <sup>d</sup>	Loop no longer required following conversion of secondary treatment to A/O
<b>Total</b>	<b>\$590,000</b>	

<sup>a.</sup> Refer to Section 3.2.1 for accuracy, contingency, mark ups, and engineering and administration assumptions

<sup>b.</sup> AACEI Class 5 estimate

<sup>c.</sup> Rough estimate without developed scope of improvements

<sup>d.</sup> Cost included in liquid treatment estimate

<sup>e.</sup> Spray water pump replacement and connection to new effluent water intake vault




Figure 5-1. Proposed heat recovery and water reuse system

Note: Following conversion to A/O

Table 5-2. Heat Recovery System Summary		
Item	Average Heat Use/Rejection (Btu/hr)	
	Current	Future
<b>Heat users</b>		
LT HVAC	0 <sup>a</sup>	4,900,000 <sup>b</sup>
Headworks HVAC	1,700,000 <sup>c</sup>	1,700,000 <sup>c</sup>
ABC HVAC	200,000 <sup>d</sup>	200,000 <sup>d</sup>
Primary 3 HVAC	430,000	430,000
<b>Total</b>	<b>2,330,000</b>	<b>7,230,000</b>
<b>Heat rejection sources</b>		
HPO	1,200,000	0
ABC aeration blowers	44,000	67,000
A/O aeration blower		67,000
Air compressor equipment	63,000	0
Digester Gas Equipment	90,000	90,000
<b>Total</b>	<b>1,350,000</b>	<b>220,000</b>

- a. Minimal current heat recovery because loop temperature is close to effluent temperature and HVAC controls are in poor repair
- b. 75% of maximum based on HVAC coil schedule in design drawing
- c. Average based on "typical" SCADA information
- d. Estimated to be roughly 10% of headworks HVAC

<b>Table 5-3. Preliminary Heat Exchanger Design Conditions</b>		
<b>Item</b>	<b>Loop</b>	<b>Effluent</b>
<b>Fluid</b>	<b>40% Glycol</b>	<b>Treated Wastewater</b>
<b>Winter Flow Rate (gpm)</b>	<b>1500</b>	<b>1500</b>
<b>Winter Inlet Temperature</b>	<b>40</b>	<b>57</b>
<b>Winter Outlet Temperature</b>	<b>51.5</b>	<b>47</b>
<b>Winter Heat Exchange</b>	<b>7,000,000<sup>a</sup></b>	
<b>Summer Flow Rate</b>	<b>500</b>	<b>500</b>
<b>Summer Inlet Temperature</b>	<b>83</b>	<b>72</b>
<b>Summer Outlet Temperature</b>	<b>74</b>	<b>80</b>
<b>Summer Heat Exchange</b>	<b>2,000,000</b>	

a. Winter heat demand minus future heat sources.

## Section 6: References

Polydyne, presentation “Laboratory Jar Testing” presented to the Michigan Water Environment Association, East Lansing, MI, April 29, 2015

EDMR, Rochester Discharge Monitoring Report, May 16, 2019

Shaw, Chris. Email exchange with Appleton Utilities Director regarding blower heat recovery, September 22, 2017.

## **Attachment A: Blower Heat Recovery Coil Drawing and Quote**

---



1401 7<sup>th</sup> STREET S.  
HOPKINS, MN 55343  
952-933-2559  
XCHANGER.COM

**Brown & Caldwell**  
30 East 7th Street  
Suite 2500  
St. Paul, MN 55101

May 3, 2019  
Proposal 56547GF

Attn : Nancy Andrews  
Subject : Air cooler - 25,000 SCFM

In response to your request, we are pleased to offer the following quotation for one Xchanger, Inc. heat exchanger with specifications per the attached data sheet.

Model C-600, ref data sheet #141719 . . . . . \$ 45,070.00 Each  
• Includes a [Heresite](#) coating on the internal core

Due to volatile market conditions, prices are valid for 15 days from date of quotation and are subject to an adjustment based on current material prices and tariffs.

Standard lead time to shipment is 10 weeks after drawing approval. Lead time options and commercial information are on the following supplement. Design options are shown on the configuration page.

Please contact me if you have any questions.

Sincerely,

A handwritten signature in black ink that reads "Gregg Fayer". The signature is written in a cursive, flowing style.

Gregg Fayer



1	<b>Xchanger, Inc. Rating for Model C-600 ref #141719</b>		<b>Page 1 of 1</b>
2	Engineer: Gregg Fayer		May 3, 2019
3	Prepared for:		
4	Brown & Caldwell		
5			
6			
7			
8	<b>PERFORMANCE</b>	<b>PROCESS MEDIA SIDE</b>	<b>SERVICE MEDIA SIDE</b>
9	Fluid Circulated	Air	Water
10	Volumetric Flow Rate	25,000.0 Std. ft <sup>3</sup> /min	297.8 gal/min
11	Total Fluid Entering	112,503. lb/hr	148,384.7 lb/hr
12	Liquid		148,384.7 lb/hr
13	Vapor		
14	Non-Condensibles	112,503.9 lb/hr	
15	Vaporized or (Cond.)		
16	Temperature In	155.0 °F	70.0 °F
17	Temperature Out	100.0 °F	80.0 °F
18	Inlet Pressure (Absolute)	28.696 lb/in <sup>2</sup>	
19	Velocity (Standard)	1,000.0 ft/min	6.7 ft/sec
20	Pressure Loss	0.09 lb/in <sup>2</sup>	8.5 lb/in <sup>2</sup>
21	Fouling Factor	0.00050 ft <sup>2</sup> -°F-hr/BTU	0.00100 ft <sup>2</sup> -°F-hr/BTU
22	Total Heat Exchanged: 1,483,467 BTU/hr		
23			
24	<b>AVERAGE MEDIA PROPERTIES</b>		
25	Thermal Conductivity	0.016 BTU/hr-ft-°F	0.349 BTU/hr-ft-°F
26	Specific Heat	0.240 BTU/lb-°F	1.000 BTU/lb-°F
27	Absolute Viscosity	0.048 lb/ft-hr	2.288 lb/ft-hr
28	Density (MW)	(29.0)	62.128 lb/ft <sup>3</sup>
29	Latent Heat of Vapor		
30			
31	<b>CONSTRUCTION</b>		
32	Design Temperature	300 °F	200 °F
33	Design Pressure (Gauge)	15.0 lb/in <sup>2</sup>	100.0 lb/in <sup>2</sup>
34	Test Pressure (Gauge)		300.0 lb/in <sup>2</sup>
35	Test Procedure	No Test	Bubble Test
36	ASME Code Stamp	Not Applicable	Not Applicable
37			
38	Tube Material : Carbon Steel	Housing Material : Galvanized Steel	
39	Fin Material : Aluminum	Casing Material : Galvanized Steel	
40	Sealant Material : Silicone	Phenolic Coating : Fin/tube core	
41	Removable Core : Yes, Front & Rear	Mist Eliminator : None	
42	Tube Circuit Type: Nontrapped	Gas Flow Dir. : Right Hand Horizontal	
43	Dry Weight : 2,527 lb	Wet Weight : 2,693 lb	
44	Thermometers : None	Mod. Water Valve : None	
45	Diff. Pres. Gauge: None	Auto. Drain Trap : None	
46			
47	<b>CONNECTIONS</b>		
48	Process Inlet : 34" ANSI 150 lb pattern FFF, 3/8" thick		
49	Process Outlet : 34" ANSI 150 lb pattern FFF, 3/8" thick		
50	Service Inlet : 3" C.S. ANSI 150 lb RFF		
51	Service Outlet : 3" C.S. ANSI 150 lb RFF		
52			
53	<b>NOTES</b>		
54	Approximate unit dimensions (inches): A = 82, B = 110, C = 85, D = 42		
55	Construction material suitability must be determined by customer.		
56	The process flow must be uniform, smooth, and free of pulsation.		
57	This unit must be protected from freezing.		
58	This unit is not designed for cycling process gas pressure.		
59			
60			
61			
62			



xchanger.com 952-933-2559



1401 7<sup>th</sup> STREET S.  
HOPKINS, MN 55343  
952-933-2559  
XCHANGER.COM

## C Series Heat Exchanger

C Series exchangers can heat, cool, dehumidify & filter air at pressures from -15 to +50 PSI with under 0.2 PSI pressure loss. Service can be cooling water, refrigerant, steam, & cryogenic liquids. C Series exchangers consist of fin-tube core(s) inside an air-tight housing. The service fluid flows inside the tubes, air flows across the fins. The air should be filtered and pulsating flow, such as that produced by rotary lobe blowers, should be dampened by a chambered silencer prior to entering the heat exchanger. Cores can optionally be removed through the front or rear covers.



SEE LINE #54 OF DATA SHEET FOR APPROXIMATE DIMENSIONS

### Design Options:


- Connection types: tube, pipe, flange, NPT, ferrule, etc
- Materials of construction: carbon or stainless steel, copper, aluminum, cupro-nickel, Hastelloy, etc
- Epoxy phenolic coating for corrosion protection of the core
- Mist eliminator to prevent condensate carryover
- Inspection/Access ports
- Air filters: HEPA pleated, metal, etc
- Units can be built to required dimensions
- Drainable tube circuiting for freezing protection

### Accessories:

- |   |          |
|---|----------|
| • Instrument Coupling   | \$ 60    |
| • Thermometer (Includes Coupling)   | \$ 90    |
| • Differential Pressure Gauge   | \$ 280   |
| • Automatic Drain Trap (3/4", 330 lb/hr)  | \$ 390   |
| • Temperature Control Valve (Regulates coolant flow to maintain a constant exiting gas temperature) |          |
| 3/4", 30 GPM  | \$ 750   |
| 1", 50 GPM  | \$ 790   |
| 2", 100GPM  | \$ 2,500 |
| • Others available upon request   |          |



## **Attachment B: Sand Filter Drawing and Quote**



## **Attachment C: Submerged Heat Exchanger**

---



**Omega Thermo Products**

PO Box 141  
 205 Sunset Avenue  
 Stratford, WI 54484 USA  
 Phone: (715) 687-8102  
 Fax: (715) 687-8053

**Quote No: SJ17618**

**Friday, March 8, 2019**

Prices are Valid Until Sunday, April 7, 2019

Page 1 of 1

**Attention: Nancy Andrews**

**Brown and Caldwell**

201E. Washington St. Suite 500  
 Phoenix, AZ 85004

**Sales Contact:**

**Kemper, Chelsey**

Phone: 715-687-8102


Extension: 222

Email: ckemper@laser-plate.com

$Q = 105\text{gpm} \times 500 \times 5F = 262,500 \text{ BTU/hr}$   
 $LMTD = 9.27F$   
 $A = 262,500 \text{ BTU/hr} / (9.27F \times 75 \text{ BTU/hr ft}^2 \text{ F}) = 377.56 \text{ ft}^2$

**Line: 5 Part ID: SUBMERGED HX**

Plate Bank  
 Double Embossed Laser-Plate Bank Assembly  
 (10) plates banked on 2" centers (Plate type 003, no baffles)  
 Plates: 16 Ga. (0.0595") x 24" x 120" SA-240 304Lss 2B/2B  
 Plate Inlet: 3/4" NPS Sch 40, Pipe  
 Plate Outlet: 3/4" NPS Sch 40, Pipe  
 Assembly Inlet: 3" NPS Sch 40 Pipe x 150# RFSO flange  
 Assembly Outlet: 3" NPS Sch 40 Pipe x 150# RFSO flange  
 Non-Code, Rated For:  
 MAWP: 150 PSI @ 400°F MDMT: -20°F @ 150PSI  
 Media Type: Water  
 T Header  
 Connections in opposite corners  
 Seal weld edges



Quantity	Unit Price	Total Price
1.00 EA	11,110.00	\$11,110.00

**Payment Terms:** 30% Dn, Net 30

**Shipping Method:** FOB, SHIPPING POINT

**Billing Type:** Charge with Invoice

**Lead Times:** Drawings 1-2 Weeks Shipping 5-6 Weeks

Due to the current volatility surrounding surcharges on stainless steel, Omega reserves the right to review and adjust the material pricing upon receipt of the purchase order.

1) Omega Thermo Products is not responsible for the corrosion resistance or suitability of the material. The process operating conditions and environment, which include cleaning and other factors may contain a corrosive element (acids, bleach, chlorides, bromine, cupric ions, ferric ions, sulfide ions, etc.), which is beyond the control of the equipment fabricator. Therefore the user of the equipment is responsible for corrosion resistance and suitability of material in the process.

2) The delivery stated represents Omega's current production load. Changes occur on a daily basis that may alter the delivery. Please contact Omega if you require delivery other than that being proposed.





Fri 5/24/2019 8:50 AM

Chelsey Kemper <ckemper@laser-plate.com>

**RE: Submerged Heat Exchanger Proposal Request**

To Nancy Andrews



Quote 17939.PDF  
89 KB

Good Morning Nancy,  
I have quoted this a few different ways.


- 1) You can buy the small bank I previously quoted you for the summer and then one large bank that is included in this quote labeled winter to use in the winter. This would then give you 2 banks, one for each season and would be the more cost effective method.
- 2) You can buy 8 of the banks labeled winter/summer. In the summer you would only run water through one bank. In the winter you would need to daisy chain all 8 together and run in series to get your desired results.

For the winter conditions you want to get the water to 53F using 55F water. I'm not sure that you will be able to get the outlet temperature of the water up that close to the temperature of the process water. I'm waiting to get more guidance on this from one of our experts and will be in touch with what I find.

Have a great weekend,

Chelsey Kemper  
Sales Engineer



	<b>Omega Thermo Products</b>	<b>Quote No: 17939</b>
	PO Box 141	<b>Wednesday, May 22, 2019</b>
	205 Sunset Avenue	Prices are Valid Until Friday, June 21, 2019
	Stratford, WI 54484 USA	
Phone: (715) 687-8102		
Fax: (715) 687-8053		Page 1 of 2

**Attention:** Nancy Andrews

**Sales Contact:**

**Brown and Caldwell**  
201E. Washington St. Suite 500  
Phoenix, AZ 85004

**Kemper, Chelsey**  
Phone: 715-687-8102      Extension: 222  
Email: ckemper@laser-plate.com

**Line: 5    Part ID: SUBMERGED HX - WINTER/SUMMER**  
Plate Bank  
Double Embossed Laser-Plate Bank Assembly  
(20) plates banked on 2" centers (Plate type 003, no baffles)  
Plates: 16 Ga. (0.0595") x 24" x 120" SA-240 304Lss 2B/2B  
Plate Inlet: 1 1/2" NPS Sch 40, Pipe  
Plate Outlet: 1 1/2" NPS Sch 40, Pipe  
Assembly Inlet: 6" NPS Sch 40 Pipe x 150# RFSO flange  
Assembly Outlet: 6" NPS Sch 40 Pipe x 150# RFSO flange  
Non-Code, Rated For:  
MAWP: 150 PSI @ 400°F    MDMT: -20°F @ 150PSI  
Media Type: Water  
Straight Header  
Connections in opposite corners  
Seal weld edges

Quantity	Unit Price	Total Price
1.00 EA	25,649.00	\$25,649.00
8.00 EA	23,870.00	\$190,960.00

**Line: 10    Part ID: SUBMERGED HX - WINTER**  
Plate Bank  
Double Embossed Laser-Plate Bank Assembly  
(34) plates banked on 2" centers (Plate type 003, no baffles)  
Plates: 16 Ga. (0.0595") x 48" x 260" SA-240 304Lss 2B/2B  
Plate Inlet: 1 1/2" NPS Sch 40, Pipe  
Plate Outlet: 1 1/2" NPS Sch 40, Pipe  
Assembly Inlet: 6" NPS Sch 40 Pipe x 150# RFSO flange  
Assembly Outlet: 6" NPS Sch 40 Pipe x 150# RFSO flange  
Non-Code, Rated For:  
MAWP: 150 PSI @ 400°F    MDMT: -20°F @ 150PSI  
Media Type: Water  
Straight Header  
Connections in opposite corners  
Seal weld edges

Quantity	Unit Price	Total Price
1.00 EA	96,335.00	\$96,335.00

**Payment Terms:** 30% Dn, Net 30

**Shipping Method:** FOB, SHIPPING POINT

**Billing Type:** To Be Determined

**Lead Times:** Drawings and shipping to be determined

Continued ...



**Quote No: 17939**

**Wednesday, May 22, 2019**

Prices are Valid Until Friday, June 21, 2019

Page 2 of 2

Due to the current volatility surrounding surcharges on stainless steel, Omega reserves the right to review and adjust the material pricing upon receipt of the purchase order.

1) Omega Thermo Products is not responsible for the corrosion resistance or suitability of the material. The process operating conditions and environment, which include cleaning and other factors may contain a corrosive element (acids, bleach, chlorides, bromine, cupric ions, ferric ions, sulfide ions, etc.), which is beyond the control of the equipment fabricator. Therefore the user of the equipment is responsible for corrosion resistance and suitability of material in the process.

2) The delivery stated represents Omega's current production load. Changes occur on a daily basis that may alter the delivery. Please contact Omega if you require delivery other than that being proposed.

## **Attachment D: Air Cooled Radiator**

---





Company Address 13601 Algonquin Road,  
Suite 925  
Rolling Meadows, IL 60008  
USA

Created Date 3/7/2019  
Expiration Date 4/30/2019  
Quote Number 00057754

Opportunity Name Minnesota Dry Cooler

Prepared By Alex Schafer  
Phone (224) 407-7289  
Email alex.schafer@guentner.com

Contact Name Nancy Andrews  
Phone 651.468.2043  
Email nandrews@brwncald.com

Bill To Name Brown and Caldwell  
Bill To 201 North Civic Drive, Suite 300  
Walnut Creek, CA 94596

Ship To Name Brown and Caldwell

Product	Line Item Description	Quantity	Total Price
GFH	S-GFH 067A/3-N(2)-F6/6P.M	1.00	USD 12,262.32
<b>Grand Total</b>			<b>USD 12,262.32</b>

**Notes**

Notes Price does not include freight or any applicable taxes

Delivery Time 8 to 9 weeks after receipt of order and technical approvals

Delivery Term FCA Laredo, TX

Payment Terms 30 DAYS NET

Standard Güntner Terms and Conditions unless stated otherwise.



★



Brown and Caldwell  
Nancy Andrews

Date: 2019-03-07  
Enquiry dated:  
Project:  
Quotation-no.: 075212  
Item: Dry Cooler  
Reference: AS

Drycooler		S-GFH 067A/3-N(2)-F6/6P.M	
Capacity:	360000 Btu/h	Medium:	Water (R718)
Surface reserve:	2.1 %	Inlet:	127.1 °F
Air flow:	22379 cfm	Outlet:	115.0 °F
Air velocity:	716 ft/min	Pressure drop:	8.15 psi
Air inlet:	100.0 °F	Volume flow:	60.00 gpm
Altitude:	1000.000 ft	Mass flow:	29691 lb/h
Heat transf. coeff.:	6.81 Btu/(h-ft <sup>2</sup> -°F)	Fans:	3 Piece(s) 3~460V 60Hz
		Data per motor (nominal data):	Fan diameter: 25 9/16 in
		Speed: 1300 rpm	Noise pressure level: 59 dB(A)
		Capacity: 1.83 kW, 2 hp mech.	at a distance of: 32.8 ft
		Current: 2.80 A	
Casing:	Galv. Steel, light grey	Tubes:	Stainl. Steel AISI 304 <sup>(1)</sup>
Surface:	4300 ft <sup>2</sup>	Fins:	Epoxy <sup>(1)</sup>
Tube volume:	1.488 ft <sup>3</sup>	Connections per unit:	
Fin spacing:	12.7 FPI	Inlet:	2" NPS
Dry weight:	733 lb <sup>(2)</sup>	Outlet:	2" NPS
Max. operating pressure:	232.1 psi		
Dimensions: <sup>(2)</sup>		Outlet header:	2" NPS
Length:	115 9/16 in	Inlet header:	2" NPS
Width:	45 1/16 in	Face Area:	30.8 ft <sup>2</sup>
Height:	37 3/8 in <sup>(2)</sup>	Circuits:	1N
No. of legs:	4	Distributions:	21

(S = Special coil, Special fan VT03017U, 1 3~400V 5060Hz)

Page 1 of 2


075212 Dry Cooler

C:AM Professional, 2018, 36-185a/2019-02-15, PL 2/2019



S-GFH 067A/3-N(2)-F6/6P.M

Project:  
 Quotation-no.: 075212  
 Item: Dry Cooler  
 Reference: AS



File: EMPsk3\_INCH.emf

L = 109 1/4 in      B = 45 1/16 in      H = 37 3/8 in  
 R = 4 5/16 in      L1 = 106 5/16 in      H1 = 15 3/4 in  
 S = 1 15/16 in

Attention: Drawing and dimensions not valid for all accessory options!

Accessories	Piece(s)
Special design	1
Extra accessories	
EC Fan Motors	3
Mounted Panel#CECC03 - 0280ML - NAUBUNN - N	1
1 x GMM EC/04 UL RD;	
3 x MSP, 2.5-4.0A, 1HP;	
1 x Non Fused Disconnect, Nema 4X, 30 A;	
1 x Control Transformer 230/460 - 115 VAC /300VA, 50/60Hz;	
1 x Panel Heater 200W 120V;	
1 x Temperature Sensor for Güntner Controller;	
1 x NEMA 4 Steel Enclosure (WxHxD) 600x800x250 [mm] / 23.62x31.5x9.84 [Inch];	
1 x Cabinet Mounting Kit 600;	
Panel Data:	
Operating Range = -40°C to 44.2°C / -40°F to 111.56°F	
Electrical Power = 3/460V/60Hz - Y	
Control Voltage = 115VAC 50/60Hz	
Largest Load [A] = 2.8	
FLA [A] = 8.4	
MCA [A] = 9.1	
MOP [A] = 10	

**Important remarks / explanatory notes:**

- (1) The unit may not be suitable for very corrosive atmospheres (close to shores, in smoke rooms, etc.). For further information see program menu "2", "Material recommendations brochure", or ask your sales partner.
- (2) Dimensions and weights are not valid for all possible options! They may differ for units with accessories or special units (S-...).

GPC-AM Professional, 2018.36-189a/2019-02-15, PL 2/2019 · 075212 Dry Cooler · Page 2 of 2

## **Attachment E: Cost Estimating**

---



## Estimate Detail Report

1/30/2019 8:29 AM

BC Project Number: 150811.009.091  
Estimate Version Number: 2  
Estimate Date: 1-30-2019  
Lead Estimator: Ryan Manocchio

<b>Estimator</b>	Ryan Manocchio
<b>BC Project Manager</b>	Harold Voth
<b>BC Office</b>	Saint Paul
<b>Est Version Number</b>	2
<b>QA/QC Reviewer</b>	William Agster
<b>QA/QC Review Date</b>	1-25-2019
<b>BC Project Number</b>	150811.009.091



# Estimate Detail Report

1/30/2019 8:29 AM  
 BC Project Number: 150811.009.091  
 Estimate Version Number: 2  
 Estimate Date: 1-30-2019  
 Lead Estimator: Ryan Manocchio

Spreadsheet Level	Item	Phase	Quantity	Labor Cost/Unit	Material Cost/Unit	Sub Cost/Unit	Equip Cost/Unit	Other Cost/Unit	Total Cost/Unit	Total Amount
<b>01 TOTALS</b>										
<b>01 Disinfection and Effluent Modifications</b>										
<b>01 Bypass Pumping</b>										
<b>33999 Bypass Pumping</b>										
	72" Inflatable Pipe Plug	BC-0176	33-01-10.21	1.00 ea	250.06 /ea	6,464.00 /ea	-	-	6,714.06 /ea	6,714
	Bypass pumping, 30 days. 15,000gpm sewage flow @ suction lift 10'. 24" dia. byp	BC-0106	46-06-20.00	1.00 ls	40,933.13 /ls	-	57,137.89 /ls	-	98,071.02 /ls	98,071
	<b>Bypass Pumping</b>			<b>1.00 LS</b>	<b>41,183.19 /LS</b>	<b>6,464.00 /LS</b>	<b>57,137.89 /LS</b>	<b>/LS</b>	<b>104,785.08 /LS</b>	<b>104,785</b>
	<b>01 Bypass Pumping</b>									<b>104,785</b>
<b>02 Concrete Flume</b>										
<b>03330 Slab on Grade, 9" Thick</b>										
	Aggregate, stone, 3/4" to 1-1/2", prices per C.Y., includes material only		1050 03-05-13.25	2.22 cy	-	33.50 /cy	-	-	33.50 /cy	74
	C.I.P. concrete forms, slab on grade, edge, wood, 7" to 12" high, 4 use, includes en		3050 03-11-13.65	34.50 sfca	5.91 /sfca	0.69 /sfca	-	-	6.60 /sfca	228
	Reinforcing steel, in place, slab on grade, #3 to #7, A615, grade 60, incl labor for ac		0600 03-21-10.60	0.15 ton	1,361.50 /ton	960.00 /ton	-	-	2,321.50 /ton	348
	Reinforcing in place, unloading & sorting, add to above - slabs		2005 03-21-10.60	0.15 ton	52.87 /ton	-	6.00 /ton	-	58.87 /ton	9
	Structural concrete, ready mix, normal weight, 4000 psi, includes local aggregate, sanc		0300 03-31-05.35	3.50 cy	-	128.00 /cy	-	-	128.00 /cy	448
	Structural concrete, placing, slab on grade, direct chute, over 6" thick, includes vibr		4600 03-31-05.70	3.50 cy	21.36 /cy	-	0.32 /cy	-	21.67 /cy	76
	Concrete finishing, floors, monolithic, screed and bull float (darby) finish		0100 03-35-29.30	120.00 sf	0.46 /sf	-	-	-	0.46 /sf	56
	Concrete finishing, floor, dustproofing, solvent-based, 1 coat		3800 03-35-29.30	120.00 sf	0.34 /sf	-	-	-	0.50 /sf	60
	Curing, sprayed membrane curing compound		0300 03-39-13.50	1.20 csf	11.98 /csf	12.10 /csf	-	-	24.08 /csf	29
	Fine grading, fine grade for slab on grade, machine		1100 31-22-16.10	13.33 sy	1.20 /sy	-	0.63 /sy	-	1.83 /sy	24
	<b>Slab on Grade, 9" Thick</b>			<b>120.00 cy</b>	<b>5.15 /cy</b>	<b>6.03 /cy</b>	<b>/cy</b>	<b>0.09 /cy</b>	<b>11.27 /cy</b>	<b>1,352</b>
<b>03345 Concrete Walls, 9" Thick</b>										
	C.I.P. concrete forms, wall, job built, plywood, over 8' to 16' high, 4 use, includes en		2550 03-11-13.85	1,196.00 sfca	9.97 /sfca	0.78 /sfca	-	-	10.75 /sfca	12,862
	Form oil, up to 800 S.F. per gallon, coverage, includes material only		3050 03-15-05.95	3.19 gal	-	21.50 /gal	-	-	21.50 /gal	69
	Reinforcing steel, in place, walls, #3 to #7, A615, grade 60, incl labor for accessorie		0700 03-21-10.60	0.75 ton	1,043.82 /ton	960.00 /ton	-	-	2,003.82 /ton	1,499
	Reinforcing in place, unloading & sorting, add - walls, cols, beams		2010 03-21-10.60	0.75 ton	52.87 /ton	-	6.03 /ton	-	58.90 /ton	44
	Structural concrete, ready mix, normal weight, 4000 psi, includes local aggregate, sanc		0300 03-31-05.35	17.44 cy	-	128.00 /cy	-	-	128.00 /cy	2,233
	Structural concrete, placing, walls, direct chute, 15" thick, includes vibrating, exclud		5300 03-31-05.70	17.44 cy	33.56 /cy	-	0.50 /cy	-	34.06 /cy	594
	Finishing: break ties & patch voids (walls, cols or beams)		0010 03-35-29.60	1,196.00 sf	1.19 /sf	0.04 /sf	-	-	1.23 /sf	1,472
	<b>Concrete Walls, 9" Thick</b>			<b>598.00 cy</b>	<b>24.68 /cy</b>	<b>6.69 /cy</b>	<b>/cy</b>	<b>0.02 /cy</b>	<b>31.39 /cy</b>	<b>18,773</b>
<b>05999 Handrail and Ladder</b>										
	Ladder, shop fabricated, steel, 20" W, bolted to concrete, excl cage		0100 05-51-33.13	10.00 vif	40.42 /vif	36.50 /vif	-	1.18 /vif	78.10 /vif	781
	Hand rail, aluminum, 3 rail		1500 09-69-13.10	34.00 lf	44.46 /lf	117.00 /lf	-	-	161.46 /lf	5,489
	<b>Handrail and Ladder</b>			<b>1.00 ls</b>	<b>1,915.69 /ls</b>	<b>4,343.00 /ls</b>	<b>/ls</b>	<b>11.81 /ls</b>	<b>6,270.50 /ls</b>	<b>6,271</b>
<b>26001 Electrical and Instrumentation</b>										
	Level transmitter and power/control wiring, allowance	FACTORED	26-00-00.02	1.00 ls	-	5,000.00 /ls	-	-	5,000.00 /ls	5,000
	<b>Electrical and Instrumentation</b>			<b>1.00 ls</b>	<b>/ls</b>	<b>5,000.00 /ls</b>	<b>/ls</b>	<b>/ls</b>	<b>5,000.00 /ls</b>	<b>5,000</b>
<b>31315 Excavation and Backfill</b>										
	Mobilization or demobilization, dozer, loader, backhoe or excavator, 70 H.P. to 150		0020 01-54-36.50	2.00 ea	160.75 /ea	-	83.67 /ea	-	244.42 /ea	489
	Soils for earthwork, common borrow, spread with 200 HP dozer, includes load at pit		0200 31-05-13.10	252.78 cy	3.62 /cy	12.75 /cy	-	-	20.38 /cy	5,153
	Excavating, bulk bank measure, 3 C.Y. capacity = 260 C.Y./hour, backhoe, hydraul		0300 31-23-16.42	252.78 bcy	0.61 /bcy	-	1.08 /bcy	-	1.69 /bcy	427
	Hauling, excavated or borrow material, loose cubic yards, 10 mile round trip, 0.6 lo		1120 31-23-23.18	349.07 lcy	7.55 /lcy	-	7.77 /lcy	-	15.32 /lcy	5,347
	<b>Excavation and Backfill</b>			<b>349.07 cy</b>	<b>11.54 /cy</b>	<b>9.23 /cy</b>	<b>/cy</b>	<b>11.93 /cy</b>	<b>32.70 /cy</b>	<b>11,415</b>
<b>32740 Sidewalks, 4" Thick</b>										
	Fine grading, for roadway, base or leveling course, large area, 6,000 S.Y. or more		0100 31-22-16.10	15.00 sy	0.63 /sy	-	0.33 /sy	-	0.95 /sy	14
	Sidewalks, driveways, and patios, sidewalk, concrete, cast-in-place with 6 x 6 - W1.		0310 32-06-10.10	135.00 sf	3.13 /sf	2.01 /sf	-	-	5.14 /sf	694
	Sidewalks, driveways, and patios, sidewalks, concrete, excludes base, for 4" thick t		0450 32-06-10.10	135.00 sf	0.70 /sf	0.43 /sf	-	0.02 /sf	1.14 /sf	154
	<b>Sidewalks, 4" Thick</b>			<b>135.00 sf</b>	<b>3.90 /sf</b>	<b>2.44 /sf</b>	<b>/sf</b>	<b>0.05 /sf</b>	<b>6.39 /sf</b>	<b>863</b>
<b>33999 FRP Insert</b>										
	Cncr blk, fndt wall, trwl cut jnts, nrml wt, sold, 2000 psi, 6"8"16", incld mortr and hrznt jc		0500 04-22-10.26	806.00 sf	7.07 /sf	2.99 /sf	-	-	10.06 /sf	8,112
	FRP insert, 48" Parshal Flume, see quote from Tracom	MISC	33-99-99.99	1.00 ls	800.00 /ls	7,540.00 /ls	-	200.00 /ls	8,540.00 /ls	8,540
	<b>FRP Insert</b>			<b>1.00 ls</b>	<b>6,501.85 /ls</b>	<b>9,949.94 /ls</b>	<b>/ls</b>	<b>200.00 /ls</b>	<b>16,651.79 /ls</b>	<b>16,652</b>



# Estimate Detail Report

1/30/2019 8:29 AM  
 BC Project Number: 150811.009.091  
 Estimate Version Number: 2  
 Estimate Date: 1-30-2019  
 Lead Estimator: Ryan Manocchio

Spreadsheet Level	Item	Phase	Quantity	Labor Cost/Unit	Material Cost/Unit	Sub Cost/Unit	Equip Cost/Unit	Other Cost/Unit	Total Cost/Unit	Total Amount
<b>02 Concrete Flume</b>										<b>60,325</b>
<b>03 Cascade Aeration Steps</b>										
<b>03330 Slab on Grade, 12" Thick</b>										
	Aggregate, stone, 3/4" to 1-1/2", prices per C.Y., includes material only	1050	03-05-13.25	19.44	cy	-	33.50	/cy	-	651
	C.I.P. concrete forms, slab on grade, edge, wood, 7" to 12" high, 4 use, includes en	3050	03-11-13.65	106.00	sfca	5.91	/sfca	0.69	/sfca	699
	Reinforcing steel, in place, slab on grade, #3 to #7, A615, grade 60, incl labor for ac	0600	03-21-10.60	1.17	ton	1,361.50	/ton	960.00	/ton	2,709
	Reinforcing in place, unloading & sorting, add to above - slabs	2005	03-21-10.60	1.17	ton	52.88	/ton	-	-	69
	Structural concrete, ready mix, normal weight, 4000 psi, includes local aggregate, sanc	0300	03-31-05.35	27.22	cy	-	128.00	/cy	-	3,484
	Structural concrete, placing, slab on grade, pumped, over 6" thick, includes vibratin	4650	03-31-05.70	27.22	cy	25.81	/cy	5.14	/cy	843
	Concrete finishing, floors, monolithic, screed and bull float(darby) finish	0100	03-35-29.30	700.00	sf	0.46	/sf	-	-	325
	Concrete finishing, floor, dustproofing, solvent-based, 1 coat	3800	03-35-29.30	700.00	sf	0.34	/sf	0.16	/sf	349
	Curing, sprayed membrane curing compound	0300	03-39-13.50	7.00	csf	11.97	/csf	12.10	/csf	169
	Fine grading, fine grade for slab on grade, machine	1100	31-22-16.10	77.78	sy	1.20	/sy	-	-	143
	<b>Slab on Grade, 12" Thick</b>			<b>700.00</b>	<b>cy</b>	<b>5.31</b>	<b>/cy</b>	<b>7.89</b>	<b>/cy</b>	<b>9,440</b>
<b>03345 Concrete Walls, 5' x 20' x 12"</b>										
	C.I.P. concrete forms, wall, job built, plywood, over 8' to 16' high, 1 use, includes en	2400	03-11-13.85	400.00	sfca	14.07	/sfca	3.05	/sfca	6,848
	Form oil, up to 800 S.F. per gallon, coverage, includes material only	3050	03-15-05.95	1.07	gal	-	-	21.50	/gal	23
	Reinforcing steel, in place, walls, #3 to #7, A615, grade 60, incl labor for accessorie	0700	03-21-10.60	0.33	ton	1,043.80	/ton	960.00	/ton	667
	Reinforcing in place, unloading & sorting, add - walls, cols, beams	2010	03-21-10.60	0.33	ton	52.88	/ton	-	-	20
	Structural concrete, ready mix, normal weight, 4500 psi, includes local aggregate, sanc	0350	03-31-05.35	7.78	cy	-	131.00	/cy	-	1,019
	Structural concrete, placing, walls, pumped, 15" thick, includes vibrating, excludes r	5350	03-31-05.70	7.78	cy	39.79	/cy	7.93	/cy	371
	Finishing: break ties & patch voids (walls, cols or beams)	0010	03-35-29.60	400.00	sf	1.19	/sf	0.04	/sf	492
	<b>Concrete Walls, 5' x 20' x 12"</b>			<b>200.00</b>	<b>cy</b>	<b>33.90</b>	<b>/cy</b>	<b>12.99</b>	<b>/cy</b>	<b>9,441</b>
<b>03345 Concrete Walls, 15' x 50' x 12"</b>										
	C.I.P. concrete forms, wall, job built, plywood, over 8' to 16' high, 1 use, includes en	2400	03-11-13.85	3,000.00	sfca	14.07	/sfca	3.05	/sfca	51,363
	Form oil, up to 800 S.F. per gallon, coverage, includes material only	3050	03-15-05.95	8.00	gal	-	-	21.50	/gal	172
	Reinforcing steel, in place, walls, #3 to #7, A615, grade 60, incl labor for accessorie	0700	03-21-10.60	2.50	ton	1,043.82	/ton	960.00	/ton	5,010
	Reinforcing in place, unloading & sorting, add - walls, cols, beams	2010	03-21-10.60	2.50	ton	52.88	/ton	-	-	147
	Structural concrete, ready mix, normal weight, 4500 psi, includes local aggregate, sanc	0350	03-31-05.35	58.33	cy	-	131.00	/cy	-	7,642
	Structural concrete, placing, walls, pumped, 15" thick, includes vibrating, excludes r	5350	03-31-05.70	58.33	cy	39.79	/cy	7.93	/cy	2,784
	Finishing: break ties & patch voids (walls, cols or beams)	0010	03-35-29.60	3,000.00	sf	1.19	/sf	0.04	/sf	3,693
	<b>Concrete Walls, 15' x 50' x 12"</b>			<b>1,500.00</b>	<b>cy</b>	<b>33.90</b>	<b>/cy</b>	<b>12.99</b>	<b>/cy</b>	<b>70,811</b>
<b>13999 Misc. Special Construction Work</b>										
	Weir plate, fiberglass, with slots	BC-0001	06-62-10.00	20.00	sqft	26.45	/sqft	18.41	/sqft	897
	<b>Misc. Special Construction Work</b>			<b>1.00</b>	<b>ls</b>	<b>529.08</b>	<b>/ls</b>	<b>368.20</b>	<b>/ls</b>	<b>897</b>
<b>31315 Excavation and Backfill</b>										
	Mobilization or demobilization, dozer, loader, backhoe or excavator, 70 H.P. to 150	0020	01-54-36.50	2.00	ea	160.75	/ea	-	-	489
	Soils for earthwork, common borrow, spread with 200 HP dozer, includes load at pit	0200	31-05-13.10	4,642.59	cy	3.62	/cy	4.01	/cy	94,633
	Excavating, bulk bank measure, 3 C.Y. capacity = 260 C.Y./hour, backhoe, hydraul	0300	31-23-16.42	4,642.59	bcy	0.61	/bcy	1.08	/bcy	7,846
	Hauling, excavated or borrow material, loose cubic yards, 10 mile round trip, 0.6 lo	1120	31-23-23.18	6,346.30	cy	7.55	/cy	7.77	/cy	97,208
	<b>Excavation and Backfill</b>			<b>6,346.30</b>	<b>cy</b>	<b>10.70</b>	<b>/cy</b>	<b>9.33</b>	<b>/cy</b>	<b>200,176</b>
<b>32740 Sidewalks, 4" Thick</b>										
	Fine grading, for roadway, base or leveling course, large area, 6,000 S.Y. or more	0100	31-22-16.10	15.00	sy	0.63	/sy	-	-	14
	Sidewalks, driveways, and patios, sidewalk, concrete, cast-in-place with 6 x 6 - W1.	0310	32-06-10.10	135.00	sf	3.13	/sf	2.01	/sf	694
	Sidewalks, driveways, and patios, sidewalks, concrete, excludes base, for 4" thick t	0450	32-06-10.10	135.00	sf	0.70	/sf	0.43	/sf	154
	<b>Sidewalks, 4" Thick</b>			<b>135.00</b>	<b>sf</b>	<b>3.90</b>	<b>/sf</b>	<b>2.44</b>	<b>/sf</b>	<b>863</b>
<b>03 Cascade Aeration Steps</b>										<b>291,628</b>
<b>04 Remove and Replace 72" RCP</b>										
<b>32920 Soil Prep and Seeding</b>										
	Rake topsoil, site material, by hand	X9010	32-91-19.13	4.20	msf	56.87	/msf	-	-	239
	Spread conditioned topsoil, skid steer loader and hand dress	X9020	32-91-19.13	51.85	cy	6.46	/cy	11.34	/cy	923
	Seeding, mechanical seeding, 44 lb/M.S.Y.	0100	32-92-19.13	466.67	sy	0.26	/sy	0.20	/sy	263
	<b>Soil Prep and Seeding</b>			<b>4,200.00</b>	<b>sf</b>	<b>0.17</b>	<b>/sf</b>	<b>0.16</b>	<b>/sf</b>	<b>1,425</b>



# Estimate Detail Report

1/30/2019 8:29 AM

BC Project Number: 150811.009.091

Estimate Version Number: 2

Estimate Date: 1-30-2019

Lead Estimator: Ryan Manocchio

Spreadsheet Level	Item	Phase	Quantity	Labor Cost/Unit	Material Cost/Unit	Sub Cost/Unit	Equip Cost/Unit	Other Cost/Unit	Total Cost/Unit	Total Amount
<b>33500 Trench for Utilities, 72" RCP at 20' Deep</b>										
	Excavating, trench or continuous footing, common earth, 1-1/2 C.Y. excavator, 14' t	1310 31-23-16.13	2,037.04 bcy	2.66 /bcy	-	-	1.90 /bcy	-	4.55 /bcy	9,277
	Backfill, trench, 6" to 12" lifts, dozer backfilling, compaction with sheepsfoot roller	2300 31-23-23.13	1,749.06 ecy	1.49 /ecy	-	-	2.67 /ecy	-	4.15 /ecy	7,264
	Hauling, excavated or borrow material, loose cubic yards, 3 mile round trip, 2.1 loac	0150 31-23-23.18	287.98 lcy	7.55 /lcy	-	-	4.32 /lcy	-	11.87 /lcy	3,417
	Trench box and jacks, cost per sfca trench wall, monthly rental	X9010 31-41-13.10	800.00 sf	-	-	7.81 /sf	-	-	7.81 /sf	6,249
	Utility line signs, markers, and flags, underground tape, detectable, reinforced, alur	0400 33-05-97.10	3.00 clf	3.79 /clf	9.00 /clf	-	-	-	12.79 /clf	38
	<b>Trench for Utilities, 72" RCP at 20' Deep</b>		<b>275.00 lf</b>	<b>37.07 /lf</b>	<b>0.10 /lf</b>	<b>22.72 /lf</b>	<b>35.55 /lf</b>	<b>/lf</b>	<b>95.44 /lf</b>	<b>26,245</b>
<b>33530 72" RCP Outfall Pipe</b>										
	Utility removal, pipe, sewer/water, 72" diameter, remove, excludes excavation	3000 02-41-13.23	275.00 lf	20.48 /lf	-	-	23.99 /lf	-	44.47 /lf	12,228
	Connect inlet to existing 72" outfall	BC-0126 22-05-00.10	1.00 ea	1,559.38 /ea	559.44 /ea	-	120.77 /ea	-	2,239.59 /ea	2,240
	Public storm utility drainage piping, reinforced concrete pipe (RCP), 72" diameter, 8	2100 33-41-13.60	275.00 lf	105.41 /lf	283.00 /lf	-	25.34 /lf	-	413.75 /lf	113,781
	<b>72" RCP Outfall Pipe</b>		<b>275.00 lf</b>	<b>131.56 /lf</b>	<b>285.03 /lf</b>	<b>/lf</b>	<b>49.77 /lf</b>	<b>/lf</b>	<b>466.36 /lf</b>	<b>128,249</b>
<b>04 Remove and Replace 72" RCP</b>										
<b>155,919</b>										
<b>05 Outfall Bulkhead</b>										
<b>33635 Outfall/Headwall</b>										
	Excavate pit, common earth, hyd backhoe, 3/4 CY bucket	X9010 31-23-16.13	106.67 cy	14.16 /cy	-	-	7.59 /cy	-	21.75 /cy	2,320
	Backfill, trench, air tamped compaction, add	2000 31-23-23.13	91.73 ecy	15.32 /ecy	-	-	3.64 /ecy	-	18.96 /ecy	1,739
	Hauling, excavated or borrow material, loose cubic yards, 3 mile round trip, 2.1 loac	0150 31-23-23.18	14.94 lcy	7.55 /lcy	-	-	4.32 /lcy	-	11.87 /lcy	177
	Headwall and tapered wings, form, reinf., place/finish, 8" thick	X9050 33-49-13.10	4.00 cy	1,095.49 /cy	178.00 /cy	-	60.57 /cy	-	1,334.06 /cy	5,336
	<b>Outfall/Headwall</b>		<b>1.00 ea</b>	<b>7,410.88 /ea</b>	<b>712.00 /ea</b>	<b>/ea</b>	<b>1,449.71 /ea</b>	<b>/ea</b>	<b>9,572.59 /ea</b>	<b>9,573</b>
<b>05 Outfall Bulkhead</b>										
<b>9,573</b>										
<b>06 Transition Structures</b>										
<b>33999 Transition Structures</b>										
	Transition structure, from 72" pipe to concrete channel flume, allowance	MISC 33-99-99.99	1.00 ea	5,000.00 /ea	15,000.00 /ea	-	2,500.00 /ea	-	22,500.00 /ea	22,500
	Transition structure, from flume to concrete steps, allowance	MISC 33-99-99.99	1.00 ea	5,000.00 /ea	15,000.00 /ea	-	2,500.00 /ea	-	22,500.00 /ea	22,500
	<b>Transition Structures</b>		<b>1.00 ea</b>	<b>10,000.00 /ea</b>	<b>30,000.00 /ea</b>	<b>/ea</b>	<b>5,000.00 /ea</b>	<b>/ea</b>	<b>45,000.00 /ea</b>	<b>45,000</b>
<b>06 Transition Structures</b>										
<b>45,000</b>										
<b>07 PVC Piping</b>										
<b>40500 PVC Piping Sch 80, 2" Diameter</b>										
	Pipe, plastic, with fittings, 1" thru 3" diameter, selective demolition	2162 22-05-05.10	1,170.00 lf	4.04 /lf	-	-	-	-	4.04 /lf	4,723
	Demo ejector system	2194 22-05-05.10	3.00 ea	4,596.91 /ea	-	-	-	-	4,596.91 /ea	13,791
	Heat trace, allowance	4050 23-83-33.10	1.00 ls	-	-	1,500.00 /ls	-	-	1,500.00 /ls	1,500
	Pipe Plain End-PVC--Sch 80 2 Inch (50mm), and 3" containment pipe	1120 33-52-13.16	1,170.00 lf	6.15 /lf	25.50 /lf	-	-	-	31.65 /lf	37,033
	Pipe Erection-Make Up Cemented Plastic Socket Joint-Non-Specific 2 Inch (50mm)	L093461000000 40-05-05.00	48.00 ea	58.12 /ea	-	-	-	-	58.12 /ea	2,790
	Pipe Erection-Handle Fittings-Plastic-Sch 80 2 Inch (50mm)	L093466100001 40-05-05.00	24.00 ea	10.95 /ea	-	-	-	-	10.95 /ea	263
	Field Testing-Hydrotest-Non-Specific 2 Inch (50mm)	L099048000000 40-05-05.00	1,170.00 lf	1.45 /lf	-	-	-	-	1.45 /lf	1,700
	Hilti-Chemical Anchor - Pipe Support Size 2 Inch (50mm)	A096043000000 40-05-07.00	48.00 ea	19.37 /ea	10.00 /ea	-	-	-	29.37 /ea	1,410
	Pipe Support 2 Inch (50mm)	A096044000000 40-05-07.00	48.00 ea	48.44 /ea	12.00 /ea	-	-	-	60.44 /ea	2,901
	Hanger Rod 2 Inch (50mm)	A096045000000 40-05-07.00	48.00 ea	29.06 /ea	15.00 /ea	-	-	-	44.06 /ea	2,115
	Fitting Socket Weld-PVC-ElI90-Sch 80 2 Inch (50mm)	A092212100000 40-05-31.13	24.00 ea	-	18.65 /ea	-	-	-	18.65 /ea	448
	Pipe Erection-Straight Run-PVC-Sch 80 2 Inch (50mm)	L0940021000P1 40-05-31.13	1,170.00 lf	8.14 /lf	-	-	-	-	8.14 /lf	9,520
	<b>PVC Piping Sch 80, 2" Diameter</b>		<b>1,170.00 lf</b>	<b>38.15 /lf</b>	<b>27.40 /lf</b>	<b>1.28 /lf</b>	<b>/lf</b>	<b>/lf</b>	<b>66.83 /lf</b>	<b>78,193</b>
<b>07 PVC Piping</b>										
<b>78,193</b>										
<b>07a Misc. Equipment</b>										
<b>11999 Misc. Equipment</b>										
	Chlorination equipment, see quote from Vesco	MISC 11-99-99.99	1.00 ls	5,625.00 /ls	-	75,000.00 /ls	1,500.00 /ls	-	82,125.00 /ls	82,125
	<b>Misc. Equipment</b>		<b>1.00 ls</b>	<b>5,625.00 /ls</b>	<b>/ls</b>	<b>75,000.00 /ls</b>	<b>1,500.00 /ls</b>	<b>/ls</b>	<b>82,125.00 /ls</b>	<b>82,125</b>
<b>07a Misc. Equipment</b>										
<b>82,125</b>										
<b>01 Disinfection and Effluent Modifications</b>										
<b>827,548</b>										
<b>02 Biogas Flare and Piping</b>										
<b>08 Slab On Grade</b>										





# Estimate Detail Report

1/30/2019 8:29 AM  
 BC Project Number: 150811.009.091  
 Estimate Version Number: 2  
 Estimate Date: 1-30-2019  
 Lead Estimator: Ryan Manocchio

Spreadsheet Level	Item	Phase	Quantity	Labor Cost/Unit	Material Cost/Unit	Sub Cost/Unit	Equip Cost/Unit	Other Cost/Unit	Total Cost/Unit	Total Amount
<b>03330 Slab On Grade, 8' x 20' x 9"</b>										
	Aggregate, stone, 3/4" to 1-1/2", prices per C.Y., includes material only	1050	03-05-13.25	2.96 cy	-	33.50 /cy	-	-	33.50 /cy	99
	C.I.P. concrete forms, slab on grade, edge, wood, 7" to 12" high, 4 use, includes en	3050	03-11-13.65	42.00 sfca	5.91 /sfca	0.69 /sfca	-	-	6.60 /sfca	277
	Sawcut control joints, slab on grade	X9000	03-15-05.25	28.00 lf	0.78 /lf	0.75 /lf	0.27 /lf	-	1.79 /lf	50
	Reinforcing steel, in place, slab on grade, #3 to #7, A615, grade 60, incl labor for ac	0600	03-21-10.60	0.20 ton	1,361.50 /ton	960.00 /ton	-	-	2,321.50 /ton	464
	Reinforcing in place, unloading & sorting, add to above - slabs	2005	03-21-10.60	0.20 ton	52.90 /ton	-	6.00 /ton	-	58.90 /ton	12
	Structural concrete, ready mix, normal weight, 4000 psi, includes local aggregate, sanc	0300	03-31-05.35	4.67 cy	-	128.00 /cy	-	-	128.00 /cy	597
	Structural concrete, placing, slab on grade, direct chute, over 6" thick, includes vibr	4600	03-31-05.70	4.67 cy	21.36 /cy	-	0.32 /cy	-	21.68 /cy	101
	Concrete finishing, floors, monolithic, screed, float and broom finish	0150	03-35-29.30	160.00 sf	1.00 /sf	-	-	-	1.00 /sf	160
	Concrete finishing, floor, dustproofing, solvent-based, 1 coat	3800	03-35-29.30	160.00 sf	0.34 /sf	0.16 /sf	-	-	0.50 /sf	80
	Curing, sprayed membrane curing compound	0300	03-39-13.50	1.60 csf	11.98 /csf	12.10 /csf	-	-	24.08 /csf	39
	Fine grading, fine grade for slab on grade, machine	1100	31-22-16.10	17.78 sy	1.20 /sy	-	0.63 /sy	-	1.83 /sy	33
	<b>Slab On Grade, 8' x 20' x 9"</b>			<b>160.00 cy</b>	<b>5.67 /cy</b>	<b>6.15 /cy</b>	<b>0.13 /cy</b>	<b>0.13 /cy</b>	<b>11.95 /cy</b>	<b>1,912</b>
	<b>08 Slab On Grade</b>									<b>1,912</b>

## 09 Piping

<b>32920 Seeding</b>										
	Rake topsoil, site material, by hand	X9010	32-91-19.13	7.00 msf	56.87 /msf	-	-	-	56.87 /msf	398
	Spread conditioned topsoil, skid steer loader and hand dress	X9020	32-91-19.13	86.42 cy	6.46 /cy	11.34 /cy	-	-	17.80 /cy	1,539
	Seeding, mechanical seeding, 44 lb/M.S.Y.	0100	32-92-19.13	777.78 sy	0.26 /sy	0.20 /sy	0.10 /sy	-	0.56 /sy	438
	<b>Seeding</b>			<b>7,000.00 sf</b>	<b>0.17 /sf</b>	<b>0.16 /sf</b>	<b>0.01 /sf</b>	<b>0.01 /sf</b>	<b>0.34 /sf</b>	<b>2,375</b>

## 33500 Trench for Utilities

	Excavating, trench or continuous footing, common earth, 3/4 C.Y. excavator, 4' to 6	0110	31-23-16.13	1,057.41 bcy	4.25 /bcy	-	2.28 /bcy	-	6.53 /bcy	6,899
	Backfill, trench, 6" to 12" lifts, dozer backfilling, compaction with sheepsfoot roller	2300	31-23-23.13	982.66 ecy	1.49 /ecy	-	2.67 /ecy	-	4.15 /ecy	4,081
	Hauling, excavated or borrow material, loose cubic yards, 3 mile round trip, 2.1 loa	0150	31-23-23.18	74.74 lcy	7.55 /lcy	-	4.32 /lcy	-	11.87 /lcy	887
	Trench box and jacks, cost per sfca trench wall, monthly rental	X9010	31-41-13.10	200.00 sf	-	7.81 /sf	-	-	7.81 /sf	1,562
	Utility line signs, markers, and flags, underground tape, detectable, reinforced, alur	0400	33-05-97.10	11.00 clf	3.79 /clf	9.00 /clf	-	-	12.79 /clf	141
	<b>Trench for Utilities</b>			<b>1,142.00 lf</b>	<b>5.74 /lf</b>	<b>0.09 /lf</b>	<b>1.37 /lf</b>	<b>4.69 /lf</b>	<b>11.88 /lf</b>	<b>13,570</b>

## 40500 PVC Piping Sch 80, 1" NG

	Pipe Erection-Make Up Cemented Plastic Socket Joint-Non-Specific 1 Inch (25mr	L063461000000	40-05-05.00	4.00 ea	48.44 /ea	-	-	-	48.44 /ea	194
	Pipe Erection-Handle Fittings-Plastic-Sch 80 1 Inch (25mm)	L063466100001	40-05-05.00	2.00 ea	7.66 /ea	-	-	-	7.66 /ea	15
	Field Testing-Hydrotest-Non-Specific 1 Inch (25mm)	L069048000000	40-05-05.00	442.00 lf	1.16 /lf	-	-	-	1.16 /lf	514
	Pipe Plain End-PVC--Sch 80 1 Inch (25mm)	A061002100000	40-05-31.13	442.00 lf	-	0.78 /lf	-	-	0.78 /lf	345
	Fitting Socket Weld-PVC-EI90-Sch 80 1 Inch (25mm)	A062212100000	40-05-31.13	2.00 ea	-	6.50 /ea	-	-	6.50 /ea	13
	Pipe Erection-Straight Run-PVC-Sch 80 1 Inch (25mm)	L0640021000P1	40-05-31.13	442.00 lf	8.14 /lf	-	-	-	8.14 /lf	3,597
	<b>PVC Piping Sch 80, 1" NG</b>			<b>442.00 lf</b>	<b>9.77 /lf</b>	<b>0.81 /lf</b>	<b>0.78 /lf</b>	<b>0.78 /lf</b>	<b>10.58 /lf</b>	<b>4,677</b>

## 40525 HDPE Piping, 18" SDR 11

	Pipe Erection-Make Up Cemented Plastic Socket Joint-Non-Specific 18 Inch (450	L213461000000	40-05-05.00	8.00 ea	87.18 /ea	-	-	-	87.18 /ea	697
	Pipe Erection-Handle Fittings-Plastic-Non-Specific 18 Inch (450mm)	L213466000001	40-05-05.00	4.00 ea	87.18 /ea	-	-	-	87.18 /ea	349
	Field Cut & Roll Grooved Joint-Std 18 Inch (450mm)	L216064010000	40-05-05.00	8.00 ea	334.20 /ea	-	-	-	334.20 /ea	2,674
	Field Testing-Hydrotest-Non-Specific 18 Inch (450mm)	L219048000000	40-05-05.00	700.00 lf	29.26 /lf	-	-	-	29.26 /lf	20,478
	Pipe Plain End-HDPE--SDR11 18 Inch (450mm)	A211002a20000	40-05-33.00	700.00 lf	-	39.36 /lf	3.00 /lf	-	42.36 /lf	29,652
	Fitting Socket Weld-HDPE-EI90-SDR11 18 Inch (450mm)	A212212a20000	40-05-33.00	4.00 ea	-	435.53 /ea	-	-	435.53 /ea	1,742
	Pipe Erection-Straight Run-HDPE-Non-Specific 18 Inch (450mm)	L2140020000P1	40-05-33.00	700.00 lf	34.87 /lf	-	3.00 /lf	-	37.87 /lf	26,511
	<b>HDPE Piping, 18" SDR 11</b>			<b>700.00 lf</b>	<b>69.44 /lf</b>	<b>41.85 /lf</b>	<b>6.00 /lf</b>	<b>6.00 /lf</b>	<b>117.29 /lf</b>	<b>82,103</b>

**09 Piping 102,726**

## 10 Equipment

### 11999 Biogas Flare Equipment

	Biogas flare equipment, see quote from Varec Biogas, dated 1-11-2019	MISC	11-99-99.99	1.00 ls	14,400.00 /ls	162,618.00 /ls	3,500.00 /ls	-	180,518.00 /ls	180,518
	<b>Biogas Flare Equipment</b>			<b>1.00 ls</b>	<b>14,400.00 /ls</b>	<b>162,618.00 /ls</b>	<b>3,500.00 /ls</b>	<b>3,500.00 /ls</b>	<b>180,518.00 /ls</b>	<b>180,518</b>

**10 Equipment 180,518**

## 11 Electrical and Instrumentation

### 26001 Electrical and Instrumentation

	Electrical, controls and SCADA, (10% factored)	FACTORED	26-00-00.02	1.00 ls	-	-	28,100.00 /ls	-	28,100.00 /ls	28,100
--	--	----------	-------------	---------	---	---	---------------	---	---------------	--------



# Estimate Detail Report

1/30/2019 8:29 AM

BC Project Number: 150811.009.091

Estimate Version Number: 2

Estimate Date: 1-30-2019

Lead Estimator: Ryan Manocchio

Spreadsheet Level	Item	Phase	Quantity	Labor Cost/Unit	Material Cost/Unit	Sub Cost/Unit	Equip Cost/Unit	Other Cost/Unit	Total Cost/Unit	Total Amount			
<b>Electrical and Instrumentation</b>			1.00	ls	/ls				28,100.00	28,100			
<b>11 Electrical and Instrumentation</b>										28,100			
<b>02 Biogas Flare and Piping</b>										313,256			
<b>03 Flow Splitting MLSS</b>													
<b>12 Alternative 2</b>													
<b>01999 Mobilization and Demobilization</b>													
	Mobilization	BC-0027	01-00-10.00	2.00	day	-	126.60	/day	-	126.60	253		
	Demobilization	BC-0028	01-00-10.00	2.00	day	-	126.60	/day	-	126.60	253		
	<b>Mobilization and Demobilization</b>		<b>1.00</b>	<b>ls</b>	<b>/ls</b>	<b>/ls</b>	<b>506.40</b>	<b>/ls</b>	<b>/ls</b>	<b>506.40</b>	<b>506</b>		
<b>02999 Misc Existing Conditions or Demolition</b>													
	Minor site demolition, pipe, sewer/water, 20" diameter, remove, excludes excavation	2960	02-41-13.33	200.00	lf	15.36	/lf	-	11.99	/lf	27.35	5,471	
	<b>Misc Existing Conditions or Demolition</b>		<b>1.00</b>	<b>ls</b>	<b>/ls</b>	<b>3,071.88</b>	<b>/ls</b>	<b>/ls</b>	<b>2,398.83</b>	<b>/ls</b>	<b>5,470.71</b>	<b>5,471</b>	
<b>40120 Ductile Iron Pipe, 32" Diameter</b>													
	Coatings & paints, B & C coating system E-1 (Epoxy, metal pipe)	BC-0001	09-91-06.41	1,675.52	sqft	0.94	/sqft	0.89	/sqft	-	1.83	3,068	
	Pipe Erection-Handle Fittings-Metal-Std 32 Inch (800mm)	L323466010000	40-05-05.00	3.00	ea	268.81	/ea	-	-	-	268.81	806	
	Field Testing-Hydrotest-Non-Specific 32 Inch (800mm)	L329048000000	40-05-05.00	200.00	lf	90.28	/lf	-	-	-	90.28	18,057	
	Hilti-Chemical Anchor - Pipe Support Size 32 Inch (800mm)	A326043000000	40-05-07.00	8.00	ea	48.44	/ea	65.00	/ea	-	113.44	907	
	Pipe Support 32 Inch (800mm)	A326044000000	40-05-07.00	2.00	ea	174.37	/ea	250.00	/ea	-	424.37	849	
	Hanger Rod 32 Inch (800mm)	A326045000000	40-05-07.00	2.00	ea	145.31	/ea	650.00	/ea	-	795.31	1,591	
	Pipe Plain End-Ductile Iron--C-151 32 Inch (800mm)	A321002200000	40-05-19.20	200.00	lf	-	-	315.00	/lf	12.00	327.00	65,400	
	Fitting Flanged & Bolted-Ductile Iron-ElI45-Non-Specific 32 Inch (800mm)	A322411000000	40-05-19.20	1.00	ea	-	-	12,116.71	/ea	-	12,416.71	12,417	
	Fitting Flanged & Bolted-Ductile Iron-ElI90-Non-Specific 32 Inch (800mm)	A322412000000	40-05-19.20	2.00	ea	-	-	8,827.00	/ea	-	9,127.00	18,254	
	Pipe Erection-Straight Run-Ductile Iron-Non-Specific 32 Inch (800mm)	L3240020000P1	40-05-19.20	200.00	lf	156.93	/lf	-	-	6.00	162.93	32,586	
	Pipe Erection-Handle Valves-Metal-Cls 150 (PN20) 32 Inch (800mm)	L324062006200	40-05-51.00	2.00	ea	809.64	/ea	-	-	-	809.64	1,619	
	<b>Ductile Iron Pipe, 32" Diameter</b>		<b>200.00</b>	<b>lf</b>	<b>/lf</b>	<b>272.38</b>	<b>/lf</b>	<b>482.89</b>	<b>/lf</b>	<b>/lf</b>	<b>22.50</b>	<b>777.77</b>	<b>155,554</b>
<b>40120 Ductile Iron Pipe, 54" Diameter</b>													
	Coatings & paints, B & C coating system E-1 (Epoxy, metal pipe)	BC-0001	09-91-06.41	1,272.35	sqft	0.94	/sqft	0.89	/sqft	-	1.83	2,330	
	Electrical, allowance	MISC	26-99-99.99	1.00	ls	-	-	80,000.00	/ls	-	80,000.00	80,000	
	Pipe Erection-Handle Fittings-Metal-Std 54 Inch (1350mm)	L543466010000	40-05-05.00	8.00	ea	428.65	/ea	-	-	-	428.65	3,429	
	Field Testing-Hydrotest-Non-Specific 54 Inch (1350mm)	L549048000000	40-05-05.00	90.00	lf	255.16	/lf	-	-	-	255.16	22,964	
	Hilti-Chemical Anchor - Pipe Support Size 54 Inch (1350mm)	A546043000000	40-05-07.00	4.00	ea	48.44	/ea	75.00	/ea	-	123.44	494	
	Pipe Support 54 Inch (1350mm)	A546044000000	40-05-07.00	1.00	ea	290.61	/ea	750.00	/ea	-	1,040.61	1,041	
	Hanger Rod 54 Inch (1350mm)	A546045000000	40-05-07.00	1.00	ea	193.74	/ea	750.00	/ea	-	943.74	944	
	Pipe Plain End-Ductile Iron--C-151 54 Inch (1350mm)	A541002200000	40-05-19.20	7.67	lf	-	-	1,982.00	/lf	22.00	2,004.00	15,367	
	Fitting Flanged & Bolted-Ductile Iron-ElI90-Non-Specific 54 Inch (1350mm)	A542412000000	40-05-19.20	4.00	ea	-	-	14,950.00	/ea	400.00	15,350.00	61,400	
	Fitting Flanged & Bolted-Ductile Iron-Tee-Non-Specific 54 Inch (1350mm)	A542414000000	40-05-19.20	4.00	ea	-	-	60,128.38	/ea	400.00	60,528.38	242,114	
	Pipe Erection-Straight Run-Ductile Iron-Non-Specific 54 Inch (1350mm)	L5440020000P1	40-05-19.20	90.00	lf	266.78	/lf	-	-	8.00	274.78	24,730	
	Pipe Erection-Handle Valves-Metal-Non-Specific 54 Inch (1350mm)	L544062000000	40-05-51.00	2.00	ea	3,419.32	/ea	-	-	-	3,419.32	6,839	
	Valve Flanged & Bolted-Cast Steel-Butterfly-Cls 150, 54 Inch, includes electric actu	A546434016200	40-05-64.00	2.00	ea	-	-	72,000.00	/ea	-	72,000.00	144,000	
	<b>Ductile Iron Pipe, 54" Diameter</b>		<b>90.00</b>	<b>lf</b>	<b>/lf</b>	<b>656.89</b>	<b>/lf</b>	<b>5,138.24</b>	<b>/lf</b>	<b>888.89</b>	<b>45.43</b>	<b>6,729.45</b>	<b>165,650</b>
<b>12 Alternative 2</b>													
<b>13 Alternative 4 and 4B</b>													
<b>01999 Mobilization and Demobilization</b>													
	Mobilization	BC-0027	01-00-10.00	2.00	day	-	-	126.60	/day	-	126.60	253	
	Demobilization	BC-0028	01-00-10.00	2.00	day	-	-	126.60	/day	-	126.60	253	
	<b>Mobilization and Demobilization</b>		<b>1.00</b>	<b>ls</b>	<b>/ls</b>	<b>/ls</b>	<b>506.40</b>	<b>/ls</b>	<b>/ls</b>	<b>506.40</b>	<b>506</b>		
<b>40120 Ductile Iron Pipe, 54" Diameter</b>													
	Coatings & paints, B & C coating system E-1 (Epoxy, metal pipe)	BC-0001	09-91-06.41	2,403.32	sqft	0.94	/sqft	0.89	/sqft	-	1.83	4,401	
	Electrical, allowance	MISC	26-99-99.99	1.00	ls	-	-	100,000.00	/ls	-	100,000.00	100,000	
	Pipe Erection-Handle Fittings-Metal-Std 54 Inch (1350mm)	L543466010000	40-05-05.00	8.00	ea	428.65	/ea	-	-	-	428.65	3,429	
	Field Testing-Hydrotest-Non-Specific 54 Inch (1350mm)	L549048000000	40-05-05.00	170.00	lf	255.16	/lf	-	-	-	255.16	43,376	
	Hilti-Chemical Anchor - Pipe Support Size 54 Inch (1350mm)	A546043000000	40-05-07.00	7.00	ea	48.44	/ea	75.00	/ea	-	123.44	864	
	Pipe Support 54 Inch (1350mm)	A546044000000	40-05-07.00	2.00	ea	290.61	/ea	750.00	/ea	-	1,040.61	2,081	
	Hanger Rod 54 Inch (1350mm)	A546045000000	40-05-07.00	2.00	ea	193.74	/ea	750.00	/ea	-	943.74	1,887	
	Pipe Plain End-Ductile Iron--C-151 54 Inch (1350mm)	A541002200000	40-05-19.20	170.00	lf	-	-	1,982.00	/lf	22.00	2,004.00	340,680	



# Estimate Detail Report

1/30/2019 8:29 AM

BC Project Number: 150811.009.091

Estimate Version Number: 2

Estimate Date: 1-30-2019

Lead Estimator: Ryan Manocchio

Spreadsheet Level	Item	Phase	Quantity	Labor Cost/Unit	Material Cost/Unit	Sub Cost/Unit	Equip Cost/Unit	Other Cost/Unit	Total Cost/Unit	Total Amount	
<b>40120 Ductile Iron Pipe, 54" Diameter</b>											
	Fitting Flanged & Bolted-Ductile Iron-ElI90-Non-Specific 54 Inch (1350mm)	A542412000000	40-05-19.20	4.00 ea	-	14,950.00 /ea	-	150.00 /ea	-	15,100.00 /ea	60,400
	Fitting Flanged & Bolted-Ductile Iron-Tee-Non-Specific 54 Inch (1350mm)	A542414000000	40-05-19.20	4.00 ea	-	60,128.38 /ea	-	150.00 /ea	-	60,278.38 /ea	241,114
	Pipe Erection-Straight Run-Ductile Iron-Non-Specific 54 Inch (1350mm)	L5440020000P1	40-05-19.20	170.00 lf	266.78 /lf	-	-	-	-	266.78 /lf	45,353
	Pipe Erection-Handle Valves-Metal-Non-Specific 54 Inch (1350mm)	L544062000000	40-05-51.00	3.00 ea	3,419.32 /ea	-	-	-	-	3,419.32 /ea	10,258
	Valve Flanged & Bolted-Cast Steel-Butterfly-Cls 150, 54 Inch, includes electric actu	A546434016200	40-05-64.00	3.00 ea	-	72,000.00 /ea	-	-	-	72,000.00 /ea	216,000
	<b>Ductile Iron Pipe, 54" Diameter</b>			<b>170.00 lf</b>	<b>623.47 /lf</b>	<b>5,052.43 /lf</b>	<b>588.24 /lf</b>	<b>29.06 /lf</b>	<b>/lf</b>	<b>6,293.19 /lf</b>	<b>1,069,843</b>
	<b>13 Alternative 4 and 4B</b>										<b>1,070,349</b>
	<b>03 Flow Splitting MLSS</b>										<b>1,837,530</b>

## 04 Cooling Water Piping and Pumps

### 14 Alternate 1: Effluent and New Pumps

<b>02221 Sidewalk Demolition</b>											
	Minor site demolition, sidewalk, concrete, mesh reinforced, 4" thick, remove, exclud	4200	02-41-13.33	105.56 sy	11.96 /sy	-	-	2.12 /sy	-	14.09 /sy	1,487
	Minor site demolition, for disposal to 5 miles, excludes hauling, add	4500	02-41-13.33	11.61 cy	7.95 /cy	-	-	8.37 /cy	-	16.32 /cy	189
	Rubbish handling, dumpster, 40 C.Y., 13 ton capacity, weekly rental, includes one c	0840	02-41-19.23	1.00 week	-	775.00 /week	-	-	-	775.00 /week	775
	<b>Sidewalk Demolition</b>			<b>950.00 sf</b>	<b>1.43 /sf</b>	<b>0.82 /sf</b>	<b>/sf</b>	<b>0.34 /sf</b>	<b>/sf</b>	<b>2.58 /sf</b>	<b>2,452</b>

### 03330 Concrete Equipment Pad, 4' x 12'-6" x 9"

	Aggregate, stone, 3/4" to 1-1/2", prices per C.Y., includes material only	1050	03-05-13.25	1.85 cy	-	33.50 /cy	-	-	-	33.50 /cy	62
	C.I.P. concrete forms, slab on grade, edge, wood, 7" to 12" high, 4 use, includes en	3050	03-11-13.65	48.00 sfca	5.91 /sfca	0.69 /sfca	-	-	-	6.60 /sfca	317
	Sawcut control joints, slab on grade	X9000	03-15-05.25	20.00 lf	0.78 /lf	0.75 /lf	-	0.27 /lf	-	1.80 /lf	36
	Reinforcing steel, in place, slab on grade, #3 to #7, A615, grade 60, incl labor for ac	0600	03-21-10.60	0.13 ton	1,361.50 /ton	960.00 /ton	-	-	-	2,321.50 /ton	290
	Reinforcing in place, unloading & sorting, add to above - slabs	2005	03-21-10.60	0.13 ton	52.90 /ton	-	-	6.00 /ton	-	58.90 /ton	7
	Structural concrete, ready mix, normal weight, 4000 psi, includes local aggregate, sanc	0300	03-31-05.35	2.92 cy	-	128.00 /cy	-	-	-	128.00 /cy	373
	Structural concrete, placing, slab on grade, direct chute, over 6" thick, includes vibr	4600	03-31-05.70	2.92 cy	21.36 /cy	-	-	0.32 /cy	-	21.67 /cy	63
	Concrete finishing, floors, monolithic, screed, float and broom finish	0150	03-35-29.30	100.00 sf	1.00 /sf	-	-	-	-	1.00 /sf	100
	Concrete finishing, floor, dustproofing, solvent-based, 1 coat	3800	03-35-29.30	100.00 sf	0.34 /sf	0.16 /sf	-	-	-	0.50 /sf	50
	Curing, sprayed membrane curing compound	0300	03-39-13.50	1.00 csf	11.97 /csf	12.10 /csf	-	-	-	24.07 /csf	24
	Fine grading, fine grade for slab on grade, machine	1100	31-22-16.10	11.11 sy	1.20 /sy	-	-	0.63 /sy	-	1.83 /sy	20
	<b>Concrete Equipment Pad, 4' x 12'-6" x 9"</b>			<b>100.00 cy</b>	<b>6.98 /cy</b>	<b>6.32 /cy</b>	<b>/cy</b>	<b>0.14 /cy</b>	<b>/cy</b>	<b>13.43 /cy</b>	<b>1,343</b>

### 22999 30 HP Pumps

	Misc. plumbing piping, fittings and connection to pumps, allowance	MISC	22-99-99.99	1.00 ls	-	-	4,000.00 /ls	-	-	4,000.00 /ls	4,000
	Electrical and I&C for pumps, allowance	BC-0001	26-00-00.01	1.00 ls	-	-	3,000.00 /ls	-	-	3,000.00 /ls	3,000
	Pump, cntlgl, horiz mtd, end suct,vert split,sgl stg,750GPM,30HP,4"D	BC-0101	46-06-18.00	2.00 ea	1,915.38 /ea	4,550.00 /ea	-	450.00 /ea	-	6,915.38 /ea	13,831
	<b>30 HP Pumps</b>			<b>2.00 ea</b>	<b>1,915.38 /ea</b>	<b>4,550.00 /ea</b>	<b>3,500.00 /ea</b>	<b>450.00 /ea</b>	<b>/ea</b>	<b>10,415.38 /ea</b>	<b>20,831</b>

### 32740 Sidewalks, 4" Thick

	Fine grading, for roadway, base or leveling course, large area, 6,000 S.Y. or more	0100	31-22-16.10	105.56 sy	0.63 /sy	-	-	0.33 /sy	-	0.95 /sy	101
	Sidewalks, driveways, and patios, sidewalk, concrete, cast-in-place with 6 x 6 - W1.	0310	32-06-10.10	950.00 sf	3.13 /sf	2.01 /sf	-	-	-	5.14 /sf	4,885
	Sidewalks, driveways, and patios, sidewalks, concrete, excludes base, for 4" thick t	0450	32-06-10.10	950.00 sf	0.70 /sf	0.43 /sf	-	0.02 /sf	-	1.14 /sf	1,087
	<b>Sidewalks, 4" Thick</b>			<b>950.00 sf</b>	<b>3.90 /sf</b>	<b>2.44 /sf</b>	<b>/sf</b>	<b>0.05 /sf</b>	<b>/sf</b>	<b>6.39 /sf</b>	<b>6,072</b>

### 33500 Trench for Utilities, 6" DIP

	Excavating, trench or continuous footing, common earth, 1-1/2 C.Y. excavator, 10' t	1000	31-23-16.13	1,104.44 bcy	2.36 /bcy	-	-	1.69 /bcy	-	4.05 /bcy	4,470
	Backfill, trench, 6" to 12" lifts, dozer backfilling, compaction with sheepsfoot roller	2300	31-23-23.13	1,100.83 cy	1.49 /ecy	-	-	2.67 /ecy	-	4.15 /ecy	4,572
	Hauling, excavated or borrow material, loose cubic yards, 3 mile round trip, 2.1 loac	0150	31-23-23.18	3.61 lcy	7.55 /lcy	-	-	4.32 /lcy	-	11.87 /lcy	43
	Trench box and jacks, cost per sfca trench wall, monthly rental	X9010	31-41-13.10	400.00 sf	-	-	7.81 /sf	-	-	7.81 /sf	3,124
	Utility line signs, markers, and flags, underground tape, detectable, reinforced, alur	0400	33-05-97.10	5.00 clf	3.79 /clf	9.00 /clf	-	-	-	12.79 /clf	64
	<b>Trench for Utilities, 6" DIP</b>			<b>497.00 lf</b>	<b>8.63 /lf</b>	<b>0.09 /lf</b>	<b>6.29 /lf</b>	<b>9.69 /lf</b>	<b>/lf</b>	<b>24.69 /lf</b>	<b>12,273</b>

### 40120 Ductile Iron Pipe, 6" Diameter

	Coatings & paints, B & C coating system E-1 (Epoxy, metal pipe)	BC-0001	09-91-06.41	1,880.24 sqft	0.94 /sqft	0.89 /sqft	-	-	-	1.83 /sqft	3,443
	Pipe Erection-Handle Fittings-Metal-Std 6 Inch (150mm)	L153466010000	40-05-05.00	21.00 ea	63.06 /ea	-	-	-	-	63.06 /ea	1,324
	Field Testing-Hydrotest-Non-Specific 6 Inch (150mm)	L159048000000	40-05-05.00	1,197.00 lf	4.84 /lf	-	-	-	-	4.84 /lf	5,798
	Pipe Plain End-Ductile Iron-C-151 6 Inch (150mm)	A151002200000	40-05-19.20	1,197.00 lf	-	20.00 /lf	-	-	-	20.00 /lf	23,940
	Fitting Flanged & Bolted-Ductile Iron-ElI45-Cls 150 6 Inch (150mm)	A152411006200	40-05-19.20	6.00 ea	-	252.86 /ea	-	60.00 /ea	-	312.86 /ea	1,877
	Fitting Flanged & Bolted-Ductile Iron-ElI90-Cls 150 6 Inch (150mm)	A152412006200	40-05-19.20	13.00 ea	-	405.00 /ea	-	60.00 /ea	-	465.00 /ea	6,045
	Fitting Flanged & Bolted-Ductile Iron-Tee-Cls 150 6 Inch (150mm)	A152414006200	40-05-19.20	2.00 ea	-	491.38 /ea	-	60.00 /ea	-	551.38 /ea	1,103
	Pipe Erection-Straight Run-Ductile Iron-Non-Specific 6 Inch (150mm)	L1540020000P1	40-05-19.20	1,197.00 lf	30.51 /lf	-	-	2.50 /lf	-	33.01 /lf	39,518



# Estimate Detail Report

1/30/2019 8:29 AM  
 BC Project Number: 150811.009.091  
 Estimate Version Number: 2  
 Estimate Date: 1-30-2019  
 Lead Estimator: Ryan Manocchio

Spreadsheet Level	Item	Phase	Quantity	Labor Cost/Unit	Material Cost/Unit	Sub Cost/Unit	Equip Cost/Unit	Other Cost/Unit	Total Cost/Unit	Total Amount	
<b>40120 Ductile Iron Pipe, 6" Diameter</b>											
	Insulation-Urethane Foam Aluminum Jacket 6 Inch (150mm) Dia 2 Inch (50mm)	A1500917409	40-42-13.00	1,197.00 /lf	28.61 /lf	21.05 /lf	-	-	49.66 /lf	59,440	
	<b>Ductile Iron Pipe, 6" Diameter</b>			<b>1,197.00 /lf</b>	<b>66.56 /lf</b>	<b>48.93 /lf</b>	<b>/lf</b>	<b>3.55 /lf</b>	<b>/lf</b>	<b>119.04 /lf</b>	<b>142,487</b>
	<b>14 Alternate 1: Effluent and New Pumps</b>										
	<b>142,487</b>										
	<b>185,458</b>										
<b>15 Alternate 2: Effluent and Wet Well Vault</b>											
<b>33635 Utility Vault</b>											
	Roof hatch, with curb, 1" fiberglass insulation, galvanized steel curb & cover, 4' x 4'	1140	07-72-33.10	1.00 ea	332.90 /ea	1,100.00 /ea	-	-	1,432.90 /ea	1,433	
	Excavate pit, common earth, hyd backhoe, 3/4 CY bucket	X9010	31-23-16.13	74.07 cy	14.16 /cy	-	7.59 /cy	-	21.75 /cy	1,611	
	Backfill, trench, air tamped compaction, add	2000	31-23-23.13	42.90 ecy	15.32 /ecy	-	3.64 /ecy	-	18.96 /ecy	813	
	Hauling, excavated or borrow material, loose cubic yards, 3 mile round trip, 2.1 loac	0150	31-23-23.18	31.17 lcy	7.55 /lcy	-	4.32 /lcy	-	11.87 /lcy	370	
	Trench box and jacks, cost per sfca trench wall, monthly rental	X9010	31-41-13.10	800.00 sf	-	7.81 /sf	-	-	7.81 /sf	6,249	
	Utility structures, utility vaults precast concrete, meter pit, 6' x 10', 20' deep, exclude	BC-0091	33-12-19.41	1.00 ea	4,486.68 /ea	18,554.00 /ea	-	1,194.00 /ea	24,234.68 /ea	24,235	
	<b>Utility Vault</b>			<b>1.00 ea</b>	<b>6,761.27 /ea</b>	<b>19,654.00 /ea</b>	<b>6,248.80 /ea</b>	<b>2,046.67 /ea</b>	<b>/ea</b>	<b>34,710.74 /ea</b>	<b>34,711</b>
<b>40120 Ductile Iron Pipe, 8" Diameter</b>											
	Coatings & paints, B & C coating system E-1 (Epoxy, metal pipe)	BC-0001	09-91-06.41	314.16 sqft	0.94 /sqft	0.89 /sqft	-	-	1.83 /sqft	575	
	Pipe Erection-Handle Fittings-Metal-Std 8 Inch (200mm)	L163466010000	40-05-05.00	6.00 ea	84.96 /ea	-	-	-	84.96 /ea	510	
	Field Testing-Hydrotest-Non-Specific 8 Inch (200mm)	L169048000000	40-05-05.00	150.00 lf	7.46 /lf	-	-	-	7.46 /lf	1,119	
	Hilti-Chemical Anchor - Pipe Support Size 8 Inch (200mm)	A166043000000	40-05-07.00	6.00 ea	29.06 /ea	25.00 /ea	-	-	54.06 /ea	324	
	Pipe Support 8 Inch (200mm)	A166044000000	40-05-07.00	3.00 ea	96.87 /ea	25.00 /ea	-	-	121.87 /ea	366	
	Hanger Rod 8 Inch (200mm)	A166045000000	40-05-07.00	3.00 ea	38.75 /ea	150.00 /ea	-	-	188.75 /ea	566	
	Pipe Plain End-Ductile Iron-C-151 8 Inch (200mm)	A161002200000	40-05-19.20	142.67 lf	-	20.00 /lf	-	-	20.00 /lf	2,853	
	Fitting Flanged & Bolted-Ductile Iron-EI145-Non-Specific 8 Inch (200mm)	A162411000000	40-05-19.20	1.00 ea	-	413.78 /ea	80.00 /ea	-	493.78 /ea	494	
	Fitting Flanged & Bolted-Ductile Iron-EI190-Non-Specific 8 Inch (200mm)	A162412000000	40-05-19.20	5.00 ea	-	725.00 /ea	80.00 /ea	-	805.00 /ea	4,025	
	Pipe Erection-Straight Run-Ductile Iron-Non-Specific 8 Inch (200mm)	L1640020000P1	40-05-19.20	150.00 lf	34.00 /lf	-	3.00 /lf	-	37.00 /lf	5,550	
	Insulation-Urethane Foam Aluminum Jacket 8 Inch (200mm) Dia 2 Inch (50mm)	A1600917409	40-42-13.00	150.00 lf	33.91 /lf	25.67 /lf	-	-	59.58 /lf	8,937	
	<b>Ductile Iron Pipe, 8" Diameter</b>			<b>150.00 lf</b>	<b>84.62 /lf</b>	<b>77.98 /lf</b>	<b>/lf</b>	<b>6.20 /lf</b>	<b>/lf</b>	<b>168.80 /lf</b>	<b>25,319</b>
	<b>15 Alternate 2: Effluent and Wet Well Vault</b>										
	<b>60,030</b>										
<b>16 Alternate 3: Sand Filter</b>											
<b>26999 Electrical Work</b>											
	120 Volt electrical connection to skid and SCADA connections, allowance	MISC	26-99-99.99	1.00 ls	-	10,000.00 /ls	-	-	10,000.00 /ls	10,000	
	<b>Electrical Work</b>			<b>1.00 ls</b>	<b>/ls</b>	<b>10,000.00 /ls</b>	<b>/ls</b>	<b>/ls</b>	<b>10,000.00 /ls</b>	<b>10,000</b>	
<b>33999 Sand Filter</b>											
	Automatic backwash sand filter, see quote from Ecologix	MISC	33-99-99.99	1.00 ls	5,200.00 /ls	43,000.00 /ls	1,600.00 /ls	-	49,800.00 /ls	49,800	
	<b>Sand Filter</b>			<b>1.00 ls</b>	<b>5,200.00 /ls</b>	<b>43,000.00 /ls</b>	<b>1,600.00 /ls</b>	<b>/ls</b>	<b>49,800.00 /ls</b>	<b>49,800</b>	
<b>40120 Ductile Iron Pipe, 8" Diameter</b>											
	Coatings & paints, B & C coating system E-1 (Epoxy, metal pipe)	BC-0001	09-91-06.41	83.78 sqft	0.94 /sqft	0.89 /sqft	-	-	1.83 /sqft	153	
	1" Compressed air connection	X9630	22-05-05.10	1.00 ea	605.49 /ea	400.00 /ea	-	-	1,005.49 /ea	1,005	
	Pipe Erection-Handle Fittings-Metal-Std 8 Inch (200mm)	L163466010000	40-05-05.00	3.00 ea	84.95 /ea	-	-	-	84.95 /ea	255	
	Field Testing-Hydrotest-Non-Specific 8 Inch (200mm)	L169048000000	40-05-05.00	40.00 lf	7.46 /lf	-	-	-	7.46 /lf	298	
	Hilti-Chemical Anchor - Pipe Support Size 8 Inch (200mm)	A166043000000	40-05-07.00	2.00 ea	29.06 /ea	25.00 /ea	-	-	54.06 /ea	108	
	Pipe Support 8 Inch (200mm)	A166044000000	40-05-07.00	1.00 ea	96.87 /ea	25.00 /ea	-	-	121.87 /ea	122	
	Hanger Rod 8 Inch (200mm)	A166045000000	40-05-07.00	1.00 ea	38.75 /ea	150.00 /ea	-	-	188.75 /ea	189	
	Pipe Plain End-Ductile Iron-C-151 8 Inch (200mm)	A161002200000	40-05-19.20	40.00 lf	-	20.00 /lf	-	-	20.00 /lf	800	
	Fitting Flanged & Bolted-Ductile Iron-EI190-Non-Specific 8 Inch (200mm)	A162412000000	40-05-19.20	2.00 ea	-	725.00 /ea	80.00 /ea	-	805.00 /ea	1,610	
	Fitting Flanged & Bolted-Ductile Iron-Tee-Non-Specific 8 Inch (200mm)	A162414000000	40-05-19.20	1.00 ea	-	1,202.55 /ea	80.00 /ea	-	1,282.55 /ea	1,283	
	Pipe Erection-Straight Run-Ductile Iron-Non-Specific 8 Inch (200mm)	L1640020000P1	40-05-19.20	40.00 lf	34.00 /lf	-	2.50 /lf	-	36.50 /lf	1,460	
	Insulation-Urethane Foam Aluminum Jacket 8 Inch (200mm) Dia 2 Inch (50mm)	A1600917409	40-42-13.00	40.00 lf	33.91 /lf	25.67 /lf	-	-	59.58 /lf	2,383	
	<b>Ductile Iron Pipe, 8" Diameter</b>			<b>40.00 lf</b>	<b>103.70 /lf</b>	<b>129.47 /lf</b>	<b>/lf</b>	<b>8.50 /lf</b>	<b>/lf</b>	<b>241.67 /lf</b>	<b>9,667</b>
	<b>16 Alternate 3: Sand Filter</b>										
	<b>69,467</b>										
	<b>04 Cooling Water Piping and Pumps</b>										
	<b>314,955</b>										
<b>05 Digester Gallery Rehab</b>											
<b>17 Mechanical and Electrical Upgrades</b>											
<b>23550 HVAC Equipment, Conceptual</b>											
	General exhaust fans, roof mount, avg. cost per cfm	X9710	23-34-13.10	6,000.00 cfm	0.07 /cfm	0.57 /cfm	-	-	0.64 /cfm	3,825	



# Estimate Detail Report

1/30/2019 8:29 AM

BC Project Number: 150811.009.091

Estimate Version Number: 2

Estimate Date: 1-30-2019

Lead Estimator: Ryan Manocchio

Spreadsheet Level	Item	Phase	Quantity	Labor Cost/Unit	Material Cost/Unit	Sub Cost/Unit	Equip Cost/Unit	Other Cost/Unit	Total Cost/Unit	Total Amount
<b>23550 HVAC Equipment, Conceptual</b>										
	Smoke exhaust fans, roof mount, avg. cost per cfm	X9730	23-34-13.10	6,000.00 cfm	0.07 /cfm	0.57 /cfm	-	-	0.64 /cfm	3,825
	Toilet exhaust fans, direct drive or v-belt, avg. cost per cfm	X9740	23-34-13.10	350.00 cfm	0.18 /cfm	0.82 /cfm	-	-	1.00 /cfm	349
	Multizone package unit, gas heat/DX cooling, curbs, to 125 tons	X9610	23-74-33.10	15.00 ton	270.02 /ton	2,125.00 /ton	-	-	2,395.02 /ton	35,925
	<b>HVAC Equipment, Conceptual</b>		<b>5,000.00 sf</b>	<b>0.99 /sf</b>	<b>7.79 /sf</b>	<b>/sf</b>	<b>/sf</b>	<b>/sf</b>	<b>8.79 /sf</b>	<b>43,924</b>
<b>26999 Electrical Work</b>										
	Electrical and low voltage replacement, 5,000 SF, see quote	MISC	26-99-99.99	1.00 ls	-	210,000.00 /ls	-	-	210,000.00 /ls	210,000
	Misc. electrical for HVAC replacement, including automatic controls and sensors (fa	MISC	26-99-99.99	1.00 ls	-	38,100.00 /ls	-	-	38,100.00 /ls	38,100
	<b>Electrical Work</b>		<b>1.00 ls</b>	<b>/ls</b>	<b>/ls</b>	<b>248,100.00 /ls</b>	<b>/ls</b>	<b>/ls</b>	<b>248,100.00 /ls</b>	<b>248,100</b>
<b>17 Mechanical and Electrical Upgrades</b>										<b>292,024</b>
<b>05 Digester Gallery Rehab</b>										<b>292,024</b>
<b>06 Bottom Bio Solids Load Out</b>										
<b>18 Miscellaneous Upgrades</b>										
<b>03330 Concrete Apron and Curb</b>										
	Aggregate, stone, 3/4" to 1-1/2", prices per C.Y., includes material only	1050	03-05-13.25	37.04 cy	-	33.50 /cy	-	-	33.50 /cy	1,241
	C.I.P. concrete forms, slab on grade, edge, wood, 7" to 12" high, 4 use, includes en	3050	03-11-13.65	180.00 sfca	5.91 /sfca	0.69 /sfca	-	-	6.60 /sfca	1,187
	Sawcut control joints, slab on grade	X9000	03-15-05.25	40.00 lf	0.78 /lf	0.75 /lf	0.27 /lf	-	1.80 /lf	72
	Reinforcing steel, in place, slab on grade, #3 to #7, A615, grade 60, incl labor for ac	0600	03-21-10.60	2.50 ton	1,361.50 /ton	960.00 /ton	-	-	2,321.50 /ton	5,804
	Reinforcing in place, unloading & sorting, add to above - slabs	2005	03-21-10.60	2.50 ton	52.88 /ton	-	6.02 /ton	-	58.90 /ton	147
	Structural concrete,ready mix,normal weight,4000 psi,includes local aggregate,sanc	0300	03-31-05.35	58.33 cy	-	128.00 /cy	-	-	128.00 /cy	7,467
	Structural concrete, placing, slab on grade, direct chute, over 6" thick, includes vibr:	4600	03-31-05.70	58.33 cy	21.36 /cy	-	0.32 /cy	-	21.67 /cy	1,264
	Concrete finishing, floors, monolithic, screed, float and broom finish	0150	03-35-29.30	2,000.00 sf	1.00 /sf	-	-	-	1.00 /sf	2,006
	Concrete finishing, floor, dustproofing, solvent-based, 1 coat	3800	03-35-29.30	2,000.00 sf	0.34 /sf	0.16 /sf	-	-	0.50 /sf	997
	Curing, sprayed membrane curing compound	0300	03-39-13.50	20.00 csf	11.97 /csf	12.10 /csf	-	-	24.07 /csf	481
	Fine grading, fine grade for slab on grade, machine	1100	31-22-16.10	222.22 sy	1.20 /sy	-	0.63 /sy	-	1.83 /sy	407
	Cast-in place concrete curbs & gutters, radius, machine formed, 6" high curb, 6" thi	0446	32-16-13.13	100.00 lf	4.04 /lf	6.75 /lf	1.33 /lf	-	12.12 /lf	1,212
	<b>Concrete Apron and Curb</b>		<b>2,000.00 cy</b>	<b>4.74 /cy</b>	<b>6.25 /cy</b>	<b>/cy</b>	<b>0.16 /cy</b>	<b>/cy</b>	<b>11.14 /cy</b>	<b>22,285</b>
<b>22999 Misc. Plumbing Work</b>										
	Valve Butt Weld-Alloy Steel-Plug-Cls 600 (PN100) 10 Inch (250mm)	A176137046700	40-05-62.00	1.00 ea	1,100.00 /ea	50,947.20 /ea	-	200.00 /ea	52,247.20 /ea	52,247
	10" Flow Meter	BC-1350	46-06-04.00	1.00 ea	1,058.16 /ea	-	-	7,950.00 /ea	9,008.16 /ea	9,008
	<b>Misc. Plumbing Work</b>		<b>0.00</b>	<b>/LS</b>	<b>/LS</b>	<b>/LS</b>	<b>/LS</b>	<b>/LS</b>	<b>/LS</b>	<b>61,255</b>
<b>26999 Misc Electrical Work</b>										
	Field control panel on building, allowance	MISC	26-99-99.99	1.00 ls	-	5,000.00 /ls	-	-	5,000.00 /ls	5,000
	<b>Misc Electrical Work</b>		<b>1.00 ls</b>	<b>/ls</b>	<b>/ls</b>	<b>5,000.00 /ls</b>	<b>/ls</b>	<b>/ls</b>	<b>5,000.00 /ls</b>	<b>5,000</b>
<b>33500 Trench for Utilities, 12" Pipe</b>										
	Excavating, trench or continuous footing, common earth, 1-1/2 C.Y. excavator, 10' t	1000	31-23-16.13	111.11 bcy	2.36 /bcy	-	1.69 /bcy	-	4.05 /bcy	450
	Backfill, trench, 6" to 12" lifts, dozer backfilling, compaction with sheepsfoot roller	2300	31-23-23.13	109.66 ecy	1.49 /ecy	-	2.67 /ecy	-	4.15 /ecy	455
	Hauling, excavated or borrow material, loose cubic yards, 3 mile round trip, 2.1 loac	0150	31-23-23.18	1.45 lcy	7.55 /lcy	-	4.32 /lcy	-	11.87 /lcy	17
	Trench box and jacks, cost per sfca trench wall, monthly rental	X9010	31-41-13.10	400.00 sf	-	-	7.81 /sf	-	7.81 /sf	3,124
	Utility line signs, markers, and flags, underground tape, detectable, reinforced, alur	0400	33-05-97.10	1.00 clf	3.79 /clf	9.00 /clf	-	-	12.79 /clf	13
	<b>Trench for Utilities, 12" Pipe</b>		<b>50.00 lf</b>	<b>8.80 /lf</b>	<b>0.18 /lf</b>	<b>62.49 /lf</b>	<b>9.72 /lf</b>	<b>/lf</b>	<b>81.19 /lf</b>	<b>4,060</b>
<b>33530 Sanitary Sewer Piping, 12" PVC</b>										
	Public sanitary utility sewerage piping, piping polyvinyl chloride pipe, B & S, 13' lenç	2160	33-31-13.25	50.00 lf	6.92 /lf	12.90 /lf	-	0.41 /lf	20.23 /lf	1,011
	<b>Sanitary Sewer Piping, 12" PVC</b>		<b>50.00 lf</b>	<b>6.92 /lf</b>	<b>12.90 /lf</b>	<b>/lf</b>	<b>0.41 /lf</b>	<b>/lf</b>	<b>20.23 /lf</b>	<b>1,011</b>
<b>33635 Catch Basins</b>										
	Excavate pit, common earth, hyd backhoe, 3/4 CY bucket	X9010	31-23-16.13	81.48 cy	14.16 /cy	-	7.59 /cy	-	21.75 /cy	1,772
	Backfill, trench, air tamped compaction, add	2000	31-23-23.13	60.52 ecy	15.32 /ecy	-	3.64 /ecy	-	18.96 /ecy	1,147
	Hauling, excavated or borrow material, loose cubic yards, 3 mile round trip, 2.1 loac	0150	31-23-23.18	20.96 lcy	7.55 /lcy	-	4.32 /lcy	-	11.87 /lcy	249
	Trench box and jacks, cost per sfca trench wall, monthly rental	X9010	31-41-13.10	880.00 sf	-	-	7.81 /sf	-	7.81 /sf	6,874
	Utility area drain, catch basins or manholes frames and covers, cast iron, heavy tral	2100	33-42-33.13	2.00 ea	230.09 /ea	263.00 /ea	-	40.85 /ea	533.94 /ea	1,068
	Storm drainage manholes, frames and covers, concrete, cast place, 4' x 4', 8" thick,	1000	33-49-13.10	2.00 ea	4,032.48 /ea	1,125.00 /ea	-	26.11 /ea	5,183.59 /ea	10,367
	Storm drainage manholes,frames and covers,concrete,cast place,4'dm,8"thick,excl	1100	33-49-13.10	4.00 vif	504.06 /vif	123.00 /vif	-	3.27 /vif	630.33 /vif	2,521



# Estimate Detail Report

1/30/2019 8:29 AM  
 BC Project Number: 150811.009.091  
 Estimate Version Number: 2  
 Estimate Date: 1-30-2019  
 Lead Estimator: Ryan Manocchio

Spreadsheet Level	Item	Phase	Quantity	Labor Cost/Unit	Material Cost/Unit	Sub Cost/Unit	Equip Cost/Unit	Other Cost/Unit	Total Cost/Unit	Total Amount
Catch Basins			2.00 ea	6,390.42 /ea	1,634.00 /ea	3,436.84 /ea	537.92 /ea	/ea	11,999.18 /ea	23,998
<b>40120 Ductile Iron Pipe, 12" Diameter</b>										
Minor site demolition, pipe and elbows	2930	02-41-13.33	5.00 lf	12.29 /lf	-	-	9.59 /lf	-	21.88 /lf	109
Pipe Erection-Handle Fittings-Metal-Std 12 Inch (300mm)	L183466010000	40-05-05.00	4.00 ea	128.94 /ea	-	-	-	-	128.94 /ea	516
Field Testing-Hydrotest-Non-Specific 12 Inch (300mm)	L189048000000	40-05-05.00	40.00 lf	15.11 /lf	-	-	-	-	15.11 /lf	604
Pipe Plain End-Ductile Iron--C-151 12 Inch (300mm)	A181002200000	40-05-19.20	32.17 lf	-	35.00 /lf	-	-	-	35.00 /lf	1,126
Fitting Flanged & Bolted-Ductile Iron-El190-Non-Specific 12 Inch (300mm)	A182412000000	40-05-19.20	3.00 ea	-	1,375.00 /ea	-	90.00 /ea	-	1,465.00 /ea	4,395
Fitting Flanged & Bolted-Ductile Iron-Tee-Non-Specific 12 Inch (300mm)	A182414000000	40-05-19.20	1.00 ea	-	1,991.32 /ea	-	90.00 /ea	-	2,081.32 /ea	2,081
Pipe Erection-Straight Run-Ductile Iron-Non-Specific 12 Inch (300mm)	L1840020000P1	40-05-19.20	40.00 lf	60.16 /lf	-	-	4.00 /lf	-	64.16 /lf	2,566
<b>Ductile Iron Pipe, 12" Diameter</b>			40.00 lf	89.70 /lf	181.05 /lf	/lf	14.20 /lf	/lf	284.95 /lf	11,398
<b>18 Miscellaneous Upgrades</b>										129,008
<b>06 Bottom Bio Solids Load Out</b>										129,008
<b>01 TOTALS</b>										3,714,322



## Estimate Detail Report

1/30/2019 8:29 AM  
 BC Project Number: 150811.009.091  
 Estimate Version Number: 2  
 Estimate Date: 1-30-2019  
 Lead Estimator: Ryan Manocchio

### Estimate Totals

Description	Rate	Hours	Amount	Totals
Labor		8,239.686 hrs	769,288	
Material			2,092,346	
Subcontract			687,020	
Equipment		2,304.784 hrs	157,718	
Other			7,950	
			<b>3,714,322</b>	<b>3,714,322</b>
Labor Mark-up	15.000 %		115,393	
Material Mark-up	10.000 %		209,235	
Subcontractor Mark-up	10.000 %		68,702	
Construction Equipment Mark-up	10.000 %		15,772	
Other - Process Equip Mark-up	8.000 %		636	
			<b>409,738</b>	<b>4,124,060</b>
Material Shipping & Handling	2.000 %		41,847	
Material Sales Tax	6.875 %		143,849	
Other - Process Eqp Sales Tax	6.875 %		547	
<b>Net Markups</b>			<b>186,243</b>	<b>4,310,303</b>
Contractor General Conditions	15.000 %		646,545	
			<b>646,545</b>	<b>4,956,848</b>
Start-Up, Training, O&M	2.000 %		99,137	
			<b>99,137</b>	<b>5,055,985</b>
Undesign/Undevelop Contingency	30.000 %		1,516,795	
			<b>1,516,795</b>	<b>6,572,780</b>
Bldg Risk, Liability Auto Ins	2.000 %		131,456	
			<b>131,456</b>	<b>6,704,236</b>
Payment and Performance Bonds	1.500 %		100,564	
			<b>100,564</b>	<b>6,804,800</b>
Escalation to Midpoint (ALL)	5.540 %		376,986	
<b>Gross Markups</b>			<b>376,986</b>	<b>7,181,786</b>
<b>Total</b>				<b>7,181,786</b>

## **Attachment F: Heat Exchanger Quotation**

---

Tranter via Electric Pump





## Performance Specification

Customer: Brown and Caldwell  
 Nancy Andrews  
 Email: nandrews@brwnald.com  
 Cust. Reference: Rochester WWTP

Date: 11/8/2019  
 Proposal No.:  
 Run No.: 1185319  
 Item No.:  
 Technician: Abresch  
 Units Required: 1

**Model: GXD-051-H-5-NR-189**

**Intended End Use:** Heat exchanger to heat 40% EthGlycol (aq) 11.5 °F using 57 °F Effluent with pressure drop at or below 15 psi on hot side and at or below 15 psi on cold side.

	<b>Hot Side</b>		<b>Cold Side</b>		
Fluid Name	Effluent		40% EthGlycol (aq)		
<b>OPERATING DATA</b>	<b>Inlet</b>	<b>Outlet</b>	<b>Inlet</b>	<b>Outlet</b>	
Total Liquid flow	GPM	1,500.00	1,500.00	1,500.00	1,500.00 GPM
Operating Temperature	°F	57.00	47.02	40.00	51.50 °F
Pressure drop (allowed / calc.)	psi	15.00 / 14.92		15.00 / 14.84 psi	
Total Heat Exchanged	Btu/h			7,529,437	
U-Service	Btu/(h·ft <sup>2</sup> ·°F)			1,092	
Total Heat Transfer Area	ft <sup>2</sup>			1,107.07	
LMTD	°F			6.23	

<b>FLUID PROPERTIES</b>		<b>Inlet</b>	<b>Outlet</b>	<b>Inlet</b>	<b>Outlet</b>
Specific Gravity	-	1.00	1.00	1.06	1.06
Specific Heat	Btu/(lb·°F)	1.00	1.01	0.82	0.83
Thermal Conductivity	Btu/(h·ft·°F)	0.34	0.33	0.26	0.26
Viscosity (avg.)	cP	1.31	1.49	4.79	3.79

### CONNECTIONS

	S1	S3	S2	S4
Position				
Type	STUDDER	STUDDER	STUDDER	STUDDER
Liner	no liner	no liner	no liner	no liner
Size	6"	6"	6"	6"
Rating	ANSI 16.5 150#	ANSI 16.5 150#	ANSI 16.5 150#	ANSI 16.5 150#
Material	SA-516-70 Carbon Steel	SA-516-70 Carbon Steel	SA-516-70 Carbon Steel	SA-516-70 Carbon Steel

### CONSTRUCTION

Pass Arrangement		1	1
Channel Arrangement		75HS+19HD	19HS+75HD
A-Dimension / C-Dimension	in	28.27 / 94	
Plate Material (Material/Thickness)		304 SS / 0.5 mm	
Gasket Material (Hot/Cold)		NBR	NBR
No. of Plates		189	
Frame material / Paint / Color		SA-516-70 Carbon Steel / Enamel / RAL 5012 (Royal Blue)	
Tightening Bolts/Nuts/Finish		SA-193-B7 / 8/2H Tie Nuts / FZB	
Pressure (design / test)	psi(g)	150.00 / 195.00	150.00 / 195.00
Temperature (min / design)	°F	14.00 / 150.00	14.00 / 150.00
Weight empty / flooded (per unit)	lbs	2,832 / 3,547	
Pressure vessel code		ASME	

### Remarks:

Plate Gap is 4.00 MM

*The performance guarantee, if applicable, is based on the accuracy of the data presented above, and the customers ability to supply product and operating conditions in conformance with the above.*

Tranter, Inc. C/O Electric Pump, Inc. 201 4th Avenue SW New Prague, Minnesota 56071

Phn: 612-889-7251 Fax: 515-265-8079 Email: craiga@electricpump.com



## Quotation

Customer: Brown and Caldwell  
 Nancy Andrews  
 Email: nandrews@brwncald.com  
 Cust. Reference: Rochester WWTP

Date: 11/8/2019  
 Proposal No.:  
 Run No.: 1185319  
 Item No.:  
 Technician: Abresch  
 Units Required: 1

**Model: GXD-051-H-5-NR-189**

Pass Arrangement: 1 x 1  
 Plates Material: 304 SS  
 Fitting Material: SA-516-70 Carbon Steel  
 Gasket Material: NBR / NBR

Total Heat Transfer Area: 1,107.07 ft<sup>2</sup>

<b>HEAT EXCHANGER PRICING (USD)</b>			
ITEM	UNIT PRICE	QTY	TOTAL
<b>GXD-051-H-5-NR-189</b>	<b>20,914.00</b>	<b>1</b>	<b>20,914.00</b>
<b>Shroud</b>	<b>191.00</b>	<b>1</b>	<b>191.00</b>
<b>GRAND TOTAL:</b>			<b>21,105.00</b>

**Please address any Purchase Order resulting from this quotation to Tranter, Inc. C/O Electric Pump, Inc.**

Our normal shipping estimate is 8 weeks after receipt of order. This estimate is based upon *after receipt of order and after final drawing approvals*, as required.

Shipping terms are F.O.B. Wichita Falls, Texas, freight collect.

Prices are firm for sixty days and subject to change without notice thereafter. Our payment terms are **Net Thirty Days**. No provision is made for Federal, State, or Municipal taxes. All orders are subject to credit approval and acceptance by Tranter, Inc.. The terms of this agreement incorporate and are subject to Tranter, Inc's standard terms of sale.


Sales and Support Contact:  
 Tranter, Inc. C/O Electric Pump, Inc.  
 201 4th Avenue SW  
 New Prague, Minnesota 56071  
 612-889-7251  
 515-265-8079(Fax)  
 craiga@electricpump.com

*The performance guarantee, if applicable, is based on the accuracy of the data presented above, and the customers ability to supply product and operating conditions in conformance with the above.*

Tranter, Inc. C/O Electric Pump, Inc. 201 4th Avenue SW New Prague, Minnesota 56071  
 Phn: 612-889-7251 Fax: 515-265-8079 Email: craiga@electricpump.com

## SUPERCHANGER ASSEMBLY GXD-051-H-5-NR-189

**Sizing Number**  
1185319



**Hot Inlet(H-I)**  
Type: STUDDERD  
Size: 6"  
Rating: ANSI 16.5 150#  
Material: SA-516-70 Carbon Steel

**Hot Outlet(H-O)**  
Type: STUDDERD  
Size: 6"  
Rating: ANSI 16.5 150#  
Material: SA-516-70 Carbon Steel

**Cold Inlet(C-I)**  
Type: STUDDERD  
Size: 6"  
Rating: ANSI 16.5 150#  
Material: SA-516-70 Carbon Steel

**Cold Outlet(C-O)**  
Type: STUDDERD  
Size: 6"  
Rating: ANSI 16.5 150#  
Material: SA-516-70 Carbon Steel

Dimensions are for reference purposes only and are not to be used for construction.



## Performance Specification

Customer: Brown and Caldwell  
 Nancy Andrews  
 Email: nandrews@brwnald.com  
 Cust. Reference: Rochester WWTP

Date: 11/8/2019  
 Proposal No.:  
 Run No.: 1186187  
 Item No.:  
 Technician: Abresch  
 Units Required: 1

**Model: GXD-051-H-5-NR-189**

**Intended End Use:** Heat exchanger to heat 40% EthGlycol (aq) 11.5 °F using 57 °F Effluent with pressure drop at or below 15 psi on hot side and at or below 15 psi on cold side.

		<b>Hot Side</b>		<b>Cold Side</b>		
Fluid Name		Effluent		40% EthGlycol (aq)		
<b>OPERATING DATA</b>		<b>Inlet</b>	<b>Outlet</b>	<b>Inlet</b>	<b>Outlet</b>	
Total Liquid flow	GPM	1,500.00	1,500.00	1,500.00	1,500.00	GPM
Operating Temperature	°F	57.00	47.02	40.00	51.50	°F
Pressure drop (allowed / calc.)	psi	15.00 / 14.92		15.00 / 14.84		psi
Total Heat Exchanged	Btu/h			7,529,437		
U-Service	Btu/(h·ft <sup>2</sup> ·°F)			1,092		
Total Heat Transfer Area	ft <sup>2</sup>			1,107.07		
LMTD	°F			6.23		

<b>FLUID PROPERTIES</b>		<b>Inlet</b>	<b>Outlet</b>	<b>Inlet</b>	<b>Outlet</b>
Specific Gravity	-	1.00	1.00	1.06	1.06
Specific Heat	Btu/(lb·°F)	1.00	1.01	0.82	0.83
Thermal Conductivity	Btu/(h·ft·°F)	0.34	0.33	0.26	0.26
Viscosity (avg.)	cP	1.31	1.49	4.79	3.79

### CONNECTIONS

	S1	S3	S2	S4
Position				
Type	STUDDER	STUDDER	STUDDER	STUDDER
Liner	no liner		no liner	
Size	6"		6"	
Rating	ANSI 16.5 150#		ANSI 16.5 150#	
Material	SA-516-70 Carbon Steel		SA-516-70 Carbon Steel	

### CONSTRUCTION

Pass Arrangement		1	1
Channel Arrangement		75HS+19HD	19HS+75HD
A-Dimension / C-Dimension	in	28.27 / 94	
Plate Material (Material/Thickness)		316 SS / 0.5 mm	
Gasket Material (Hot/Cold)		NBR	
No. of Plates		189	
Frame material / Paint / Color		SA-516-70 Carbon Steel / Enamel / RAL 5012 (Royal Blue)	
Tightening Bolts/Nuts/Finish		SA-193-B7 / 8/2H Tie Nuts / FZB	
Pressure (design / test)	psi(g)	150.00 / 195.00	
Temperature (min / design)	°F	14.00 / 150.00	
Weight empty / flooded (per unit)	lbs	2,832 / 3,547	
Pressure vessel code		ASME	

### Remarks:

Plate Gap 4.00 MM

*The performance guarantee, if applicable, is based on the accuracy of the data presented above, and the customers ability to supply product and operating conditions in conformance with the above.*

Tranter, Inc. C/O Electric Pump, Inc. 201 4th Avenue SW New Prague, Minnesota 56071

Phn: 612-889-7251 Fax: 515-265-8079 Email: craiga@electricpump.com



## Quotation

Customer: Brown and Caldwell  
 Nancy Andrews  
 Email: nandrews@brwncald.com  
 Cust. Reference: Rochester WWTP

Date: 11/8/2019  
 Proposal No.:  
 Run No.: 1186187  
 Item No.:  
 Technician: Abresch  
 Units Required: 1

**Model: GXD-051-H-5-NR-189**

Pass Arrangement: 1 x 1  
 Plates Material: 316 SS  
 Fitting Material: SA-516-70 Carbon Steel  
 Gasket Material: NBR / NBR

Total Heat Transfer Area: 1,107.07 ft<sup>2</sup>

<b>HEAT EXCHANGER PRICING (USD)</b>			
ITEM	UNIT PRICE	QTY	TOTAL
<b>GXD-051-H-5-NR-189</b>	<b>21,827.00</b>	<b>1</b>	<b>21,827.00</b>
<b>Shroud</b>	<b>191.00</b>	<b>1</b>	<b>191.00</b>
<b>GRAND TOTAL:</b>			<b>22,018.00</b>

**Please address any Purchase Order resulting from this quotation to Tranter, Inc. C/O Electric Pump, Inc.**

Our normal shipping estimate is 8 weeks after receipt of order. This estimate is based upon *after receipt of order and after final drawing approvals*, as required.

Shipping terms are F.O.B. Wichita Falls, Texas, freight collect.

Prices are firm for sixty days and subject to change without notice thereafter. Our payment terms are **Net Thirty Days**. No provision is made for Federal, State, or Municipal taxes. All orders are subject to credit approval and acceptance by Tranter, Inc.. The terms of this agreement incorporate and are subject to Tranter, Inc's standard terms of sale.


Sales and Support Contact:  
 Tranter, Inc. C/O Electric Pump, Inc.  
 201 4th Avenue SW  
 New Prague, Minnesota 56071  
 612-889-7251  
 515-265-8079(Fax)  
 craiga@electricpump.com

*The performance guarantee, if applicable, is based on the accuracy of the data presented above, and the customers ability to supply product and operating conditions in conformance with the above.*

Tranter, Inc. C/O Electric Pump, Inc. 201 4th Avenue SW New Prague, Minnesota 56071  
 Phn: 612-889-7251 Fax: 515-265-8079 Email: craiga@electricpump.com

# SUPERCHANGER ASSEMBLY GXD-051-H-5-NR-189

**Sizing Number**  
1186187



<b>Hot Inlet(H-I)</b> Type: STUDDERD Size: 6" Rating: ANSI 16.5 150# Material: SA-516-70 Carbon Steel	<b>Hot Outlet(H-O)</b> Type: STUDDERD Size: 6" Rating: ANSI 16.5 150# Material: SA-516-70 Carbon Steel	<b>Cold Inlet(C-I)</b> Type: STUDDERD Size: 6" Rating: ANSI 16.5 150# Material: SA-516-70 Carbon Steel	<b>Cold Outlet(C-O)</b> Type: STUDDERD Size: 6" Rating: ANSI 16.5 150# Material: SA-516-70 Carbon Steel
---	--	--	---

Dimensions are for reference purposes only and are not to be used for construction.

Property of Tranter, Inc. C/O Electric Pump, Inc. and not to be reproduced without their consent nor used in any manner detrimental to the interest of Tranter, Inc. C/O Electric Pump, Inc..



## Performance Specification

Customer: Brown and Caldwell  
 Nancy Andrews  
 Email: nandrews@brwncald.com  
 Cust. Reference: Rochester WWTP

Date: 11/12/2019  
 Proposal No.:  
 Run No.: 1186426  
 Item No.:  
 Technician: Abresch  
 Units Required: 1

**Model: GXD-051-H-5-NR-189**

**Intended End Use:** Heat exchanger to cool 40% EthGlycol (aq) 9.03 °F using 72 °F Effluent with pressure drop at or below 1.68 psi on hot side and at or below 1.75 psi on cold side.

		<b>Hot Side</b>		<b>Cold Side</b>			
Fluid Name		40% EthGlycol (aq)		Effluent			
<b>OPERATING DATA</b>		<b>Inlet</b>	<b>Outlet</b>	<b>Inlet</b>	<b>Outlet</b>		
Total Liquid flow	GPM	500.00	500.00	500.00	500.00	GPM	
Operating Temperature	°F	83.00	73.97	72.00	79.97	°F	
Pressure drop (allowed / calc.)	psi	15.00 / 1.68		15.00 / 1.75		psi	
Total Heat Exchanged	Btu/h			1,991,925			
U-Service	Btu/(h·ft <sup>2</sup> ·°F)			731			
Total Heat Transfer Area	ft <sup>2</sup>			1,107.07			
LMTD	°F			2.46			
<b>FLUID PROPERTIES</b>		<b>Inlet</b>	<b>Outlet</b>	<b>Inlet</b>	<b>Outlet</b>		
Specific Gravity	-	1.05	1.05	1.00	1.00		
Specific Heat	Btu/(lb·°F)	0.85	0.84	1.00	1.00		
Thermal Conductivity	Btu/(h·ft·°F)	0.26	0.26	0.35	0.35		
Viscosity (avg.)	cP	2.20	2.54	1.06	0.95		
<b>CONNECTIONS</b>							
Position		S1	S3	S2	S4		
Type		STUDDER	STUDDER	STUDDER	STUDDER		
Liner		no liner	no liner	no liner	no liner		
Size		6"	6"	6"	6"		
Rating		ANSI 16.5 150#	ANSI 16.5 150#	ANSI 16.5 150#	ANSI 16.5 150#		
Material		SA-516-70 Carbon Steel		SA-516-70 Carbon Steel			
<b>CONSTRUCTION</b>							
Pass Arrangement		1		1			
Channel Arrangement		19HS+75HD		75HS+19HD			
A-Dimension / C-Dimension	in	28.27 / 94					
Plate Material (Material/Thickness)		316 SS / 0.5 mm					
Gasket Material (Hot/Cold)		NBR		NBR			
No. of Plates		189					
Frame material / Paint / Color		SA-516-70 Carbon Steel / Enamel / RAL 5012 (Royal Blue)					
Tightening Bolts/Nuts/Finish		SA-193-B7 / 8/2H Tie Nuts / FZB					
Pressure (design / test)	psi(g)	150.00 / 195.00		150.00 / 195.00			
Temperature (min / design)	°F	14.00 / 150.00		14.00 / 150.00			
Weight empty / flooded (per unit)	lbs	2,832 / 3,543					
Pressure vessel code		ASME					

**Remarks:**


*The performance guarantee, if applicable, is based on the accuracy of the data presented above, and the customers ability to supply product and operating conditions in conformance with the above.*

Tranter, Inc. C/O Electric Pump, Inc. 201 4th Avenue SW New Prague, Minnesota 56071

Phn: 612-889-7251 Fax: 515-265-8079 Email: craiga@electricpump.com

**SUPERCHANGER ASSEMBLY  
GXD-051-H-5-NR-189**

**Sizing Number**  
1186426



**Hot Inlet(H-I)**  
Type: STUDDERD  
Size: 6"  
Rating: ANSI 16.5 150#  
Material: SA-516-70 Carbon Steel

**Hot Outlet(H-O)**  
Type: STUDDERD  
Size: 6"  
Rating: ANSI 16.5 150#  
Material: SA-516-70 Carbon Steel

**Cold Inlet(C-I)**  
Type: STUDDERD  
Size: 6"  
Rating: ANSI 16.5 150#  
Material: SA-516-70 Carbon Steel

**Cold Outlet(C-O)**  
Type: STUDDERD  
Size: 6"  
Rating: ANSI 16.5 150#  
Material: SA-516-70 Carbon Steel


Dimensions are for reference purposes only and are not to be used for construction.





LOWER ENERGY // CLEAN DESIGN

DECREASED MAINTENANCE // INNOVATIVE PROCESSES



Technical Memorandum 1  
Technical Memorandum 2  
Technical Memorandum 3  
Technical Memorandum 4  
Technical Memorandum 5  
Technical Memorandum 6  
Technical Memorandum 7  
Technical Memorandum 8  
Technical Memorandum 9  
Technical Memorandum 10  
Technical Memorandum 11  
Technical Memorandum 12  
Technical Memorandum 13

Influent Flows and Loadings  
Wastewater Characterization and BioWin Calibration  
Plant Hydraulic Evaluation  
Primary Clarifier Computational Fluid Dynamics Modeling  
Final Clarifier Computational Fluid Dynamics Modeling  
Liquid Stream Alternative Evaluation  
Solids Alternative Evaluation  
Digester Gas Management  
Disinfection and Outfall Evaluation  
Whole Plant Evaluation  
Heat Recovery Loop Alternative  
NPDES Permitting Process  
Industrial Discharge Wasteloads and Practices